



*Pacific Gas and  
Electric Company*

**David H. Oatley**  
Vice President  
Diablo Canyon Operations

Diablo Canyon Power Plant  
P.O. Box 56  
Avila Beach, CA 93424

805.545.4350  
Fax: 805.545.4234

April 13, 2001

PG&E Letter DCL-01-034

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Docket No. 50-275, DPR-80  
Docket No. 50-323, DPR-82  
Diablo Canyon Units 1 and 2  
Monthly Operating Report for March 2001

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant,  
Units 1 and 2, for March 2001.

Please note that page 1 of Enclosure 2 specifies the revised Maximum Dependable  
Capacity and Design Electrical Rating resulting from a Unit 1 uprate in November 2000.

This report is submitted in accordance with Section 5.6.4 of the Units 1 and 2 Technical  
Specifications and NRC Generic Letter 97-02.

Sincerely,

David H. Oatley

cc: Robert D. Glynn, Jr.  
Kurt Larson  
Barbara Lewis  
Ellis W. Merschoff  
David L. Proulx  
Girija S. Shukla  
Gregory M. Rueger  
INPO Record Center

Enclosures

LMP/1713/R0218110

IE24

**MARCH 2001, OPERATION SUMMARIES  
DIABLO CANYON POWER PLANT  
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 began March in Mode 1 (Power Operation), at approximately 100 percent power. There were no significant operational activities.

Summary of Unit 2 Operation

Unit 2 began March in Mode 1, at approximately 100 percent power. There were no significant operational activities.

Actuations of Steam Generator Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the pressurizer power operated relief valves, or steam generator safety valves.

### OPERATING DATA REPORT

DOCKET NO.: 50-275  
UNIT NAME: Diablo Canyon Unit 1  
DATE: 03/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2001

1.	Design Electrical Rating (MWe - Net):	<b>1103*</b>
2.	Maximum Dependable Capacity (MWe - Net):	<b>1087*</b>

**\* Note:** These values have been revised based on a Unit 1 core thermal power uprate in November 2000 from 3338 to 3411 MWt.

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	2160.0	120821.4
4.	Number of Hours Generator On-Line:	744.0	2152.1	119495.2
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	826513	2340562	122994065

### UNIT SHUTDOWNS

DOCKET NO.: 50-275  
UNIT NAME: Diablo Canyon Unit 1  
DATE: 03/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON <sup>1</sup>	METHOD OF SHUTTING DOWN <sup>2</sup>	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training/License Examination  
F- Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

2. Method

1-Manual  
2-Manual Trip/Scram  
3-Automatic Trip/Scram  
4-Continuation from Previous Month  
5-Other

### OPERATING DATA REPORT

DOCKET NO.: 50-323  
UNIT NAME: Diablo Canyon Unit 2  
DATE: 03/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2001

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	2160.0	116696.8
4.	Number of Hours Generator On-Line:	744.0	2160.0	115303.6
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	815435	2321710	121069270

### UNIT SHUTDOWNS

DOCKET NO.: 50-323  
UNIT NAME: Diablo Canyon Unit 2  
DATE: 03/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON <sup>1</sup>	METHOD OF SHUTTING DOWN <sup>2</sup>	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training/License Examination  
F- Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

2. Method

1-Manual  
2-Manual Trip/Scram  
3-Automatic Trip/Scram  
4-Continuation from Previous Month  
5-Other