

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND ISOLATION CONDENSER (IC) SYSTEM

3.5.1 ECCS - Operating

LC0 3.5.1 Each ECCS injection/spray subsystem and the Automatic Depressurization System (ADS) function of four relief valves shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3, except high pressure coolant injection (HPCI)
and ADS valves are not required to be OPERABLE with
reactor steam dome pressure \leq 150 psig.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. One Low Pressure Coolant Injection (LPCI) pump inoperable. | A.1 Restore LPCI pump to OPERABLE status. | 30 days |
| B. One LPCI subsystem inoperable for reasons other than Condition A. <u>OR</u> One Core Spray subsystem inoperable. | B.1 Restore low pressure ECCS injection/spray subsystem to OPERABLE status. | 7 days |
| C. One LPCI pump in each subsystem inoperable. | C.1 Restore one LPCI pump to OPERABLE status. | 7 days |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| D. Two LPCI subsystems inoperable for reasons other than Condition C. | D.1 Restore one LPCI subsystem to OPERABLE status. | 72 hours |
| E. Required Action and associated Completion Time of Condition A, B, C, or D not met. | E.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> E.2 Be in MODE 4. | 36 hours |
| F. HPCI System inoperable. | F.1 Verify by administrative means IC System is OPERABLE. | Immediately |
| | <u>AND</u> F.2 Restore HPCI System to OPERABLE status. | 14 days |
| G. HPCI System inoperable. <u>AND</u> One low pressure ECCS injection/spray subsystem is inoperable or Condition C entered. | G.1 Restore HPCI System to OPERABLE status. | 72 hours |
| | <u>OR</u> G.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status. | 72 hours |
| H. One required ADS valve inoperable. | H.1 Restore ADS valve to OPERABLE status. | 14 days |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|---------------------------------|
| <p>I. Required Action and associated Completion Time of Condition F, G, or H not met.</p> <p><u>OR</u></p> <p>Two or more required ADS valves inoperable.</p> | <p>I.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>I.2 Reduce reactor steam dome pressure to ≤ 150 psig.</p> | <p>12 hours</p> <p>36 hours</p> |
| <p>J. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition C or D.</p> <p><u>OR</u></p> <p>HPCI System and one or more required ADS valves inoperable.</p> <p><u>OR</u></p> <p>One or more low pressure ECCS injection/spray subsystems inoperable and one or more required ADS valves inoperable.</p> | <p>J.1 Enter LCO 3.0.3.</p> | <p>Immediately</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | | | FREQUENCY |
|--------------|--|------------------|---------------------|--|
| SR 3.5.1.1 | Verify, for each ECCS injection/spray subsystem, the piping is filled with water from the pump discharge valve to the injection valve. | | | 31 days |
| SR 3.5.1.2 | Verify each ECCS injection/spray subsystem manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position. | | | 31 days |
| SR 3.5.1.3 | Verify correct breaker alignment to the LPCI swing bus. | | | 31 days |
| SR 3.5.1.4 | Verify each recirculation pump discharge valve cycles through one complete cycle of full travel or is de-energized in the closed position. | | | In accordance with the Inservice Testing Program |
| SR 3.5.1.5 | Verify the following ECCS pumps develop the specified flow rate against a test line pressure corresponding to the specified reactor pressure. | | | In accordance with the Inservice Testing Program |
| | <u>SYSTEM</u> | <u>FLOW RATE</u> | <u>NO. OF PUMPS</u> | <u>TEST LINE PRESSURE CORRESPONDING TO A REACTOR PRESSURE OF</u> |
| | Core | | | |
| | Spray | ≥ 4500 gpm | 1 | ≥ 90 psig |
| | LPCI | ≥ 14,500 gpm | 3 | ≥ 20 psig |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|---|
| <p>SR 3.5.1.6 -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify, with reactor pressure ≤ 1005 and ≥ 920 psig, the HPCI pump can develop a flow rate ≥ 5000 gpm against a system head corresponding to reactor pressure.</p> | <p>In accordance with the Inservice Testing Program</p> |
| <p>SR 3.5.1.7 -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify, with reactor pressure ≤ 180 psig, the HPCI pump can develop a flow rate ≥ 5000 gpm against a system head corresponding to reactor pressure.</p> | <p>24 months</p> |
| <p>SR 3.5.1.8 -----NOTE----- Vessel injection/spray may be excluded. -----</p> <p>Verify each ECCS injection/spray subsystem actuates on an actual or simulated automatic initiation signal.</p> | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| <p>SR 3.5.1.9 -----NOTE----- Valve actuation may be excluded. -----</p> <p>Verify the ADS actuates on an actual or simulated automatic initiation signal.</p> | 24 months |
| <p>SR 3.5.1.10 -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify each required ADS valve opens when manually actuated.</p> | 24 months |
| <p>SR 3.5.1.11 Verify automatic transfer capability of the LPCI swing bus power supply from the normal source to the backup source.</p> | 24 months |

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND ISOLATION CONDENSER (IC) SYSTEM

3.5.2 ECCS – Shutdown

LC0 3.5.2 Two low pressure ECCS injection/spray subsystems shall be OPERABLE.

APPLICABILITY: MODE 4,
MODE 5, except with the spent fuel storage pool gates removed and water level \geq 23 ft over the top of the reactor pressure vessel flange.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|----------------------------|
| A. One required ECCS injection/spray subsystem inoperable. | A.1 Restore required ECCS injection/spray subsystem to OPERABLE status. | 4 hours |
| B. Required Action and associated Completion Time of Condition A not met. | B.1 Initiate action to suspend operations with a potential for draining the reactor vessel (OPDRVs). | Immediately |
| C. Two required ECCS injection/spray subsystems inoperable. | C.1 Initiate action to suspend OPDRVs. <u>AND</u> C.2 Restore one required ECCS injection/spray subsystem to OPERABLE status. | Immediately 4 hours |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| D. Required Action C.2 and associated Completion Time not met. | D.1 Initiate action to restore secondary containment to OPERABLE status. | Immediately |
| | <u>AND</u> | |
| | D.2 Initiate action to restore one standby gas treatment subsystem to OPERABLE status. | Immediately |
| | <u>AND</u> | |
| | D.3 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------------|
| <p>SR 3.5.2.1 Verify, for each required ECCS injection/spray subsystem, the:</p> <p> a. Suppression pool water level is \geq 10 ft 4 inches; or</p> <p> b. -----NOTE----- Only one required ECCS injection/spray subsystem may take credit for this option during OPDRVs. -----</p> <p> Contaminated condensate storage tanks water volume is \geq 140,000 available gallons.</p> | <p>12 hours</p> |
| <p>SR 3.5.2.2 Verify, for each required ECCS injection/spray subsystem, the piping is filled with water from the pump discharge valve to the injection valve.</p> | <p>31 days</p> |
| <p>SR 3.5.2.3 Verify each required ECCS injection/spray subsystem manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p> | <p>31 days</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | | | | FREQUENCY |
|---------------|---|--------------|----------------------------|--|--|
| SR 3.5.2.4 | Verify each required ECCS pump develops the specified flow rate against a test line pressure corresponding to the specified reactor pressure. | | | | In accordance with the Inservice Testing Program |
| | | | TEST LINE PRESSURE | | |
| | | NO. OF PUMPS | CORRESPONDING TO A REACTOR | | |
| <u>SYSTEM</u> | <u>FLOW RATE</u> | | <u>PRESSURE OF</u> | | |
| CS | ≥ 4500 gpm | 1 | ≥ 90 psig | | |
| LPCI | ≥ 4500 gpm | 1 | ≥ 20 psig | | |
| SR 3.5.2.5 | -----NOTE----- Vessel injection/spray may be excluded. ----- | | | | 24 months |
| | Verify each required ECCS injection/spray subsystem actuates on an actual or simulated automatic initiation signal. | | | | |

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND ISOLATION CONDENSER (IC) SYSTEM

3.5.3 IC System

LC0 3.5.3 The IC System shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. IC System inoperable. | A.1 Verify by administrative means High Pressure Coolant Injection System is OPERABLE. | Immediately |
| | <u>AND</u> A.2 Restore IC System to OPERABLE status. | 14 days |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Reduce reactor steam dome pressure to ≤ 150 psig. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.5.3.1 Verify the IC System: a. Shellside water level \geq 6 feet; and b. Shellside water temperature \leq 210°F. | 24 hours |
| SR 3.5.3.2 Verify each IC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position. | 31 days |
| SR 3.5.3.3 Verify the IC System actuates on an actual or simulated automatic initiation signal. | 24 months |
| SR 3.5.3.4 Verify IC System heat removal capability to remove design heat load. | 60 months |

3.6 CONTAINMENT SYSTEMS

3.6.1.1 Primary Containment

LC0 3.6.1.1 Primary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Primary containment inoperable. | A.1 Restore primary containment to OPERABLE status. | 1 hour |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|--|
| SR 3.6.1.1.1 Perform required visual examinations and leakage rate testing except for primary containment air lock testing, in accordance with the Primary Containment Leakage Rate Testing Program. | In accordance with the Primary Containment Leakage Rate Testing Program |
| SR 3.6.1.1.2 Verify drywell-to-suppression chamber bypass leakage is $\leq 2\%$ of the acceptable A/\sqrt{k} design value of 0.18 ft^2 at an initial differential pressure of $\geq 1.0 \text{ psid}$. | 24 months <u>AND</u> -----NOTE----- Only required after two consecutive tests fail and continues until two consecutive tests pass ----- 12 months |

3.6 CONTAINMENT SYSTEMS

3.6.1.2 Primary Containment Air Lock

LC0 3.6.1.2 The primary containment air lock shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

- NOTES-----
1. Entry and exit is permissible to perform repairs of the air lock components.
 2. Enter applicable Conditions and Required Actions of LC0 3.6.1.1, "Primary Containment," when air lock leakage results in exceeding overall containment leakage rate acceptance criteria.
-

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|----------------------------------|
| A. One primary containment air lock door inoperable. | <p>-----NOTES-----</p> <ol style="list-style-type: none">1. Required Actions A.1, A.2, and A.3 are not applicable if both doors in the air lock are inoperable and Condition C is entered.2. Entry and exit is permissible for 7 days under administrative controls. <p>-----</p> <p>A.1 Verify the OPERABLE door is closed.</p> <p><u>AND</u></p> | <p>1 hour</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|----------------------------------|
| A. (continued) | A.2 Lock the OPERABLE door closed. | 24 hours |
| | <p><u>AND</u></p> <p>A.3 -----NOTE----- Air lock doors in high radiation areas or areas with limited access due to inerting may be verified locked closed by administrative means. -----</p> <p>Verify the OPERABLE door is locked closed.</p> | Once per 31 days |
| B. Primary containment air lock interlock mechanism inoperable. | <p>-----NOTES-----</p> <p>1. Required Actions B.1, B.2, and B.3 are not applicable if both doors in the air lock are inoperable and Condition C is entered.</p> <p>2. Entry into and exit from primary containment is permissible under the control of a dedicated individual. -----</p> | |
| | <p>B.1 Verify an OPERABLE door is closed.</p> <p><u>AND</u></p> | <p>1 hour</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|------------------|
| B. (continued) | B.2 Lock an OPERABLE door closed. | 24 hours |
| | <p><u>AND</u></p> <p>B.3 -----NOTE----- Air lock doors in high radiation areas or areas with limited access due to inerting may be verified locked closed by administrative means. -----</p> <p>Verify an OPERABLE door is locked closed.</p> | Once per 31 days |
| C. Primary containment air lock inoperable for reasons other than Condition A or B. | C.1 Initiate action to evaluate primary containment overall leakage rate per LCO 3.6.1.1, using current air lock test results. | Immediately |
| | <u>AND</u> | |
| | C.2 Verify a door is closed. | 1 hour |
| | <u>AND</u> | |
| | C.3 Restore air lock to OPERABLE status. | 24 hours |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---------------------------------|-----------------|
| D. Required Action and associated Completion Time not met. | D.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> D.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|---|
| <p>SR 3.6.1.2.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. An inoperable air lock door does not invalidate the previous successful performance of the overall air lock leakage test. 2. Results shall be evaluated against acceptance criteria applicable to SR 3.6.1.1.1. <p>-----</p> <p>Perform required primary containment air lock leakage rate testing in accordance with the Primary Containment Leakage Rate Testing Program.</p> | In accordance with the Primary Containment Leakage Rate Testing Program |
| <p>SR 3.6.1.2.2 Verify only one door in the primary containment air lock can be opened at a time.</p> | 24 months |

3.6 CONTAINMENT SYSTEMS

3.6.1.3 Primary Containment Isolation Valves (PCIVs)

LCO 3.6.1.3 Each PCIV, except reactor building-to-suppression chamber vacuum breakers, shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
When associated instrumentation is required to be OPERABLE
per LCO 3.3.6.1, "Primary Containment Isolation
Instrumentation."

ACTIONS

- NOTES-----
1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by PCIVs.
 4. Enter applicable Conditions and Required Actions of LCO 3.6.1.1, "Primary Containment," when PCIV leakage results in exceeding overall containment leakage rate acceptance criteria.
-

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---|
| <p>A. -----NOTE----- Only applicable to penetration flow paths with two or more PCIVs. ----- One or more penetration flow paths with one PCIV inoperable for reasons other than Condition D.</p> | <p>A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.</p> <p><u>AND</u></p> | <p>4 hours except for main steam line</p> <p><u>AND</u></p> <p>8 hours for main steam line</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|---|---|
| A. (continued) | <p>A.2</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p> | <p>Once per 31 days for isolation devices outside primary containment</p> <p><u>AND</u></p> <p>Prior to entering MODE 2 or 3 from MODE 4, if primary containment was de-inerted while in MODE 4, if not performed within the previous 92 days, for isolation devices inside primary containment</p> |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|---|
| <p>B. -----NOTE----- Only applicable to penetration flow paths with two or more PCIVs. -----</p> <p>One or more penetration flow paths with two or more PCIVs inoperable for reasons other than Condition D.</p> | <p>B.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p> | <p>1 hour</p> |
| <p>C. -----NOTE----- Only applicable to penetration flow paths with only one PCIV. -----</p> <p>One or more penetration flow paths with one PCIV inoperable for reasons other than Condition D.</p> | <p>C.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p> <p><u>AND</u></p> | <p>4 hours except for excess flow check valves (EFCVs) and penetrations with a closed system</p> <p><u>AND</u></p> <p>72 hours for EFCVs and penetrations with a closed system</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---------------------------------|
| C. (continued) | <p>C.2 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are a locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p> | Once per 31 days |
| D. MSIV leakage rate not within limit. | D.1 Restore leakage rate to within limit. | 8 hours |
| E. Required Action and associated Completion Time of Condition A, B, C, or D not met in MODE 1, 2, or 3. | <p>E.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>E.2 Be in MODE 4.</p> | <p>12 hours</p> <p>36 hours</p> |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| F. Required Action and associated Completion Time of Condition A, B, C, or D not met for PCIV(s) required to be OPERABLE during MODE 4 or 5. | F.1 Initiate action to suspend operations with a potential for draining the reactor vessel (OPDRVs). | Immediately |
| | <u>OR</u> F.2 Initiate action to restore valve(s) to OPERABLE status. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| <p>SR 3.6.1.3.1 -----NOTE----- Not required to be met when the 18 inch primary containment vent and purge valves are open for inerting, de-inerting, pressure control, ALARA or air quality considerations for personnel entry, or Surveillances that require the valves to be open, provided the drywell vent and purge valves and their associated suppression chamber vent and purge valves are not open simultaneously. ----- Verify each 18 inch primary containment vent and purge valve, except the torus purge valve, is closed.</p> | 31 days |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|--|
| <p>SR 3.6.1.3.2 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment isolation manual valve and blind flange that is located outside primary containment and not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p> | <p>31 days</p> |
| <p>SR 3.6.1.3.3 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment manual isolation valve and blind flange that is located inside primary containment and not locked sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p> | <p>Prior to entering MODE 2 or 3 from MODE 4 if primary containment was de-inerted while in MODE 4, if not performed within the previous 92 days</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|--|
| SR 3.6.1.3.4 | Verify continuity of the traversing incore probe (TIP) shear isolation valve explosive charge. | 31 days |
| SR 3.6.1.3.5 | Verify the isolation time of each power operated, automatic PCIV, except for MSIVs, is within limits. | In accordance with the Inservice Testing Program |
| SR 3.6.1.3.6 | Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds. | In accordance with the Inservice Testing Program |
| SR 3.6.1.3.7 | Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal. | 24 months |
| SR 3.6.1.3.8 | Verify each reactor instrumentation line EFCV actuates to the isolation position on an actual or simulated instrument line break signal. | 24 months |
| SR 3.6.1.3.9 | Remove and test the explosive squib from each shear isolation valve of the TIP System. | 24 months on a STAGGERED TEST BASIS |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|---|
| SR 3.6.1.3.10 Verify the combined leakage rate for all MSIV leakage paths is ≤ 46 scfh when tested at ≥ 25 psig. | In accordance with the Primary Containment Leakage Rate Testing Program |

3.6 CONTAINMENT SYSTEMS

3.6.1.4 Drywell Pressure

LC0 3.6.1.4 Drywell pressure shall be ≤ 1.5 psig.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Drywell pressure not within limit. | A.1 Restore drywell pressure to within limit. | 1 hour |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.6.1.4.1 Verify drywell pressure is within limit. | 12 hours |

3.6 CONTAINMENT SYSTEMS

3.6.1.5 Drywell Air Temperature

LC0 3.6.1.5 Drywell average air temperature shall be $\leq 150^{\circ}\text{F}$.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. Drywell average air temperature not within limit. | A.1 Restore drywell average air temperature to within limit. | 8 hours |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.6.1.5.1 Verify drywell average air temperature is within limit. | 24 hours |

3.6 CONTAINMENT SYSTEMS

3.6.1.6 Low Set Relief Valves

LC0 3.6.1.6 The low set relief function of two relief valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|------------------------------|
| A. One low set relief valve inoperable. | A.1 Restore low set relief valve to OPERABLE status. | 14 days |
| B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Two low set relief valves inoperable. | B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4. | 12 hours 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|------------------|
| <p>SR 3.6.1.6.1 -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----</p> <p>Verify each low set relief valve opens when manually actuated.</p> | <p>24 months</p> |
| <p>SR 3.6.1.6.2 -----NOTE----- Valve actuation may be excluded. -----</p> <p>Verify each low set relief valve actuates on an actual or simulated automatic initiation signal.</p> | <p>24 months</p> |

3.6 CONTAINMENT SYSTEMS

3.6.1.7 Reactor Building-to-Suppression Chamber Vacuum Breakers

LC0 3.6.1.7 Each reactor building-to-suppression chamber vacuum breaker shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each line.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. One or more lines with one reactor building-to-suppression chamber vacuum breaker not closed. | A.1 Close the open vacuum breaker. | 7 days |
| B. One or more lines with two reactor building-to-suppression chamber vacuum breakers not closed. | B.1 Close one open vacuum breaker. | 1 hour |
| C. One line with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening. | C.1 Restore the vacuum breaker(s) to OPERABLE status. | 7 days |

(continued)

Reactor Building-to-Suppression Chamber Vacuum Breakers
3.6.1.7

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| D. Two lines with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening. | D.1 Restore all vacuum breakers in one line to OPERABLE status. | 1 hour |
| E. Required Action and Associated Completion Time not met. | E.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> E.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.6.1.7.1 -----NOTES----- 1. Not required to be met for vacuum breakers that are open during Surveillances. 2. Not required to be met for vacuum breakers open when performing their intended function. ----- Verify each vacuum breaker is closed. | 14 days |
| SR 3.6.1.7.2 Perform a functional test of each vacuum breaker. | 92 days |

(continued)

Reactor Building-to-Suppression Chamber Vacuum Breakers
3.6.1.7

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------|
| SR 3.6.1.7.3 | Verify the opening setpoint of each vacuum breaker is ≤ 0.5 psid. | 24 months |

3.6 CONTAINMENT SYSTEMS

3.6.1.8 Suppression Chamber-to-Drywell Vacuum Breakers

LC0 3.6.1.8 Nine suppression chamber-to-drywell vacuum breakers shall be OPERABLE for opening.

AND

Twelve suppression chamber-to-drywell vacuum breakers shall be closed.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One required suppression chamber-to-drywell vacuum breaker inoperable for opening. | A.1 Restore one vacuum breaker to OPERABLE status. | 72 hours |
| B. One suppression chamber-to-drywell vacuum breaker not closed. | B.1 Close the open vacuum breaker. | 4 hours |
| C. Required Action and associated Completion Time not met. | C.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> C.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|--|
| <p>SR 3.6.1.8.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Not required to be met for vacuum breakers that are open during Surveillances. 2. Not required to be met for vacuum breakers open when performing their intended function. <p>-----</p> <p>Verify each vacuum breaker is closed.</p> | <p>14 days</p> |
| <p>SR 3.6.1.8.2 Perform a functional test of each required vacuum breaker.</p> | <p>31 days</p> <p><u>AND</u></p> <p>Within 12 hours after any discharge of steam to the suppression chamber from the relief valves</p> |
| <p>SR 3.6.1.8.3 Verify the opening setpoint of each required vacuum breaker is ≤ 0.5 psid.</p> | <p>24 months</p> |

3.6 CONTAINMENT SYSTEMS

3.6.2.1 Suppression Pool Average Temperature

LC0 3.6.2.1 Suppression pool average temperature shall be:

- a. $\leq 95^{\circ}\text{F}$ with THERMAL POWER $> 1\%$ RTP and no testing that adds heat to the suppression pool is being performed;
- b. $\leq 105^{\circ}\text{F}$ with THERMAL POWER $> 1\%$ RTP and testing that adds heat to the suppression pool is being performed;
and
- c. $\leq 110^{\circ}\text{F}$ with THERMAL POWER $\leq 1\%$ RTP.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|--------------------------------------|
| <p>A. Suppression pool average temperature $> 95^{\circ}\text{F}$ but $\leq 110^{\circ}\text{F}$.</p> <p><u>AND</u></p> <p>THERMAL POWER $> 1\%$ RTP.</p> <p><u>AND</u></p> <p>Not performing testing that adds heat to the suppression pool.</p> | <p>A.1 Verify suppression pool average temperature $\leq 110^{\circ}\text{F}$.</p> <p><u>AND</u></p> <p>A.2 Restore suppression pool average temperature to $\leq 95^{\circ}\text{F}$.</p> | <p>Once per hour</p> <p>24 hours</p> |
| <p>B. Required Action and associated Completion Time of Condition A not met.</p> | <p>B.1 Reduce THERMAL POWER to $\leq 1\%$ RTP.</p> | <p>12 hours</p> |

(continued)

Suppression Pool Average Temperature
3.6.2.1

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|---|
| <p>C. Suppression pool average temperature > 105°F.</p> <p><u>AND</u></p> <p>THERMAL POWER > 1% RTP.</p> <p><u>AND</u></p> <p>Performing testing that adds heat to the suppression pool.</p> | <p>C.1 Suspend all testing that adds heat to the suppression pool.</p> | <p>Immediately</p> |
| <p>D. Suppression pool average temperature > 110°F but ≤ 120°F.</p> | <p>D.1 Place the reactor mode switch in the shutdown position.</p> <p><u>AND</u></p> <p>D.2 Verify suppression pool average temperature ≤ 120°F.</p> <p><u>AND</u></p> <p>D.3 Be in MODE 4.</p> | <p>Immediately</p> <p>Once per 30 minutes</p> <p>36 hours</p> |
| <p>E. Suppression pool average temperature > 120°F.</p> | <p>E.1 Depressurize the reactor vessel to < 150 psig.</p> <p><u>AND</u></p> <p>E.2 Be in MODE 4.</p> | <p>12 hours</p> <p>36 hours</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|---|
| SR 3.6.2.1.1 Verify suppression pool average temperature is within the applicable limits. | 24 hours <u>AND</u> 5 minutes when performing testing that adds heat to the suppression, pool |

3.6 CONTAINMENT SYSTEMS

3.6.2.2 Suppression Pool Water Level

LC0 3.6.2.2 Suppression pool water level shall be \geq 14 ft 6.5 inches and \leq 14 ft 10.5 inches.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Suppression pool water level not within limits. | A.1 Restore suppression pool water level to within limits. | 2 hours |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.6.2.2.1 Verify suppression pool water level is within limits. | 24 hours |

3.6 CONTAINMENT SYSTEMS

3.6.2.3 Suppression Pool Cooling

LC0 3.6.2.3 Two suppression pool cooling subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. One suppression pool cooling subsystem inoperable. | A.1 Restore suppression pool cooling subsystem to OPERABLE status. | 7 days |
| B. Two suppression pool cooling subsystems inoperable. | B.1 Restore one suppression pool cooling subsystem to OPERABLE status. | 8 hours |
| C. Required Action and associated Completion Time not met. | C.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> C.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|--|
| SR 3.6.2.3.1 Verify each suppression pool cooling subsystem manual and power operated valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position. | 31 days |
| SR 3.6.2.3.2 Verify each required LPCI pump develops a flow rate \geq 5000 gpm through the associated heat exchanger while operating in the suppression pool cooling mode. | In accordance with the Inservice Testing Program |

3.6 CONTAINMENT SYSTEMS

3.6.2.4 Suppression Pool Spray

LC0 3.6.2.4 Two suppression pool spray subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. One suppression pool spray subsystem inoperable. | A.1 Restore suppression pool spray subsystem to OPERABLE status. | 7 days |
| B. Two suppression pool spray subsystems inoperable. | B.1 Restore one suppression pool spray subsystem to OPERABLE status. | 8 hours |
| C. Required Action and associated Completion Time not met. | C.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> C.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.6.2.4.1 Verify each suppression pool spray subsystem manual and power operated valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position. | 31 days |
| SR 3.6.2.4.2 Verify each suppression pool spray nozzle is unobstructed. | 10 years |

3.6 CONTAINMENT SYSTEMS

3.6.2.5 Drywell-to-Suppression Chamber Differential Pressure

LC0 3.6.2.5 The drywell pressure shall be maintained ≥ 1.0 psid above the pressure of the suppression chamber.

-----NOTE-----
Not required to be met for up to 4 hours during performance of required Surveillances.

APPLICABILITY: MODE 1 during the time period:

- a. From 24 hours after THERMAL POWER is $> 15\%$ RTP following startup, to
- b. 24 hours prior to reducing THERMAL POWER to $< 15\%$ RTP prior to the next scheduled reactor shutdown.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. Drywell-to-suppression chamber differential pressure not within limit. | A.1 Restore differential pressure to within limit. | 24 hours |
| B. Required Action and associated Completion Time not met. | B.1 Reduce THERMAL POWER to $\leq 15\%$ RTP. | 8 hours |

Drywell-to-Suppression Chamber Differential Pressure
3.6.2.5

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.6.2.5.1 Verify drywell-to-suppression chamber differential pressure is within limit. | 12 hours |

3.6 CONTAINMENT SYSTEMS

3.6.3.1 Primary Containment Oxygen Concentration

LCO 3.6.3.1 The primary containment oxygen concentration shall be < 4.0 volume percent.

APPLICABILITY: MODE 1 during the time period:

- a. From 24 hours after THERMAL POWER is > 15% RTP following startup, to
- b. 24 hours prior to reducing THERMAL POWER to < 15% RTP prior to the next scheduled reactor shutdown.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. Primary containment oxygen concentration not within limit. | A.1 Restore oxygen concentration to within limit. | 24 hours |
| B. Required Action and associated Completion Time not met. | B.1 Reduce THERMAL POWER to \leq 15% RTP. | 8 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.6.3.1.1 Verify primary containment oxygen concentration is within limits. | 7 days |

3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LC0 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the
secondary containment,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|--|
| A. Secondary containment inoperable in MODE 1, 2, or 3. | A.1 Restore secondary containment to OPERABLE status. | 4 hours |
| B. Required Action and associated Completion Time of Condition A not met. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |
| C. Secondary containment inoperable during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | C.1 -----NOTE----- LC0 3.0.3 is not applicable. ----- Suspend movement of irradiated fuel assemblies in the secondary containment. <u>AND</u> | Immediately (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| C. (continued) | C.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | C.3 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|--|
| SR 3.6.4.1.1 | Verify secondary containment vacuum is ≥ 0.25 inch of vacuum water gauge. | 24 hours |
| SR 3.6.4.1.2 | Verify one secondary containment access door in each access opening is closed. | 31 days |
| SR 3.6.4.1.3 | Verify the secondary containment can be maintained ≥ 0.25 inch of vacuum water gauge for 1 hour using one SGT subsystem at a flow rate ≤ 4000 cfm. | 24 months on a STAGGERED TEST BASIS for each SGT subsystem |
| SR 3.6.4.1.4 | Verify all secondary containment equipment hatches are closed and sealed. | 24 months |

3.6 CONTAINMENT SYSTEMS

3.6.4.2 Secondary Containment Isolation Valves (SCIVs)

LC0 3.6.4.2 Each SCIV shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the
secondary containment,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

- NOTES-----
1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by SCIVs.
-

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more penetration flow paths with one SCIV inoperable. | A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange. | 8 hours |
| | <u>AND</u> | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|------------------|
| A. (continued) | <p>A.2</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Isolation devices in high radiation areas may be verified by use of administrative means. 2. Isolation devices that are locked, sealed, or otherwise secured may be verified by use of administrative means. <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p> | Once per 31 days |
| <p>B. -----NOTE-----</p> <p>Only applicable to penetration flow paths with two isolation valves.</p> <p>-----</p> <p>One or more penetration flow paths with two SCIVs inoperable.</p> | <p>B.1</p> <p>Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p> | 4 hours |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3. | C.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> C.2 Be in MODE 4. | 36 hours |
| D. Required Action and associated Completion Time of Condition A or B not met during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | D.1 -----NOTE----- LCO 3.0.3 is not applicable. ----- Suspend movement of irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | |
| | D.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> D.3 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|------------------|
| <p>SR 3.6.4.2.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for SCIVs that are open under administrative controls. <p>-----</p> <p>Verify each secondary containment isolation manual valve and blind flange that is not locked, sealed or otherwise secured and is required to be closed during accident conditions is closed.</p> | <p>31 days</p> |
| <p>SR 3.6.4.2.2 Verify the isolation time of each power operated, automatic SCIV is within limits.</p> | <p>92 days</p> |
| <p>SR 3.6.4.2.3 Verify each automatic SCIV actuates to the isolation position on an actual or simulated actuation signal.</p> | <p>24 months</p> |

3.6 CONTAINMENT SYSTEMS

3.6.4.3 Standby Gas Treatment (SGT) System

LC0 3.6.4.3 Two SGT subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the
secondary containment,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|--------------------------------|
| A. One SGT subsystem inoperable. | A.1 Restore SGT subsystem to OPERABLE status. | 7 days |
| B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3. | B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4. | 12 hours 36 hours |
| C. Required Action and associated Completion Time of Condition A not met during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | -----NOTE----- LC0 3.0.3 is not applicable. ----- C.1 Place OPERABLE SGT subsystem in operation. <u>OR</u> | Immediately (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| C. (continued) | C.2.1 Suspend movement of irradiated fuel assemblies in secondary containment. | Immediately |
| | <u>AND</u> | |
| | C.2.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | C.2.3 Initiate action to suspend OPDRVs. | Immediately |
| D. Two SGT subsystems inoperable in MODE 1, 2, or 3. | D.1 Restore one SGT subsystem to OPERABLE status. | 1 hour |
| E. Required Action and associated Completion Time of Condition D not met. | E.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> E.2 Be in MODE 4. | 36 hours |
| F. Two SGT subsystems inoperable during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | F.1 -----NOTE----- LCO 3.0.3 is not applicable. ----- Suspend movement of irradiated fuel assemblies in secondary containment. | Immediately |
| | <u>AND</u> | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| F. (continued) | F.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | F.3 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|---|-----------------------------|
| SR 3.6.4.3.1 | Operate each SGT subsystem for ≥ 10 continuous hours with heaters operating. | 31 days |
| SR 3.6.4.3.2 | Perform required SGT filter testing in accordance with the Ventilation Filter Testing Program (VFTP). | In accordance with the VFTP |
| SR 3.6.4.3.3 | Verify each SGT subsystem actuates on an actual or simulated initiation signal. | 24 months |

3.7 PLANT SYSTEMS

3.7.1 Containment Cooling Service Water (CCSW) System

LC0 3.7.1 Two CCSW subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. One CCSW pump inoperable. | A.1 Restore CCSW pump to OPERABLE status. | 30 days |
| B. One CCSW pump in each subsystem inoperable. | B.1 Restore one CCSW pump to OPERABLE status. | 7 days |
| C. One CCSW subsystem inoperable for reasons other than Condition A. | C.1 Restore CCSW subsystem to OPERABLE status. | 7 days |
| D. Both CCSW subsystems inoperable for reasons other than Condition B. | D.1 Restore one CCSW subsystem to OPERABLE status. | 8 hours |
| E. Required Action and associated Completion Time not met. | E.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> E.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.7.1.1 Verify each CCSW manual and power operated valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position. | 31 days |

3.7 PLANT SYSTEMS

3.7.2 Diesel Generator Cooling Water (DGCW) System

LC0 3.7.2 The following DGCW subsystems shall be OPERABLE:

- a. Two DGCW subsystems; and
- b. The opposite unit DGCW subsystem capable of supporting its associated diesel generator (DG).

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each DGCW subsystem.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---------------------------------------|-----------------|
| A. One or more DGCW subsystems inoperable. | A.1 Declare associated DG inoperable. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.7.2.1 Verify each DGCW subsystem manual valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position. | 31 days |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.7.2.2 Verify each DGCW pump starts automatically on an actual or simulated initiation signal. | 24 months |

3.7 PLANT SYSTEMS

3.7.3 Ultimate Heat Sink (UHS)

LC0 3.7.3 The UHS shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--------------------|-------------------|-----------------|
| A. UHS inoperable. | A.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> | |
| | A.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------|
| SR 3.7.3.1 | Verify the water level in the CCSW and DGCW pump suction bays is \geq 501.5 ft mean sea level. | 24 hours |
| SR 3.7.3.2 | Verify the average water temperature of UHS is \leq 95°F. | 24 hours |

3.7 PLANT SYSTEMS

3.7.4 Control Room Emergency Ventilation (CREV) System

LC0 3.7.4 The CREV System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of irradiated fuel assemblies in the
secondary containment,
During CORE ALTERATIONS,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---------------------------------------|
| A. CREV System inoperable in MODE 1, 2, or 3. | A.1 Restore CREV System to OPERABLE status. | 7 days |
| B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |
| C. CREV System inoperable during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | <p>-----NOTE----- LC0 3.0.3 is not applicable. -----</p> <p>C.1 Suspend movement of irradiated fuel assemblies in the secondary containment.</p> <p><u>AND</u></p> | <p>Immediately</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| C. (continued) | C.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> C.3 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------------------------|
| SR 3.7.4.1 Operate the CREV System for ≥ 10 continuous hours with the heaters operating. | 31 days |
| SR 3.7.4.2 Perform required CREV filter testing in accordance with the Ventilation Filter Testing Program (VFTP). | In accordance with the VFTP |
| SR 3.7.4.3 Verify the CREV System actuates on a manual initiation signal. | 24 months |
| SR 3.7.4.4 Verify the CREV System can maintain a positive pressure of ≥ 0.125 inches water gauge relative to the adjacent areas during the isolation/pressurization mode of operation at a flow rate of ≤ 2000 scfm. | 24 months |

3.7 PLANT SYSTEMS

3.7.5 Control Room Emergency Ventilation Air Conditioning (AC) System

LC0 3.7.5 The Control Room Emergency Ventilation AC System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
 During movement of irradiated fuel assemblies in the
 secondary containment,
 During CORE ALTERATIONS,
 During operations with a potential for draining the reactor
 vessel (OPDRVs).

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Control Room Emergency Ventilation AC System inoperable in MODE 1, 2, or 3. | A.1 Restore Control Room Emergency Ventilation AC System to OPERABLE status. | 30 days |
| B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3. | B.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 36 hours |

(continued)

Control Room Emergency Ventilation AC System
3.7.5

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| C. Control Room Emergency Ventilation AC System inoperable during movement of irradiated fuel assemblies in the secondary containment, during CORE ALTERATIONS, or during OPDRVs. | -----NOTE----- LC0 3.0.3 is not applicable. ----- | |
| | C.1 Suspend movement of irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | |
| | C.2 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | C.3 Initiate action to suspend OPDRVs. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.7.5.1 Verify the Control Room Emergency Ventilation AC System has the capability to remove the assumed heat load. | 24 months |

3.7 PLANT SYSTEMS

3.7.6 Main Condenser Offgas

LC0 3.7.6 The gross gamma activity rate of the noble gases measured prior to the offgas holdup line shall be $\leq 252,700 \mu\text{Ci/second}$ after decay of 30 minutes.

APPLICABILITY: MODE 1,
MODES 2 and 3 with any main steam line not isolated and steam jet air ejector (SJAE) in operation.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. Gross gamma activity rate of the noble gases not within limit. | A.1 Restore gross gamma activity rate of the noble gases to within limit. | 72 hours |
| B. Required Action and associated Completion Time not met. | B.1 Isolate all main steam lines. | 12 hours |
| | <u>OR</u> | |
| | B.2 Isolate SJAE. | 12 hours |
| | <u>OR</u> | |
| | B.3.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> | |
| | B.3.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| <p>SR 3.7.6.1 -----NOTE----- Not required to be performed until 31 days after any main steam line not isolated and SJAE in operation. -----</p> <p>Verify the gross gamma activity rate of the noble gases is $\leq 252,700 \mu\text{Ci/second}$ after decay of 30 minutes.</p> | <p>31 days</p> <p><u>AND</u></p> <p>Once within 4 hours after a $\geq 50\%$ increase in the nominal steady state fission gas release after factoring out increases due to changes in THERMAL POWER level</p> |

3.7 PLANT SYSTEMS

3.7.7 The Main Turbine Bypass System

LCO 3.7.7 The Main Turbine Bypass System shall be OPERABLE.

OR

LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," limits for an inoperable Main Turbine Bypass System, as specified in the COLR, are made applicable.

APPLICABILITY: THERMAL POWER \geq 25% RTP.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. Requirements of the LCO not met. | A.1 Satisfy the requirements of the LCO. | 2 hours |
| B. Required Action and associated Completion Time not met. | B.1 Reduce THERMAL POWER to < 25% RTP. | 4 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.7.7.1 Verify one complete cycle of each main turbine bypass valve. | 92 days |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.7.7.2 Perform a system functional test. | 24 months |
| SR 3.7.7.3 Verify the TURBINE BYPASS SYSTEM RESPONSE TIME is within limits. | 24 months |

Spent Fuel Storage Pool Water Level
3.7.8

3.7 PLANT SYSTEMS

3.7.8 Spent Fuel Storage Pool Water Level

LCO 3.7.8 The spent fuel storage pool water level shall be ≥ 19 ft over the top of irradiated fuel assemblies seated in the spent fuel storage pool racks.

APPLICABILITY: During movement of irradiated fuel assemblies in the spent fuel storage pool,
 During movement of new fuel assemblies in the spent fuel storage pool with irradiated fuel assemblies seated in the spent fuel storage pool.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. Spent fuel storage pool water level not within limit. | <p>A.1 -----NOTE----- LCO 3.0.3 is not applicable. -----</p> <p>Suspend movement of fuel assemblies in the spent fuel storage pool.</p> | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.7.8.1 Verify the spent fuel storage pool water level is ≥ 19 ft over the top of irradiated fuel assemblies seated in the spent fuel storage pool racks. | 7 days |

3.8 ELECTRICAL POWER SYSTEMS

3.8.1 AC Sources – Operating

LCO 3.8.1 The following AC electrical power sources shall be OPERABLE:

- a. Two qualified circuits between the offsite transmission network and the onsite Class 1E AC Electrical Power Distribution System;
- b. Two diesel generators (DGs);
- c. One qualified circuit between the offsite transmission network and the opposite unit's Division 2 onsite Class 1E AC electrical power distribution subsystem capable of supporting the equipment required to be OPERABLE by LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," LCO 3.7.4, "Control Room Emergency Ventilation (CREV) System" (Unit 3 only), and LCO 3.7.5, "Control Room Emergency Ventilation Air Conditioning (AC) System" (Unit 3 only); and
- d. The opposite unit's DG capable of supporting the equipment required to be OPERABLE by LCO 3.6.4.3, LCO 3.7.4 (Unit 3 only), and LCO 3.7.5 (Unit 3 only).

APPLICABILITY: MODES 1, 2, and 3.

-----NOTE-----

The opposite unit's AC electrical power sources in LCO 3.8.1.c and d are not required to be OPERABLE when the associated required equipment (SGT subsystem, CREV System (Unit 3 only), and Control Room Emergency Ventilation AC System (Unit 3 only)) is inoperable.

ACTIONS

-----NOTE-----
LCO 3.0.4 is not applicable for the opposite unit's AC electrical power sources.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--|
| A. One required offsite circuit inoperable. | A.1 Perform SR 3.8.1.1 for OPERABLE required offsite circuit. | 1 hour <u>AND</u> Once per 8 hours thereafter |
| | <u>AND</u> A.2 Declare required feature(s) with no offsite power available inoperable when the redundant required feature(s) are inoperable. | 24 hours from discovery of no offsite power to one division concurrent with inoperability of redundant required feature(s) |
| | <u>AND</u> A.3 Restore required offsite circuit to OPERABLE status. | 7 days <u>AND</u> 14 days from discovery of failure to meet LCO 3.8.1.a or b |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--------------------------------|--|--|
| B. One required DG inoperable. | B.1 Perform SR 3.8.1.1 for OPERABLE required offsite circuit(s). | 1 hour <u>AND</u> Once per 8 hours thereafter |
| | <u>AND</u> | |
| | B.2 Declare required feature(s), supported by the inoperable DG, inoperable when the redundant required feature(s) are inoperable. | 4 hours from discovery of Condition B concurrent with inoperability of redundant required feature(s) |
| | <u>AND</u> | |
| | B.3.1 Determine OPERABLE DG(s) are not inoperable due to common cause failure. | 24 hours |
| | <u>OR</u> | |
| | B.3.2 Perform SR 3.8.1.2 for OPERABLE DG(s). | 24 hours |
| | <u>AND</u> | |
| | B.4 Restore required DG to OPERABLE status. | 7 days <u>AND</u> 14 days from discovery of failure to meet LCO 3.8.1.a or b |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---|
| C. Two required offsite circuits inoperable. | C.1 Declare required feature(s) inoperable when the redundant required feature(s) are inoperable. | 12 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s) |
| | <u>AND</u> C.2 Restore one required offsite circuit to OPERABLE status. | 24 hours |
| D. One required offsite circuit inoperable. <u>AND</u> One required DG inoperable. | -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems – Operating," when Condition D is entered with no AC power source to any division. ----- | |
| | D.1 Restore required offsite circuit to OPERABLE status. | 12 hours |
| | <u>OR</u> D.2 Restore required DG to OPERABLE status. | 12 hours |
| E. Two required DGs inoperable. | E.1 Restore one required DG to OPERABLE status. | 2 hours |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---------------------------------|-----------------|
| F. Required Action and associated Completion Time of Condition A, B, C, D, or E not met. | F.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> F.2 Be in MODE 4. | 36 hours |
| G. Three or more required AC sources inoperable. | G.1 Enter LCO 3.0.3. | Immediately |

SURVEILLANCE REQUIREMENTS

- NOTES-----
1. SR 3.8.1.1 through SR 3.8.1.20 are applicable only to the given unit's AC electrical power sources.
 2. SR 3.8.1.21 is applicable to the opposite unit's AC electrical power sources.
-

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.8.1.1 Verify correct breaker alignment and indicated power availability for each required offsite circuit. | 7 days |
| <div> <div> SR 3.8.1.2 -----NOTES----- <ol style="list-style-type: none"> 1. All DG starts may be preceded by an engine prelube period and followed by a warmup period prior to loading. 2. A modified DG start involving idling and gradual acceleration to synchronous speed may be used for this SR as recommended by the manufacturer. When modified start procedures are not used, the time, voltage, and frequency tolerances of SR 3.8.1.8 must be met. 3. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. </div> <div> ----- Verify each DG starts from standby conditions and achieves steady state voltage ≥ 3952 V and ≤ 4368 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. </div> </div> | 31 days |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| <p>SR 3.8.1.3 -----NOTES-----</p> <ol style="list-style-type: none"> 1. DG loadings may include gradual loading as recommended by the manufacturer. 2. Momentary transients outside the load range do not invalidate this test. 3. This Surveillance shall be conducted on only one DG at a time. 4. This SR shall be preceded by and immediately follow, without shutdown, a successful performance of SR 3.8.1.2 or SR 3.8.1.8. 5. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. <p>-----</p> <p>Verify each DG is synchronized and loaded and operates for ≥ 60 minutes at a load ≥ 2340 kW and ≤ 2600 kW.</p> | 31 days |
| <p>SR 3.8.1.4 Verify each day tank contains ≥ 205 gal of fuel oil and each bulk fuel storage tank contains $\geq 10,000$ gal of fuel oil.</p> | 31 days |
| <p>SR 3.8.1.5 Remove accumulated water from each day tank.</p> | 31 days |
| <p>SR 3.8.1.6 Verify each fuel oil transfer pump operates to automatically transfer fuel oil from the storage tank to the day tank.</p> | 31 days |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|---|-----------|
| SR 3.8.1.7 | Check for and remove accumulated water from each bulk storage tank. | 92 days |
| SR 3.8.1.8 | <p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. All DG starts may be preceded by an engine prelube period. 2. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. <p>-----</p> <p>Verify each DG starts from standby condition and achieves:</p> <ol style="list-style-type: none"> a. In ≤ 13 seconds, voltage ≥ 3952 V and frequency ≥ 58.8 Hz; and b. Steady state voltage ≥ 3952 V and ≤ 4368 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. | 184 days |
| SR 3.8.1.9 | Verify manual transfer of unit power supply from the normal offsite circuit to the alternate offsite circuit. | 24 months |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|------------------|
| <p>SR 3.8.1.10 -----NOTE----- A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. ----- Verify each DG rejects a load greater than or equal to its associated single largest post-accident load, and:</p> <ol style="list-style-type: none"> Following load rejection, the frequency is ≤ 66.73 Hz; Within 3 seconds following load rejection, the voltage is ≥ 3952 V and ≤ 4368 V; and Within 4 seconds following load rejection, the frequency is ≥ 58.8 Hz and ≤ 61.2 Hz. | <p>24 months</p> |
| <p>SR 3.8.1.11 -----NOTES----- 1. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. 2. Momentary transients outside the voltage limit do not invalidate this test. ----- Verify each DG does not trip and voltage is maintained ≤ 5000 V during and following a load rejection of ≥ 2340 kW and ≤ 2600 kW.</p> | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|------------------|
| <p>SR 3.8.1.12 -----NOTE----- All DG starts may be preceded by an engine prelube period. -----</p> <p>Verify on an actual or simulated loss of offsite power signal:</p> <ul style="list-style-type: none"> a. De-energization of emergency buses; b. Load shedding from emergency buses; and c. DG auto-starts from standby condition and: <ul style="list-style-type: none"> 1. energizes permanently connected loads in ≤ 13 seconds, 2. maintains steady state voltage ≥ 3952 V and ≤ 4368 V, 3. maintains steady state frequency ≥ 58.8 Hz and ≤ 61.2 Hz, and 4. supplies permanently connected loads for ≥ 5 minutes. | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|------------------|
| <p>SR 3.8.1.13 -----NOTE----- All DG starts may be preceded by an engine prelube period. -----</p> <p>Verify on an actual or simulated Emergency Core Cooling System (ECCS) initiation signal each DG auto-starts from standby condition and:</p> <ul style="list-style-type: none"> a. In ≤ 13 seconds after auto-start, achieves voltage ≥ 3952 V and frequency ≥ 58.8 Hz; b. Achieves steady state voltage ≥ 3952 V and ≤ 4368 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz; and c. Operates for ≥ 5 minutes. | <p>24 months</p> |
| <p>SR 3.8.1.14 Verify each DG's automatic trips are bypassed on actual or simulated loss of voltage signal on the emergency bus concurrent with an actual or simulated ECCS initiation signal except:</p> <ul style="list-style-type: none"> a. Engine overspeed; and b. Generator differential current. | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|------------------|
| <p>SR 3.8.1.15 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Momentary transients outside the load range and power factor limit do not invalidate this test. 2. If grid conditions do not permit, the power factor limit is not required to be met. Under this condition, the power factor shall be maintained as close to the limit as practicable. 3. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. <p>-----</p> <p>Verify each DG operating within the power factor limit operates for ≥ 24 hours:</p> <ol style="list-style-type: none"> a. For ≥ 2 hours loaded ≥ 2730 kW and ≤ 2860 kW; and b. For the remaining hours of the test loaded ≥ 2340 kW and ≤ 2600 kW. | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|------------------|
| <p>SR 3.8.1.16 -----NOTES-----</p> <ol style="list-style-type: none"> 1. This Surveillance shall be performed within 5 minutes of shutting down the DG after the DG has operated ≥ 2 hours loaded ≥ 2340 kW. Momentary transients below the load limit do not invalidate this test. 2. All DG starts may be preceded by an engine prelube period. 3. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units. <p>-----</p> <p>Verify each DG starts and achieves:</p> <ol style="list-style-type: none"> a. In ≤ 13 seconds, voltage ≥ 3952 and frequency ≥ 58.8 Hz; and b. Steady state voltage ≥ 3952 V and ≤ 4368 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz. | <p>24 months</p> |
| <p>SR 3.8.1.17 Verify each DG:</p> <ol style="list-style-type: none"> a. Synchronizes with offsite power source while loaded with emergency loads upon a simulated restoration of offsite power; b. Transfers loads to offsite power source; and c. Returns to ready-to-load operation. | <p>24 months</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.8.1.18 Verify interval between each sequenced load block is $\geq 90\%$ of the design interval for each load sequence time delay relay. | 24 months |
| SR 3.8.1.19 -----NOTE----- All DG starts may be preceded by an engine prelube period. ----- Verify, on an actual or simulated loss of offsite power signal in conjunction with an actual or simulated ECCS initiation signal: a. De-energization of emergency buses; b. Load shedding from emergency buses; and c. DG auto-starts from standby condition and: 1. energizes permanently connected loads in ≤ 13 seconds, 2. energizes auto-connected emergency loads including through time delay relays, where applicable, 3. maintains steady state voltage ≥ 3952 V and ≤ 4368 V, 4. maintains steady state frequency ≥ 58.8 Hz and ≤ 61.2 Hz, and 5. supplies permanently connected and auto-connected emergency loads for ≥ 5 minutes. | 24 months |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| <p>SR 3.8.1.20 -----NOTE----- All DG starts may be preceded by an engine prelube period. -----</p> <p>Verify, when started simultaneously from standby condition, each DG achieves, in ≤ 13 seconds, voltage ≥ 3952 V and frequency ≥ 58.8 Hz.</p> | <p>10 years</p> |
| <p>SR 3.8.1.21 -----NOTE----- When the opposite unit is in MODE 4 or 5, or moving irradiated fuel assemblies in secondary containment, the following opposite unit SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12, and SR 3.8.1.14 through SR 3.8.1.17. -----</p> <p>For required opposite unit AC electrical power sources, the SRs of the opposite unit's Specification 3.8.1, except SR 3.8.1.9, SR 3.8.1.13, SR 3.8.1.18, SR 3.8.1.19, and SR 3.8.1.20, are applicable.</p> | <p>In accordance with applicable SRs</p> |

3.8 ELECTRICAL POWER SYSTEMS

3.8.2 AC Sources - Shutdown

LC0 3.8.2 The following AC electrical power sources shall be OPERABLE:

- a. One qualified circuit between the offsite transmission network and the onsite Class 1E AC electrical power distribution subsystem(s) required by LC0 3.8.8, "Distribution Systems - Shutdown"; and
- b. One diesel generator (DG) capable of supplying one division of the onsite Class 1E AC electrical power distribution subsystem(s) required by LC0 3.8.8.

APPLICABILITY: MODES 4 and 5,
During movement of irradiated fuel assemblies in the
secondary containment.

ACTIONS

-----NOTE-----
 LCO 3.0.3 is not applicable.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. One required offsite circuit inoperable. | -----NOTE----- Enter applicable Condition and Required Actions of LCO 3.8.8, when any required division is de-energized as a result of Condition A. ----- | |
| | A.1 Declare affected required feature(s), with no offsite power available, inoperable. | Immediately |
| | <u>OR</u> | |
| | A.2.1 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| A. (continued) | A.2.2 Suspend movement of irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | |
| | A.2.3 Initiate action to suspend operations with a potential for draining the reactor vessel (OPDRVs). | Immediately |
| | <u>AND</u> | |
| | A.2.4 Initiate action to restore required offsite power circuit to OPERABLE status. | Immediately |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--------------------------------|--|-----------------|
| B. One required DG inoperable. | B.1 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | B.2 Suspend movement of irradiated fuel assemblies in secondary containment. | Immediately |
| | <u>AND</u> | |
| | B.3 Initiate action to suspend OPDRVs. | Immediately |
| | <u>AND</u> | |
| | B.4 Initiate action to restore required DG to OPERABLE status. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| <p>SR 3.8.2.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. The following SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12, and SR 3.8.1.14 through SR 3.8.1.19. 2. SR 3.8.1.13 and SR 3.8.1.19 are not required to be met when associated ECCS subsystem(s) are not required to be OPERABLE per LCO 3.5.2, "ECCS – Shutdown." <p>-----</p> <p>For AC sources required to be OPERABLE the SRs of Specification 3.8.1, except SR 3.8.1.9, SR 3.8.1.20, and SR 3.8.1.21 are applicable.</p> | <p>In accordance with applicable SRs</p> |

3.8 ELECTRICAL POWER SYSTEMS

3.8.3 Diesel Fuel Oil and Starting Air

LC0 3.8.3 The stored diesel fuel oil and starting air subsystem shall be within limits for each required diesel generator (DG).

APPLICABILITY: When associated DG is required to be OPERABLE.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each DG.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. One or more DGs with stored fuel oil total particulates not within limit. | A.1 Restore stored fuel oil total particulates to within limit. | 7 days |
| B. One or more DGs with new fuel oil properties not within limits. | B.1 Restore stored fuel oil properties to within limits. | 30 days |
| C. One or more DGs with required starting air receiver pressure < 220 psig and ≥ 175 psig. | C.1 Restore starting air receiver pressure to ≥ 220 psig. | 48 hours |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|--------------------|
| <p>D. Required Action and associated Completion Time of Condition A, B, or C not met.</p> <p><u>OR</u></p> <p>One or more DGs with stored diesel fuel oil or starting air subsystem not within limits for reasons other than Condition A, B, or C.</p> | <p>D.1 Declare associated DG inoperable.</p> | <p>Immediately</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|---|
| <p>SR 3.8.3.1 Verify fuel oil properties of new and stored fuel oil are tested in accordance with, and maintained within the limits of, the Diesel Fuel Oil Testing Program.</p> | <p>In accordance with the Diesel Fuel Oil Testing Program</p> |
| <p>SR 3.8.3.2 Verify each required DG air start receiver pressure is \geq 220 psig.</p> | <p>31 days</p> |

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

- LCO 3.8.4 The following DC electrical power subsystems shall be OPERABLE:
- a. Two 250 VDC electrical power subsystems;
 - b. Division 1 and Division 2 125 VDC electrical power subsystems; and
 - c. The opposite unit's Division 2 125 VDC electrical power subsystem capable of supporting equipment required to be OPERABLE by LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," LCO 3.7.4, "Control Room Emergency Ventilation (CREV) System" (Unit 3 only), LCO 3.7.5, "Control Room Emergency Ventilation Air Conditioning (AC) System" (Unit 3 only), and LCO 3.8.1, "AC Sources - Operating."

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|--|
| A. One 250 VDC battery inoperable as a result of maintenance or testing. | A.1 Restore 250 VDC battery to OPERABLE status. | Prior to exceeding 7 cumulative days per operating cycle of battery inoperability, on a per battery basis, as a result of maintenance or testing |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|--|
| B. One 250 VDC battery inoperable, due to the need to replace the battery, as determined by maintenance or testing. | B.1 Restore 250 VDC battery to OPERABLE status. | 7 days |
| C. One 250 VDC electrical power subsystem inoperable for reasons other than Conditions A or B. | C.1 Restore 250 VDC electrical power subsystem to OPERABLE status. | 2 hours |
| D. -----NOTE----- Only applicable if the opposite unit is in MODE 1, 2, or 3. ----- Division 1 or 2 125 VDC battery inoperable as a result of maintenance or testing. | D.1 Place associated OPERABLE alternate 125 VDC electrical power subsystem in service. <u>AND</u> D.2 Restore Division 1 or 2 125 VDC battery to OPERABLE status. | 2 hours Prior to exceeding 7 cumulative days per operating cycle on a per battery basis |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-------------------------------|
| <p>E. -----NOTE----- Only applicable if the opposite unit is in MODE 1, 2, or 3. -----</p> <p>Division 1 or 2 125 VDC battery inoperable, due to the need to replace the battery, as determined by maintenance or testing.</p> | <p>E.1 Place associated OPERABLE alternate 125 VDC electrical power subsystem in service.</p> <p><u>AND</u></p> <p>E.2 Restore Division 1 or 2 125 VDC battery to OPERABLE status.</p> | <p>2 hours</p> <p>7 days</p> |
| <p>F. Division 1 or 2 125 VDC electrical power subsystem inoperable for reasons other than Condition D or E.</p> | <p>F.1 Restore Division 1 or 2 125 VDC electrical power subsystem to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2 -----NOTE----- Only applicable if the opposite unit is not in MODE 1, 2, or 3. -----</p> <p>Place associated OPERABLE alternate 125 VDC electrical power subsystem in service.</p> | <p>2 hours</p> <p>2 hours</p> |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| G. Opposite unit Division 2 125 VDC electrical power subsystem inoperable. | G.1 Restore opposite unit Division 2 125 VDC electrical power subsystem to OPERABLE status. | 7 days |
| H. Required Action and associated Completion Time not met. | H.1 Be in MODE 3. | 12 hours |
| | <u>AND</u> H.2 Be in MODE 4. | 36 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| <p>SR 3.8.4.1 Verify battery terminal voltage on float charge is:</p> <ul style="list-style-type: none"> a. ≥ 260.4 VDC for each 250 VDC subsystem; b. ≥ 125.9 VDC for each 125 VDC subsystem; and c. -----NOTE----- Only required to be met when the Unit 2 alternate battery is required to be OPERABLE. ----- ≥ 130.2 VDC for Unit 2 alternate battery. | 7 days |
| <p>SR 3.8.4.2 Verify no visible corrosion at battery terminals and connectors.</p> <p><u>OR</u></p> <p>Verify battery connection resistance is $\leq 1.5E-4$ ohm for inter-cell connections and $\leq 1.5E-4$ ohm for terminal connections.</p> | 92 days |
| <p>SR 3.8.4.3 Verify each required 250 V battery charger supplies ≥ 200 amps at ≥ 260 VDC for ≥ 4 hours for the 250 VDC subsystems.</p> | 18 months |
| <p>SR 3.8.4.4 Verify battery cells, cell plates, and racks show no visual indication of physical damage or abnormal deterioration that could degrade battery performance.</p> | 24 months |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------|
| SR 3.8.4.5 | Remove visible corrosion and verify battery cell to cell and terminal connections are coated with anti-corrosion material. | 24 months |
| SR 3.8.4.6 | Verify battery connection resistance is $\leq 1.5E-4$ ohm for inter-cell connections and $\leq 1.5E-4$ ohm for terminal connections. | 24 months |
| SR 3.8.4.7 | Verify each required 125 V battery charger supplies ≥ 200 amps at ≥ 130 VDC for ≥ 4 hours for the 125 VDC subsystems. | 24 months |
| SR 3.8.4.8 | <p>-----NOTE-----</p> <p>The modified performance discharge test in SR 3.8.4.9 may be performed in lieu of the service test in SR 3.8.4.8 provided the modified performance discharge test completely envelopes the service test.</p> <p>-----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.</p> | 24 months |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|---|
| <p>SR 3.8.4.9 Verify battery capacity is \geq 80% of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.</p> | <p>60 months</p> <p><u>AND</u></p> <p>12 months when battery shows degradation or has reached 85% of expected life with capacity $<$ 100% of manufacturer's rating</p> <p><u>AND</u></p> <p>24 months when battery has reached 85% of the expected life with capacity \geq 100% of manufacturer's rating</p> |

3.8 ELECTRICAL POWER SYSTEMS

3.8.5 DC Sources – Shutdown

LC0 3.8.5 One 250 VDC and one 125 VDC electrical power subsystem shall be OPERABLE to support the 250 VDC and one 125 VDC Class 1E electrical power distribution subsystems required by LC0 3.8.8, "Distribution Systems – Shutdown."

APPLICABILITY: MODES 4 and 5,
During movement of irradiated fuel assemblies in the
secondary containment.

ACTIONS

-----NOTE-----
LC0 3.0.3 is not applicable.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. One or more required DC electrical power subsystems inoperable. | A.1 Declare affected required feature(s) inoperable. | Immediately |
| | <u>OR</u> | |
| | A.2.1 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | A.2.2 Suspend movement of irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| A. (continued) | A:2.3 Initiate action to suspend operations with a potential for draining the reactor vessel. | Immediately |
| | <p style="text-align: center;"><u>AND</u></p> A:2.4 Initiate action to restore required DC electrical power subsystems to OPERABLE status. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------------------------------|
| <p>SR 3.8.5.1 -----NOTE-----</p> <p>The following SRs are not required to be performed for the 250 VDC electrical power subsystem: SR 3.8.4.3, SR 3.8.4.8 and SR 3.8.4.9.</p> <p>-----</p> <p>For DC electrical power subsystems required to be OPERABLE the following SRs are applicable:</p> <p>SR 3.8.4.1, SR 3.8.4.2, SR 3.8.4.3, SR 3.8.4.4, SR 3.8.4.5, SR 3.8.4.6, SR 3.8.4.7, SR 3.8.4.8, and SR 3.8.4.9.</p> | In accordance with applicable SRs |

3.8 ELECTRICAL POWER SYSTEMS

3.8.6 Battery Cell Parameters

LC0 3.8.6 Battery cell parameters for the 125 V and 250 V station batteries shall be within limits.

APPLICABILITY: When associated DC electrical power subsystems are required to be OPERABLE.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each battery.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|----------------------------|
| A. One or more batteries with one or more battery cell parameters not within Table 3.8.6-1 Category A or B limits. | A.1 Verify pilot cell(s) electrolyte level and float voltage meet Table 3.8.6-1 Category C limits. | 1 hour |
| | <u>AND</u> | |
| | A.2 Verify battery cell parameters meet Table 3.8.6-1 Category C limits. | 24 hours |
| | <u>AND</u> | Once per 7 days thereafter |
| | <u>AND</u> | |
| | A.3 Restore battery cell parameters to Table 3.8.6-1 Category A and B limits. | 31 days |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--------------------|
| <p>B. Required Action and associated Completion Time of Condition A not met.</p> <p><u>OR</u></p> <p>One or more batteries with average electrolyte temperature of the representative cells not within limits.</p> <p><u>OR</u></p> <p>One or more batteries with one or more battery cell parameters not within Table 3.8.6-1 Category C limits.</p> | <p>B.1 Declare associated battery inoperable.</p> | <p>Immediately</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|---|
| SR 3.8.6.1 Verify battery cell parameters meet Table 3.8.6-1 Category A limits. | 7 days |
| SR 3.8.6.2 Verify battery cell parameters meet Table 3.8.6-1 Category B limits. | 92 days <u>AND</u> Once within 7 days after battery discharge < 105 V for 125 V batteries and < 210 V for 250 V batteries <u>AND</u> Once within 7 days after battery overcharge > 150 V for 125 V batteries and > 300 V for 250 V batteries |
| SR 3.8.6.3 Verify average electrolyte temperature of representative cells is > 65°F. | 92 days |

Table 3.8.6-1 (page 1 of 1)
Battery Cell Parameter Requirements

| PARAMETER | CATEGORY A: LIMITS FOR EACH DESIGNATED PILOT CELL | CATEGORY B: LIMITS FOR EACH CONNECTED CELL | CATEGORY C: LIMITS FOR EACH CONNECTED CELL |
|---------------------------------------|---|---|--|
| Electrolyte Level | > Minimum level indication mark, and $\leq \frac{1}{4}$ inch above maximum level indication mark ^(a) | > Minimum level indication mark, and $\leq \frac{1}{4}$ inch above maximum level indication mark ^(a) | Above top of plates, and not overflowing |
| Float Voltage | ≥ 2.13 V | ≥ 2.13 V | > 2.07 V |
| Specific Gravity ^{(b)(c)} | ≥ 1.200 | ≥ 1.195 <u>AND</u> Average of all connected cells > 1.205 | Not more than 0.020 below average of all connected cells <u>AND</u> Average of all connected cells ≥ 1.195 |

- (a) It is acceptable for the electrolyte level to temporarily increase above the specified maximum level during and, for a limited time, following equalizing charges provided it is not overflowing.
- (b) Corrected for electrolyte temperature and level.
- (c) A battery charging current of < 2 amps when on float charge is acceptable for meeting specific gravity limits following a battery recharge, for a maximum of 7 days. When charging current is used to satisfy specific gravity requirements, specific gravity of each connected cell shall be measured prior to expiration of the 7 day allowance.

3.8 ELECTRICAL POWER SYSTEMS

3.8.7 Distribution Systems—Operating

LCO 3.8.7 The following electrical power distribution subsystems shall be OPERABLE:

- a. Division 1 and Division 2 AC and DC electrical power distribution subsystems; and
- b. The portions of the opposite unit's Division 2 AC and DC electrical power distribution subsystem necessary to support equipment required to be OPERABLE by LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," LCO 3.7.4, "Control Room Emergency Ventilation (CREV) System" (Unit 3 only), LCO 3.7.5, "Control Room Emergency Ventilation Air Conditioning (AC) System" (Unit 3 only), and LCO 3.8.1, "AC Sources—Operating."

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---|
| A. One or more AC electrical power distribution subsystems inoperable. | A.1 Restore AC electrical power distribution subsystems to OPERABLE status. | 8 hours <u>AND</u> 16 hours from discovery of failure to meet LCO 3.8.7.a |

(continued)

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|---|
| B. One or more DC electrical power distribution subsystems inoperable. | B.1 Restore DC electrical power distribution subsystems to OPERABLE status. | 2 hours <u>AND</u> 16 hours from discovery of failure to meet LCO 3.8.7.a |
| C. One or more required opposite unit Division 2 AC or DC electrical power distribution subsystems inoperable. | <p>-----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.1 when Condition C results in the inoperability of a required offsite circuit. -----</p> <p>C.1 Restore required opposite unit Division 2 AC and DC electrical power distribution subsystems to OPERABLE status.</p> | 7 days |
| D. Required Action and associated Completion Time of Condition A, B, or C not met. | <p>D.1 Be in MODE 3. <u>AND</u></p> <p>D.2 Be in MODE 4.</p> | <p>12 hours</p> <p>36 hours</p> |
| E. Two or more electrical power distribution subsystems inoperable that, in combination, result in a loss of function. | E.1 Enter LCO 3.0.3. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|---|-----------|
| SR 3.8.7.1 | Verify correct breaker alignments and voltage to required AC and DC electrical power distribution subsystems. | 7 days |

3.8 ELECTRICAL POWER SYSTEMS

3.8.8 Distribution Systems – Shutdown

LCO 3.8.8 The necessary portions of the AC, DC, and the opposite unit's Division 2 electrical power distribution subsystems shall be OPERABLE to support equipment required to be OPERABLE.

APPLICABILITY: MODES 4 and 5,
During movement of irradiated fuel assemblies in the secondary containment.

ACTIONS

-----NOTE-----
LCO 3.0.3 is not applicable.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. One or more required AC or DC electrical power distribution subsystems inoperable. | A.1 Declare associated supported required feature(s) inoperable. | Immediately |
| | <u>OR</u> | |
| | A.2.1 Suspend CORE ALTERATIONS. | Immediately |
| | <u>AND</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|---|-----------------|
| A. (continued) | A.2.2 Suspend movement of irradiated fuel assemblies in the secondary containment. | Immediately |
| | <u>AND</u> | |
| | A.2.3 Initiate action to suspend operations with a potential for draining the reactor vessel. | Immediately |
| | <u>AND</u> | |
| | A.2.4 Initiate actions to restore required AC and DC electrical power distribution subsystems to OPERABLE status. | Immediately |
| | <u>AND</u> | |
| | A.2.5 Declare associated required shutdown cooling subsystem(s) inoperable and not in operation. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.8.8.1 Verify correct breaker alignments and voltage to required AC and DC electrical power distribution subsystems. | 7 days |

3.9 REFUELING OPERATIONS

3.9.1 Refueling Equipment Interlocks

LC0 3.9.1 The refueling equipment interlocks associated with the reactor mode switch refuel position shall be OPERABLE.

APPLICABILITY: During in-vessel fuel movement with equipment associated with the interlocks when the reactor mode switch is in the refuel position.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. One or more required refueling equipment interlocks inoperable. | A.1 Suspend in-vessel fuel movement with equipment associated with the inoperable interlock(s). | Immediately |
| | <u>OR</u> | |
| | A.2.1 Insert a control rod withdrawal block. | Immediately |
| | <u>AND</u> | |
| | A.2.2 Verify all control rods are fully inserted. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------|
| SR 3.9.1.1 | Perform CHANNEL FUNCTIONAL TEST on each of the following required refueling equipment interlock inputs: a. All-rods-in, b. Refuel platform position, c. Refuel platform fuel grapple, fuel loaded, d. Refuel platform fuel grapple fully retracted position, e. Refuel platform frame mounted hoist, fuel loaded, f. Refuel platform monorail mounted hoist, fuel loaded, and g. Service platform hoist, fuel loaded. | 7 days |

3.9 REFUELING OPERATIONS

3.9.2 Refuel Position One-Rod-Out Interlock

LC0 3.9.2 The refuel position one-rod-out interlock shall be OPERABLE.

APPLICABILITY: MODE 5 with the reactor mode switch in the refuel position and any control rod withdrawn.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Refuel position one-rod-out interlock inoperable. | A.1 Suspend control rod withdrawal. | Immediately |
| | <u>AND</u> A.2 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|---|-----------|
| SR 3.9.2.1 | Verify reactor mode switch locked in Refuel position. | 12 hours |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|---------------|
| <p>SR 3.9.2.2 -----NOTE----- Not required to be performed until 1 hour after any control rod is withdrawn. -----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p> | <p>7 days</p> |

3.9 REFUELING OPERATIONS

3.9.3 Control Rod Position

LC0 3.9.3 All control rods shall be fully inserted.

APPLICABILITY: When loading fuel assemblies into the core.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more control rods not fully inserted. | A.1 Suspend loading fuel assemblies into the core. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.9.3.1 Verify all control rods are fully inserted. | 12 hours |

3.9 REFUELING OPERATIONS

3.9.4 Control Rod Position Indication

LCO 3.9.4 The control rod "full-in" position indication channel for each control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more control rod position indication channels inoperable. | A.1.1 Suspend in vessel fuel movement. | Immediately |
| | <u>AND</u> | |
| | A.1.2 Suspend control rod withdrawal. | Immediately |
| | <u>AND</u> | |
| | A.1.3 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies. | Immediately |
| | <u>OR</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| A. (continued) | A.2.1 Initiate action to fully insert the control rod associated with the inoperable position indicator. | Immediately |
| | <p><u>AND</u></p> <p>A.2.2 Initiate action to disarm the control rod drive associated with the fully inserted control rod.</p> | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| SR 3.9.4.1 Verify the channel has no "full-in" indication on each control rod that is not "full-in." | Each time the control rod is withdrawn from the "full-in" position |

3.9 REFUELING OPERATIONS

3.9.5 Control Rod OPERABILITY – Refueling

LC0 3.9.5 Each withdrawn control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more withdrawn control rods inoperable. | A.1 Initiate action to fully insert inoperable withdrawn control rods. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.9.5.1 -----NOTE----- Not required to be performed until 7 days after the control rod is withdrawn. ----- Insert each withdrawn control rod at least one notch. | 7 days |
| SR 3.9.5.2 Verify each withdrawn control rod scram accumulator pressure is \geq 940 psig. | 7 days |

3.9 . REFUELING OPERATIONS

3.9.6 Reactor Pressure Vessel (RPV) Water Level - Irradiated Fuel

LC0 3.9.6 RPV water level shall be \geq 23 ft above the top of the RPV flange.

APPLICABILITY: During movement of irradiated fuel assemblies within the RPV.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--------------------------------------|---|-----------------|
| A. RPV water level not within limit. | A.1 Suspend movement of irradiated fuel assemblies within the RPV. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.9.6.1 Verify RPV water level is \geq 23 ft above the top of the RPV flange. | 24 hours |

3.9 REFUELING OPERATIONS

3.9.7 Reactor Pressure Vessel (RPV) Water Level – New Fuel or Control Rods

LC0 3.9.7 RPV water level shall be \geq 23 ft above the top of irradiated fuel assemblies seated within the RPV.

APPLICABILITY: During movement of new fuel assemblies or handling of control rods within the RPV, when irradiated fuel assemblies are seated within the RPV.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--------------------------------------|--|-----------------|
| A. RPV water level not within limit. | A.1 Suspend movement of new fuel assemblies and handling of control rods within the RPV. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.9.7.1 Verify RPV water level is \geq 23 ft above the top of irradiated fuel assemblies seated within the RPV. | 24 hours |

3.9 REFUELING OPERATIONS

3.9.8 Shutdown Cooling (SDC) - High Water Level

LC0 3.9.8 One SDC subsystem shall be OPERABLE and in operation.

-----NOTE-----
The required SDC subsystem may be not in operation for up to 2 hours per 8 hour period.

APPLICABILITY: MODE 5 with irradiated fuel in the reactor pressure vessel (RPV) and the water level \geq 23 ft above the top of the RPV flange.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|--|
| A. Required SDC subsystem inoperable. | A.1 Verify an alternate method of decay heat removal is available. | 1 hour <u>AND</u> Once per 24 hours thereafter |
| B. Required Action and associated Completion Time of Condition A not met. | B.1 Suspend loading irradiated fuel assemblies into the RPV. <u>AND</u> | Immediately (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|-----------------------------------|--|---|
| B. (continued) | B.2 Initiate action to restore secondary containment to OPERABLE status. | Immediately |
| | <u>AND</u> | |
| | B.3 Initiate action to restore one standby gas treatment subsystem to OPERABLE status. | Immediately |
| | <u>AND</u> | |
| | B.4 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated. | Immediately |
| C. No SDC subsystem in operation. | C.1 Verify reactor coolant circulation by an alternate method. | 1 hour from discovery of no reactor coolant circulation |
| | <u>AND</u> | |
| | | Once per 12 hours thereafter |
| | <u>AND</u> | |
| | C.2 Monitor reactor coolant temperature. | Once per hour |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.9.8.1 Verify one SDC subsystem is operating. | 12 hours |

3.9 REFUELING OPERATIONS

3.9.9 Shutdown Cooling (SDC) - Low Water Level

LC0 3.9.9 Two SDC subsystems shall be OPERABLE, and one SDC subsystem shall be in operation.

-----NOTE-----
The required operating shutdown cooling subsystem may be not in operation for up to 2 hours per 8 hour period.

APPLICABILITY: MODE 5 with irradiated fuel in the reactor pressure vessel (RPV) and the water level < 23 ft above the top of the RPV flange.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|---|
| <p>A. -----NOTE----- Separate Condition entry is allowed for each inoperable SDC subsystem. -----</p> <p>One or two required SDC subsystems inoperable.</p> | <p>A.1 Verify an alternate method of decay heat removal is available for the inoperable required SDC subsystem.</p> | <p>1 hour</p> <p><u>AND</u></p> <p>Once per 24 hours thereafter</p> |
| <p>B. Required Action and associated Completion Time of Condition A not met.</p> | <p>B.1 Initiate action to restore secondary containment to OPERABLE status.</p> <p><u>AND</u></p> | <p>Immediately</p> <p>(continued)</p> |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|-----------------------------------|--|---|
| B. (continued) | B.2 Initiate action to restore one standby gas treatment subsystem to OPERABLE status. | Immediately |
| | <u>AND</u> B.3 Initiate action to restore isolation capability in each required secondary containment penetration flow path not isolated. | Immediately |
| C. No SDC subsystem in operation. | C.1 Verify reactor coolant circulation by an alternate method. | 1 hour from discovery of no reactor coolant circulation |
| | <u>AND</u> C.2 Monitor reactor coolant temperature. | <u>AND</u> Once per 12 hours thereafter Once per hour |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.9.9.1 Verify one SDC subsystem is operating. | 12 hours |

3.10 SPECIAL OPERATIONS

3.10.1 Reactor Mode Switch Interlock Testing

LC0 3.10.1 The reactor mode switch position specified in Table 1.1-1 for MODES 3, 4, and 5 may be changed to include the run, startup/hot standby, and refuel position, and operation considered not to be in MODE 1 or 2, to allow testing of instrumentation associated with the reactor mode switch interlock functions, provided:

- a. All control rods remain fully inserted in core cells containing one or more fuel assemblies; and
- b. No CORE ALTERATIONS are in progress.

APPLICABILITY: MODES 3 and 4 with the reactor mode switch in the run, startup/hot standby, or refuel position,
MODE 5 with the reactor mode switch in the run or startup/hot standby position.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more of the above requirements not met. | A.1 Suspend CORE ALTERATIONS except for control rod insertion. | Immediately |
| | <u>AND</u> | |
| | A.2 Fully insert all insertable control rods in core cells containing one or more fuel assemblies. | 1 hour |
| | <u>AND</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| A. (continued) | A.3.1 Place the reactor mode switch in the shutdown position. | 1 hour |
| | <p style="text-align: center;"><u>OR</u></p> <p>A.3.2 -----NOTE----- Only applicable in MODE 5. -----</p> <p>Place the reactor mode switch in the refuel position.</p> | 1 hour |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|-----------|
| SR 3.10.1.1 Verify all control rods are fully inserted in core cells containing one or more fuel assemblies. | 12 hours |
| SR 3.10.1.2 Verify no CORE ALTERATIONS are in progress. | 24 hours |

3.10 SPECIAL OPERATIONS

3.10.2 Single Control Rod Withdrawal—Hot Shutdown

LC0 3.10.2 The reactor mode switch position specified in Table 1.1-1 for MODE 3 may be changed to include the refuel position, and operation considered not to be in MODE 2, to allow withdrawal of a single control rod, provided the following requirements are met:

- a. LC0 3.9.2, "Refuel Position One-Rod-Out Interlock";
- b. LC0 3.9.4, "Control Rod Position Indication";
- c. All other control rods are fully inserted; and
- d. 1. LC0 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," MODE 5 requirements for Functions 1.a, 1.b, 7.a, 7.b, 11, and 12 of Table 3.3.1.1-1,

LC0 3.3.8.2, "Reactor Protection System (RPS) Electric Power Monitoring," MODE 5 requirements, and

LC0 3.9.5, "Control Rod OPERABILITY—Refueling,"

OR

- 2. All other control rods in a five by five array centered on the control rod being withdrawn are disarmed; at which time LC0 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 3 requirements, may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod.

APPLICABILITY: MODE 3 with the reactor mode switch in the refuel position.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. One or more of the above requirements not met. | <p>A.1 -----NOTES-----</p> <p>1. Required Actions to fully insert all insertable control rods include placing the reactor mode switch in the shutdown position.</p> <p>2. Only applicable if the requirement not met is a required LCO.</p> <p>-----</p> <p>Enter the applicable Condition of the affected LCO.</p> | Immediately |
| | <p><u>OR</u></p> <p>A.2.1 Initiate action to fully insert all insertable control rods.</p> | Immediately |
| | <p><u>AND</u></p> <p>A.2.2 Place the reactor mode switch in the shutdown position.</p> | 1 hour |
| | | |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|---------------------------------|
| SR 3.10.2.1 | Perform the applicable SRs for the required LCOs. | According to the applicable SRs |
| SR 3.10.2.2 | <p>-----NOTE----- Not required to be met if SR 3.10.2.1 is satisfied for LCO 3.10.2.d.1 requirements. -----</p> <p>Verify all control rods, other than the control rod being withdrawn, in a five by five array centered on the control rod being withdrawn, are disarmed.</p> | 24 hours |
| SR 3.10.2.3 | Verify all control rods, other than the control rod being withdrawn, are fully inserted. | 24 hours |

3.10 SPECIAL OPERATIONS

3.10.3 Single Control Rod Withdrawal—Cold Shutdown

- LCO 3.10.3 The reactor mode switch position specified in Table 1.1-1 for MODE 4 may be changed to include the refuel position, and operation considered not to be in MODE 2, to allow withdrawal of a single control rod, and subsequent removal of the associated control rod drive (CRD) if desired, provided the following requirements are met:
- a. All other control rods are fully inserted;
 - b.
 - 1. LCO 3.9.2, "Refuel Position One-Rod-Out Interlock," and
LCO 3.9.4, "Control Rod Position Indication,"
OR
 - 2. A control rod withdrawal block is inserted; and
 - c.
 - 1. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," MODE 5 requirements for Functions 1.a, 1.b, 7.a, 7.b, 11, and 12 of Table 3.3.1.1-1,
LCO 3.3.8.2, "Reactor Protection System (RPS) Electric Power Monitoring," MODE 5 requirements, and
LCO 3.9.5, "Control Rod OPERABILITY—Refueling,"
OR
 - 2. All other control rods in a five by five array centered on the control rod being withdrawn are disarmed; at which time LCO 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 4 requirements, may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod.

APPLICABILITY: MODE 4 with the reactor mode switch in the refuel position.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. One or more of the above requirements not met with the affected control rod insertable. | A.1 -----NOTES----- 1. Required Actions to fully insert all insertable control rods include placing the reactor mode switch in the shutdown position. 2. Only applicable if the requirement not met is a required LCO. ----- Enter the applicable Condition of the affected LCO. | Immediately |
| | <u>OR</u> | |
| | A.2.1 Initiate action to fully insert all insertable control rods. | Immediately |
| | <u>AND</u> | |
| | A.2.2 Place the reactor mode switch in the shutdown position. | 1 hour |

(continued)

| ACTIONS | CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---------|--|---|--|
| | B. One or more of the above requirements not met with the affected control rod not insertable. | <p>B.1 Suspend withdrawal of the control rod and removal of associated CRD.</p> <p><u>AND</u></p> <p>B.2.1 Initiate action to fully insert all control rods.</p> <p><u>OR</u></p> <p>B.2.2 Initiate action to satisfy the requirements of this LCO.</p> | <p>Immediately</p> <p>Immediately</p> <p>Immediately</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------------------------|
| SR 3.10.3.1 | Perform the applicable SRs for the required LCOs. | According to applicable SRs |
| SR 3.10.3.2 | <p>-----NOTE-----</p> <p>Not required to be met if SR 3.10.3.1 is satisfied for LCO 3.10.3.c.1 requirements.</p> <p>-----</p> <p>Verify all control rods, other than the control rod being withdrawn, in a five by five array centered on the control rod being withdrawn, are disarmed.</p> | 24 hours |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.10.3.3 Verify all control rods, other than the control rod being withdrawn, are fully inserted. | 24 hours |
| SR 3.10.3.4 -----NOTE----- Not required to be met if SR 3.10.3.1 is satisfied for LCO 3.10.3.b.1 requirements. ----- Verify a control rod withdrawal block is inserted. | 24 hours |

3.10 SPECIAL OPERATIONS

3.10.4 Single Control Rod Drive (CRD) Removal - Refueling

- LCO 3.10.4 The requirements of LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation"; LCO 3.3.8.2, "Reactor Protection System (RPS) Electric Power Monitoring"; LCO 3.9.1, "Refueling Equipment Interlocks"; LCO 3.9.2, "Refuel Position One Rod Out Interlock"; LCO 3.9.4, "Control Rod Position Indication"; and LCO 3.9.5, "Control Rod OPERABILITY - Refueling," may be suspended in MODE 5 to allow the removal of a single CRD associated with a control rod withdrawn from a core cell containing one or more fuel assemblies, provided the following requirements are met:
- All other control rods are fully inserted;
 - All other control rods in a five by five array centered on the withdrawn control rod are disarmed;
 - A control rod withdrawal block is inserted, and LCO 3.1.1, "SHUTDOWN MARGIN (SDM)," MODE 5 requirements may be changed to allow the single control rod withdrawn to be assumed to be the highest worth control rod; and
 - No other CORE ALTERATIONS are in progress.

APPLICABILITY: MODE 5 with LCO 3.9.5 not met.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. One or more of the above requirements not met. | A.1 Suspend removal of the CRD mechanism. | Immediately |
| | <u>AND</u> | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|---|-----------------|
| A. (continued) | A.2.1 Initiate action to fully insert all control rods. | Immediately |
| | <u>OR</u> A.2.2 Initiate action to satisfy the requirements of this LCO. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.10.4.1 Verify all control rods, other than the control rod withdrawn for the removal of the associated CRD, are fully inserted. | 24 hours |
| SR 3.10.4.2 Verify all control rods, other than the control rod withdrawn for the removal of the associated CRD, in a five by five array centered on the control rod withdrawn for the removal of the associated CRD, are disarmed. | 24 hours |
| SR 3.10.4.3 Verify a control rod withdrawal block is inserted. | 24 hours |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|----------------------------|
| SR 3.10.4.4 Perform SR 3.1.1.1. | According to SR 3.1.1.1 |
| SR 3.10.4.5 Verify no other CORE ALTERATIONS are in progress. | 24 hours |

3.10 SPECIAL OPERATIONS

3.10.5 Multiple Control Rod Withdrawal - Refueling

LCO 3.10.5 The requirements of LCO 3.9.3, "Control Rod Position"; LCO 3.9.4, "Control Rod Position Indication"; and LCO 3.9.5, "Control Rod OPERABILITY - Refueling," may be suspended, and the "full-in" position indicators may be bypassed for any number of control rods in MODE 5, to allow withdrawal of these control rods, removal of associated control rod drives (CRDs), or both, provided the following requirements are met:

- a. The four fuel assemblies are removed from the core cells associated with each control rod or CRD to be removed;
- b. All other control rods in core cells containing one or more fuel assemblies are fully inserted; and
- c. Fuel assemblies shall only be loaded in compliance with an approved spiral reload sequence.

APPLICABILITY: MODE 5 with LCO 3.9.3, LCO 3.9.4, or LCO 3.9.5 not met.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. One or more of the above requirements not met. | A.1 Suspend withdrawal of control rods and removal of associated CRDs. | Immediately |
| | <u>AND</u> | |
| | A.2 Suspend loading fuel assemblies. | Immediately |
| | <u>AND</u> | |
| | | (continued) |

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|-----------------|
| A. (continued) | A.3.1 Initiate action to fully insert all control rods in core cells containing one or more fuel assemblies. | Immediately |
| | <u>OR</u> A.3.2 Initiate action to satisfy the requirements of this LCO. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.10.5.1 Verify the four fuel assemblies are removed from core cells associated with each control rod or CRD removed. | 24 hours |
| SR 3.10.5.2 Verify all other control rods in core cells containing one or more fuel assemblies are fully inserted. | 24 hours |
| SR 3.10.5.3 -----NOTE----- Only required to be met during fuel loading. ----- Verify fuel assemblies being loaded are in compliance with an approved spiral reload sequence. | 24 hours |

3.10 SPECIAL OPERATIONS

3.10.6 Control Rod Testing—Operating

LCO 3.10.6 The requirements of LCO 3.1.6, "Rod Pattern Control," may be suspended to allow performance of SDM demonstrations, control rod scram time testing, and control rod friction testing, provided:

- a. The analyzed rod position sequence requirements of SR 3.3.2.1.8 are changed to require the control rod sequence to conform to the specified test sequence.

OR

- b. The RWM is bypassed; the requirements of LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 2 are suspended; and conformance to the approved control rod sequence for the specified test is verified by a second licensed operator or other qualified member of the technical staff.

APPLICABILITY: MODES 1 and 2 with LCO 3.1.6 not met.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|-------------------------------------|---|-----------------|
| A. Requirements of the LCO not met. | A.1 Suspend performance of the test and exception to LCO 3.1.6. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| <p>SR 3.10.6.1 -----NOTE----- Not required to be met if SR 3.10.6.2 satisfied. -----</p> <p>Verify movement of control rods is in compliance with the approved control rod sequence for the specified test by a second licensed operator or other qualified member of the technical staff.</p> | <p>During control rod movement</p> |
| <p>SR 3.10.6.2 -----NOTE----- Not required to be met if SR 3.10.6.1 satisfied. -----</p> <p>Verify control rod sequence input to the RWM is in conformance with the approved control rod sequence for the specified test.</p> | <p>Prior to control rod movement</p> |

3.10 SPECIAL OPERATIONS

3.10.7 SHUTDOWN MARGIN (SDM) Test – Refueling

LCO 3.10.7 The reactor mode switch position specified in Table 1.1-1 for MODE 5 may be changed to include the startup/hot standby position, and operation considered not to be in MODE 2, to allow SDM testing, provided the following requirements are met:

- a. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," MODE 2 requirements for Functions 2.a and 2.d of Table 3.3.1.1-1;
- b. 1. LCO 3.3.2.1, "Control Rod Block Instrumentation," MODE 2 requirements for Function 2 of Table 3.3.2.1-1, with the analyzed rod position sequence requirements of SR 3.3.2.1.8 changed to require the control rod sequence to conform to the SDM test sequence,

OR

- 2. Conformance to the approved control rod sequence for the SDM test is verified by a second licensed operator or other qualified member of the technical staff;
- c. Each withdrawn control rod shall be coupled to the associated CRD;
- d. All control rod withdrawals during out of sequence control rod moves shall be made in the single notch withdrawal mode;
- e. No other CORE ALTERATIONS are in progress; and
- f. CRD charging water header pressure \geq 940 psig.

APPLICABILITY: MODE 5 with the reactor mode switch in startup/hot standby position.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-------------------------------|
| <p>A. -----NOTE----- Separate Condition entry is allowed for each control rod. -----</p> <p>One or more control rods not coupled to its associated CRD.</p> | <p>-----NOTE----- Rod worth minimizer may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation," if required, to allow insertion of inoperable control rod and continued operation. -----</p> <p>A.1 Fully insert inoperable control rod.</p> <p><u>AND</u></p> <p>A.2 Disarm the associated CRD.</p> | <p>3 hours</p> <p>4 hours</p> |
| <p>B. One or more of the above requirements not met for reasons other than Condition A.</p> | <p>B.1 Place the reactor mode switch in the shutdown or refuel position.</p> | <p>Immediately</p> |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|--|
| <p>SR 3.10.7.1 Perform the MODE 2 applicable SRs for LCO 3.3.1.1, Functions 2.a and 2.d of Table 3.3.1.1-1.</p> | <p>According to the applicable SRs</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| <p>SR 3.10.7.2 -----NOTE----- Not required to be met if SR 3.10.7.3 satisfied. -----</p> <p>Perform the MODE 2 applicable SRs for LCO 3.3.2.1, Function 2 of Table 3.3.2.1-1.</p> | <p>According to the applicable SRs</p> |
| <p>SR 3.10.7.3 -----NOTE----- Not required to be met if SR 3.10.7.2 satisfied. -----</p> <p>Verify movement of control rods is in compliance with the approved control rod sequence for the SDM test by a second licensed operator or other qualified member of the technical staff.</p> | <p>During control rod movement</p> |
| <p>SR 3.10.7.4 Verify no other CORE ALTERATIONS are in progress.</p> | <p>12 hours</p> |

(continued)

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|--|--|
| SR 3.10.7.5 Verify each withdrawn control rod does not go to the withdrawn overtravel position. | Each time the control rod is withdrawn to "full out" position <u>AND</u> Prior to satisfying LCO 3.10.7.c requirement after work on control rod or CRD System that could affect coupling |
| SR 3.10.7.6 Verify CRD charging water header pressure \geq 940 psig. | 7 days |

4.0 DESIGN FEATURES

4.1 Site Location

4.1.1 Site and Exclusion Area Boundaries

The site area boundary follows the Illinois River to the north, the Kankakee River to the east, a country road from Divine extended eastward to the Kankakee River on the south, and the Elgin, Joliet, and Eastern Railway right-of-way on the west. The exclusion area boundary shall be an 800 meter radius from the centerline of the reactor vessels.

4.1.2 Low Population Zone

The low population zone shall be a five mile radius from the centerline of the reactor vessels.

4.2 Reactor Core

4.2.1 Fuel Assemblies

The reactor shall contain 724 fuel assemblies. Each assembly shall consist of a matrix of Zircaloy clad fuel rods with an initial composition of natural or slightly enriched uranium dioxide (UO_2) as fuel material. The assemblies may contain water rods or a water box. Limited substitutions of Zircaloy, ZIRLO, or stainless steel filler rods for fuel rods, in accordance with approved applications of fuel rod configurations, may be used. Fuel assemblies shall be limited to those fuel designs that have been analyzed with NRC staff approved codes and methods and have been shown by tests or analyses to comply with all safety design bases. A limited number of lead test assemblies that have not completed representative testing may be placed in nonlimiting core regions.

4.2.2 Control Rod Assemblies

The reactor core shall contain 177 cruciform shaped control rod assemblies. The control material shall be boron carbide and hafnium metal as approved by the NRC.

(continued)

4.0 DESIGN FEATURES (continued)

4.3 Fuel Storage

4.3.1 Criticality

4.3.1.1 The spent fuel storage racks are designed and shall be maintained with:

- a. $k_{eff} \leq 0.95$ if fully flooded with unborated water, which includes an allowance for uncertainties as described in Section 9.1.2 of the UFSAR; and
- b. A nominal 6.30 inch center to center distance between fuel assemblies placed in the storage racks.

4.3.2 Drainage

The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 589 ft 2.5 inches.

4.3.3 Capacity

The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 3537 fuel assemblies.

5.0 ADMINISTRATIVE CONTROLS

5.1 Responsibility

- 5.1.1 The station manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.
- 5.1.2 A unit supervisor shall be responsible for the control room command function (Since the control room is common to both units, the control room command function for both units can be satisfied by a single unit supervisor). During any absence of the unit supervisor from the control room while the unit is in MODE 1, 2, or 3, an individual with an active Senior Reactor Operator (SRO) license shall be designated to assume the control room command function. During any absence of the unit supervisor from the control room while the unit is in MODE 4 or 5 or defueled, an individual with an active SRO license or Reactor Operator license shall be designated to assume the control room command function.
-

5.0 ADMINISTRATIVE CONTROLS

5.2 Organization

5.2.1 Onsite and Offsite Organizations

Onsite and offsite organizations shall be established for unit operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be defined and established throughout highest management levels, intermediate levels, and all operating organization positions. These relationships shall be documented and updated, as appropriate, in organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements, including the plant-specific titles of those personnel fulfilling the responsibilities of the positions delineated in these Technical Specifications, shall be documented in the Quality Assurance Manual.
- b. The station manager shall be responsible for overall safe operation of the plant and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- c. A corporate officer shall have corporate responsibility for overall plant nuclear safety and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety.
- d. The individuals who train the operating staff, or perform radiation protection or quality assurance functions, may report to the appropriate onsite manager; however, these individuals shall have sufficient organizational freedom to ensure their independence from operating pressures.

5.2.2 Unit Staff

The unit staff organization shall include the following:

(continued)

5.2 Organization

5.2.2 Unit Staff (continued)

- a. A total of three non-licensed operators for the two units is required in all conditions. At least one of the required non-licensed operators shall be assigned to each unit.
 - b. Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and Specifications 5.2.2.a and 5.2.2.f for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.
 - c. A radiation protection technician shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.
 - d. The amount of overtime worked by unit staff members performing safety related functions shall be limited and controlled in accordance with the NRC Policy Statement on working hours (Generic Letter 82-12).
 - e. The operations manager or shift operations supervisor shall hold an SRO license.
 - f. The Shift Technical Advisor (STA) shall provide advisory technical support to the shift manager in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. In addition, the STA shall meet the qualifications specified by the Commission Policy Statement on Engineering Expertise on Shift.
-

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

- 5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971, except for the radiation protection manager, who shall meet or exceed the qualifications for "Radiation Protection Manager" in Regulatory Guide 1.8, September 1975.
-

5.0 ADMINISTRATIVE CONTROLS

5.4 Procedures

- 5.4.1 Written procedures shall be established, implemented, and maintained covering the following activities:
- a. The applicable procedures recommended in Regulatory Guide 1.33, Revision 2, Appendix A, February 1978;
 - b. The emergency operating procedures required to implement the requirements of NUREG-0737 and NUREG-0737, Supplement 1, as stated in Generic Letter 82-33, Section 7.1;
 - c. Fire Protection Program implementation; and
 - d. All programs specified in Specification 5.5.
-

5.0 ADMINISTRATIVE CONTROLS

5.5 Programs and Manuals

The following programs shall be established, implemented and maintained.

5.5.1 Offsite Dose Calculation Manual (ODCM)

- a. The ODCM shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring alarm and trip setpoints, and in the conduct of the radiological environmental monitoring program; and
- b. The ODCM shall also contain the radioactive effluent controls and radiological environmental monitoring activities, and descriptions of the information that should be included in the Annual Radiological Environmental Operating, and Radioactive Effluent Release Reports required by Specification 5.6.2 and Specification 5.6.3.
- c. Licensee initiated changes to the ODCM:
 1. Shall be documented and records of reviews performed shall be retained. This documentation shall contain:
 - (a) Sufficient information to support the change(s) together with the appropriate analyses or evaluations justifying the change(s), and
 - (b) A determination that the change(s) maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50, Appendix I, and do not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations;
 2. Shall become effective after the approval of the station manager; and
 3. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Radioactive Effluent Release Report for the period of the report in which any change in the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and

(continued)

5.5 Programs and Manuals

5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the Core Spray, High Pressure Coolant Injection, Low Pressure Coolant Injection, Isolation Condenser, Shutdown Cooling, Reactor Water Cleanup, process sampling, containment monitoring, and Standby Gas Treatment. The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at 24 month intervals.

The provisions of SR 3.0.2 are applicable to the 24 month Frequency for performing integrated system leak test activities.

5.5.3 Post Accident Sampling

This program provides controls that ensure the capability to obtain and analyze reactor coolant, radioactive iodines, and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

- a. Training of personnel;
- b. Procedures for sampling and analysis; and
- c. Provisions for maintenance of sampling and analysis equipment.

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program

This program conforms to 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;
- b. Limitations on the concentrations of radioactive material released in liquid effluents to unrestricted areas, conforming to ten times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001-20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents in accordance with 10 CFR 20.1302 and with the methodology and parameters in the ODCM;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative and projected dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days;
- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be in accordance with the following:

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

1. For noble gases: a dose rate \leq 500 mrems/yr to the whole body and a dose rate \leq 3000 mrems/yr to the skin, and
 2. For iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days: a dose rate \leq 1500 mrems/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives $>$ 8 days in gaseous effluents released from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and
- j. Limitations on the annual dose or dose commitment to any member of the public, beyond the site boundary, due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluents Control Program Surveillance Frequencies.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the UFSAR Section 3.9, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Inservice Testing Program

This program provides controls for inservice testing of ASME Code Class 1, 2, and 3 pumps and valves.

- a. Testing Frequencies specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda are as follows:

(continued)

5.5 Programs and Manuals

5.5.6 Inservice Testing Program (continued)

| <u>ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice testing activities</u> | <u>Required Frequencies for performing inservice testing activities</u> |
|---|---|
| Weekly | At least once per 7 days |
| Monthly | At least once per 31 days |
| Quarterly or every 3 months | At least once per 92 days |
| Semiannually or every 6 months | At least once per 184 days |
| Every 9 months | At least once per 276 days |
| Yearly or annually | At least once per 366 days |
| Biennially or every 2 years | At least once per 731 days |
| Every 48 months | At least once per 1461 days |

- b. The provisions of SR 3.0.2 are applicable to the above required Frequencies for performing inservice testing activities;
- c. The provisions of SR 3.0.3 are applicable to inservice testing activities; and
- d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any TS.

5.5.7 Ventilation Filter Testing Program (VFTP)

The VFTP shall establish the required testing of Engineered Safety Feature (ESF) filter ventilation systems. Tests described in Specification 5.5.7.a and 5.5.7.b shall be performed once per 24 months; after each complete or partial replacement of the HEPA filter bank or charcoal adsorber bank; after any structural maintenance on the HEPA filter bank or charcoal adsorber bank housing; and, following painting, fire, or chemical release in any ventilation zone communicating with the subsystem while it is in operation that could adversely affect the filter bank or charcoal adsorber capability.

(continued)

5.5 Programs and Manuals

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

Tests described in Specification 5.5.7.c shall be performed once per 24 months; after 720 hours of adsorber operation; after any structural maintenance on the charcoal adsorber bank housing; and, following painting, fire, or chemical release in any ventilation zone communicating with the subsystem while it is in operation that could adversely affect the charcoal adsorber capability.

Tests described in Specification 5.5.7.d and 5.5.7.e shall be performed once per 24 months.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the VFTP test frequencies.

- a. Demonstrate for each of the ESF systems that an inplace test of the HEPA filters shows a penetration and system bypass specified below when tested in accordance with Regulatory Guide 1.52, Revision 2, and ANSI/ASME N510-1980 at the system flowrate specified below:

| <u>ESF Ventilation</u> <u>System</u> | <u>Penetration</u> | <u>Flowrate</u> |
|---|--------------------|--------------------------------|
| Standby Gas Treatment (SGT) System | < 1.0% | ≥ 3600 cfm and ≤ 4400 cfm |
| Control Room Emergency Ventilation (CREV) System | < 0.05% | ≥ 1800 scfm and ≤ 2200 scfm |

- b. Demonstrate for each of the ESF systems that an inplace test of the charcoal adsorber shows a penetration and system bypass specified below when tested in accordance with Regulatory Guide 1.52, Revision 2, and ANSI/ASME N510-1980 at the system flowrate specified below:

(continued)

5.5 Programs and Manuals

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

| <u>ESF Ventilation</u> <u>System</u> | <u>Penetration</u> | <u>Flowrate</u> |
|--|--------------------|--------------------------------|
| Standby Gas Treatment (SGT) System | < 1.0% | ≥ 3600 cfm and ≤ 4400 cfm |
| Control Room Emergency Ventilation (CREV) System | < 0.05% | ≥ 1800 scfm and ≤ 2200 scfm |

- c. Demonstrate for each of the ESF systems that a laboratory test of a sample of the charcoal adsorber, when obtained as described in Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than the value specified below when tested in accordance with ASTM D3803-1989 at a temperature of 30°C and relative humidity (RH) specified below:

| <u>ESF Ventilation</u> <u>System</u> | <u>Penetration</u> | <u>RH</u> |
|--|--------------------|-----------|
| Standby Gas Treatment (SGT) System | 2.5% | 70% |
| Control Room Emergency Ventilation (CREV) System | 0.5% | 70% |

- d. Demonstrate for each of the ESF systems that the pressure drop across the combined HEPA filters and the charcoal adsorbers is less than the value specified below when tested at the system flowrate specified as follows:

| <u>ESF Ventilation</u> <u>System</u> | <u>Delta P</u> | <u>Flowrate</u> |
|--|------------------------|--------------------------------|
| Standby Gas Treatment (SGT) System | < 6 inches water guage | ≥ 3600 cfm and ≤ 4400 cfm |
| Control Room Emergency Ventilation (CREV) System | < 6 inches water guage | ≥ 1800 scfm and ≤ 2200 scfm |

(continued)

5.5 Programs and Manuals

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

- e. Demonstrate that the heaters for each of the ESF systems dissipate the value, corrected for voltage variations at the 480 V bus, specified below when tested in accordance with ANSI/ASME N510-1989:

| <u>ESF Ventilation System</u> | <u>Wattage</u> |
|--|--------------------------------------|
| Standby Gas Treatment (SGT) System | ≥ 27 kW and ≤ 33 kW |
| Control Room Emergency Ventilation (CREV) System | ≥ 10.8 kW and ≤ 13.2 kW |

5.5.8 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Off-Gas System and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks.

The program shall include:

- a. The limits for concentrations of hydrogen in the Off-Gas System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion); and
- b. A surveillance program to ensure that the quantity of radioactivity contained in all outdoor liquid radwaste tanks that are not surrounded by liners, dikes, or walls, capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the Liquid Waste Management System is ≤ 0.7 curies in each tank and ≤ 3.0 curies total in all tanks, which is less than the amount that would result in concentrations less than the limits of 10 CFR 20, Appendix B, Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area, in the event of an uncontrolled release of the tanks' contents.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Explosive Gas and Storage Tank Radioactivity Monitoring Program Surveillance Frequencies.

(continued)

5.5 Programs and Manuals

5.5.9 Diesel Fuel Oil Testing Program

A diesel fuel oil testing program shall establish the required testing of both new fuel oil and stored fuel oil. The program shall include sampling and testing requirements, and acceptance criteria, all in accordance with applicable ASTM Standards. The purpose of the program is to establish the following:

- a. Acceptability of new fuel oil for use prior to addition to storage tanks by determining that the fuel oil has:
 - 1. An API gravity or an absolute specific gravity within limits,
 - 2. A flash point and kinematic viscosity within limits,
 - 3. A clear and bright appearance with proper color or water and sediment within limits;
- b. Within 31 days following addition of the new fuel oil to storage tanks verify that the properties of the new fuel oil, other than those addressed in a., above, are within limits; and
- c. Total particulate concentration of the fuel oil in the storage tanks is ≤ 10 mg/l when tested every 31 days in accordance with the applicable ASTM Standard.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Diesel Fuel Oil Testing Program test frequencies.

5.5.10 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

- a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.
- b. Licensees may make changes to Bases without prior NRC approval provided the changes do not require either of the following:
 - 1. A change in the TS incorporated in the license; or

(continued)

5.5 Programs and Manuals

5.5.10 Technical Specifications (TS) Bases Control Program (continued)

2. A change to the UFSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.
- c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the UFSAR.
- d. Proposed changes that meet the criterion of Specification 5.5.10.b.1 or 5.5.10.b.2 above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

5.5.11 Safety Function Determination Program (SFDP)

This program ensures loss of safety function is detected and appropriate actions taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other appropriate limitations and remedial or compensatory actions may be identified to be taken as a result of the support system inoperability and corresponding exception to entering supported system Condition and Required Actions. This program implements the requirements of LCO 3.0.6.

- a. The SFDP shall contain the following:
 1. Provisions for cross division checks to ensure a loss of the capability to perform the safety function assumed in the accident analysis does not go undetected;
 2. Provisions for ensuring the plant is maintained in a safe condition if a loss of function condition exists;
 3. Provisions to ensure that an inoperable supported system's Completion Time is not inappropriately extended as a result of multiple support system inoperabilities; and
 4. Other appropriate limitations and remedial or compensatory actions.

(continued)

5.5 Programs and Manuals

5.5.11 Safety Function Determination Program (SFDP) (continued)

- b. A loss of safety function exists when, assuming no concurrent single failure, and assuming no concurrent loss of offsite power or loss of onsite diesel generator(s), a safety function assumed in the accident analysis cannot be performed. For the purpose of this program, a loss of safety function may exist when a support system is inoperable, and:
 - 1. A required system redundant to system(s) supported by the inoperable support system is also inoperable; or
 - 2. A required system redundant to system(s) in turn supported by the inoperable supported system is also inoperable; or
 - 3. A required system redundant to support system(s) for the supported systems described in b.1 and b.2 above is also inoperable.
- c. The SFDP identifies where a loss of safety function exists. If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered. When a loss of safety function is caused by the inoperability of a single Technical Specification support system, the appropriate Conditions and Required Actions to enter are those of the support system.

5.5.12 Primary Containment Leakage Rate Testing Program

- a. This program shall establish the leakage testing of the primary containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemption. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak-Testing Program," dated September 1995.
- b. The peak calculated primary containment internal pressure for the design basis loss of coolant accident, P_a , is 48 psig.

(continued)

5.5 Programs and Manuals

5.5.12 Primary Containment Leakage Rate Testing Program (continued)

- c. The maximum allowable primary containment leakage rate, L_a , at P_a , is 1.6% of primary containment air weight per day.
 - d. Leakage rate acceptance criteria are:
 - 1. Primary containment overall leakage rate acceptance criterion is $\leq 1.0 L_a$. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are $\leq 0.60 L_a$ for the combined Type B and Type C tests, and $\leq 0.75 L_a$ for Type A tests.
 - 2. Air lock testing acceptance criteria is the overall air lock leakage rate is $\leq 0.05 L_a$ when tested at $\geq P_a$.
 - e. The provisions of SR 3.0.3 are applicable to the Primary Containment Leakage Rate Testing Program.
-

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Occupational Radiation Exposure Report

-----NOTE-----
A single submittal may be made for a multiple unit station. The submittal should combine sections common to all units at the station.

A tabulation on an annual basis of the number of station, utility, and other personnel (including contractors), for whom monitoring was performed, receiving an annual deep dose equivalent > 100 mrem and the associated collective deep dose equivalent (reported in man-rem) according to work and job functions (e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling). This tabulation supplements the requirements of 10 CFR 20.2206. The dose assignments to various duty functions may be estimated based on pocket ionization chamber, thermoluminescence dosimeter (TLD), or electronic dosimeter measurements. Small exposures totaling < 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total deep dose equivalent received from external sources should be assigned to specific major work functions. The report covering the previous calendar year shall be submitted by April 30 of each year.

5.6.2 Annual Radiological Environmental Operating Report

-----NOTE-----
A single submittal may be made for a multiple unit station. The submittal should combine sections common to all units at the station.

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual

(continued)

5.6 Reporting Requirements

5.6.2 Annual Radiological Environmental Operating Report (continued)

(ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

5.6.3 Radioactive Effluent Release Report

-----NOTE-----

A single submittal may be made for a multiple unit station. The submittal should combine sections common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

The Radioactive Effluent Release Report covering the operation of the unit shall be submitted prior to May 1 of each year in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and the Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the safety and relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

1. The APLHGR for Specification 3.2.1.
2. The MCPR for Specification 3.2.2.

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

3. The LHGR for Specification 3.2.3.
 4. The LHGR and transient linear heat generation rate limit for Specification 3.2.4.
 5. Control Rod Block Instrumentation Setpoint for the Rod Block Monitor—Upscale Function Allowable Value for Specification 3.3.2.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
1. ANF-1125(P)(A), "Critical Power Correlation - ANFB."
 2. ANF-524(P)(A), "ANF Critical Power Methodology for Boiling Water Reactors."
 3. XN-NF-79-71(P)(A), "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors."
 4. XN-NF-80-19(P)(A), "Exxon Nuclear Methodology for Boiling Water Reactors."
 5. XN-NF-85-67(P)(A), "Generic Mechanical Design for Exxon Nuclear Jet Pump Boiling Water Reactors Reload Fuel."
 6. ANF-913(P)(A), "CONTRANSA2: A Computer Program for Boiling Water Reactor Transient Analysis."
 7. XN-NF-82-06(P)(A), Qualification of Exxon Nuclear Fuel for Extended Burnup Supplement 1 Extended Burnup Qualification of ENC 9x9 BWR Fuel.
 8. ANF-89-14(P)(A), Advanced Nuclear Fuels Corporation Generic Mechanical Design for Advance Nuclear Fuels Corporation 9x9-IX and 9x9-9X BWR Reload Fuel.

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

9. ANF-89-98(P)(A), Generic Mechanical Design Criteria for BWR Fuel Designs.
10. ANF-91-048(P)(A), Advanced Nuclear Fuels Corporation Methodology for Boiling Water Reactors EXEM BWR Evaluation Model.
11. Commonwealth Edison Company Topical Report NFSR-0091, "Benchmark of CASMO/MICROBURN BWR Nuclear Design Methods."
12. EMF-85-74(P), RODEX2A (BWR) Fuel Rod Thermal Mechanical Evaluation Model.

The COLR will contain the complete identification for each of the TS referenced topical reports used to prepare the COLR (i.e., report number, title, revision, date, and any supplements).

- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

5.6.6 Post Accident Monitoring (PAM) Instrumentation Report

When a report is required by Condition B or F of LCO 3.3.3.1, "Post Accident Monitoring (PAM) Instrumentation," a report shall be submitted within the following 14 days. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.1 Pursuant to 10 CFR 20, paragraph 20.1601(c), in lieu of the requirements of 10 CFR 20.1601, each high radiation area, as defined in 10 CFR 20, in which the intensity of radiation is > 100 mrem/hr at 30 cm (12 in.), shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP) (or equivalent document). Individuals qualified in radiation protection procedures (e.g., radiation protection technicians) or personnel escorted by such individuals may be exempt from the RWP issuance requirement during the performance of their assigned duties, provided they are otherwise following plant radiation protection procedures for entry into high radiation areas.

Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device that continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device that continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate levels in the area have been established and personnel are aware of them.
- c. An individual qualified in radiation protection procedures with a radiation dose rate monitoring device, who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified in the RWP (or equivalent document).

5.7.2 In addition to the requirements of Specification 5.7.1, areas accessible to personnel with radiation levels > 1000 mrem/hr at 30 cm (12 in.) from the radiation source or from any surface which the radiation penetrates shall require the following:

- a. Doors shall be locked to prevent unauthorized entry and shall not prevent individuals from leaving the area. In place of locking the door, direct or electronic surveillance

(continued)

5.7 High Radiation Area

5.7.2 (continued)

that is capable of preventing unauthorized entry may be used. The keys shall be maintained under the administrative control of the shift manager on duty or radiation protection supervision.

- b. Personnel access and exposure control requirements of activities being performed within these areas shall be specified by an approved RWP (or equivalent document).
- c. Each person entering the area shall be provided with an alarming radiation monitoring device that continuously integrates the radiation dose rate (such as an electronic dosimeter). Surveillance and radiation monitoring by a radiation protection technician may be substituted for an alarming dosimeter.

5.7.3 For individual high radiation areas with radiation levels of > 1000 mrem/hr at 30 cm (12 in.), accessible to personnel, that are located within large areas where no enclosure exists for purposes of locking, and where no enclosure can be reasonably constructed around the individual area, that individual area shall be barricaded and conspicuously posted, and a flashing light shall be activated as a warning device.
