

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.2 ECCS - Operating

LCO 3.5.2 Two ECCS trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

NOTE

In MODE 3, both safety injection (SI) pump flow paths may be isolated by closing the isolation valve(s) for up to 2 hours to perform pressure isolation valve testing per SR 3.4.14.1.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more trains inoperable. <u>AND</u> At least 100% of the ECCS flow equivalent to a single OPERABLE ECCS train available.	A.1 Restore train(s) to OPERABLE status	-----NOTE----- The Completion Time may be extended to 7 days for Unit 2 cycle 10 for repair or replacement of centrifugal charging pump 2-1. ----- 72 hours
	B. Required Action and associated Completion Time not met. B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4.	6 hours 12 hours