



Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247

April 19, 2001  
LIC-01-0041

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Reference: Docket No. 50-285

**SUBJECT: Fort Calhoun Station (FCS) Steam Generator Tube Plugging Report - 2001  
Refueling Outage**

Pursuant to FCS Unit No. 1 Technical Specifications (TS) 3.17(5)(i), the Omaha Public Power District (OPPD) completed eddy current testing of the steam generator tubes at Fort Calhoun Station (FCS) on April 10, 2001, during the nineteenth refueling outage. In accordance with the TS, OPPD reports that 51 tubes were plugged in Steam Generator RC-2A and 70 tubes were plugged in Steam Generator RC-2B. To date, RC-2A has 218 plugged tubes and RC-2B has 227 plugged tubes. No tubes were repaired by sleeving in either steam generator during the 2001 Refueling Outage. Specific details in regard to steam generator tube plugging will be included in the six (6) month report required by Technical Specification 3.17(5)(ii).

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "S. K. Gambhir", is written over a horizontal line.

S. K. Gambhir  
Division Manager  
Nuclear Operations

SKG/RRL/rri

c: E. W. Merschoff, NRC Regional Administrator, Region IV  
L. R. Wharton, NRC Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
Winston & Strawn

IE 26