

April 27, 2001

Mr. Gregg R. Overbeck  
Senior Vice President, Nuclear  
Arizona Public Service Company  
P. O. Box 52034  
Phoenix, AZ 85072-2034

SUBJECT: PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3 -  
REGARDING REACTOR VESSEL MATERIAL SURVEILLANCE CAPSULE  
REPORTS (TAC NO. MB0396)

Dear Mr. Overbeck:

By letters dated October 20, 2000, April 15, 1994, and April 26, 1995, the reactor vessel material capsule reports were submitted to the Nuclear Regulatory Commission (NRC) for Palo Verde Nuclear Generating Station, Units 1, 2, and 3, respectively. This is a reporting requirement of Appendix H to 10 CFR Part 50. Each of these letters submitted a report on the results of the analysis of the surveillance capsule removed from the reactor vessel in accordance with the reactor vessel material surveillance program, which monitors the effects of neutron irradiation on the reactor vessel materials. The surveillance program is also a requirement of Appendix H.

The letters submitted WCAP-15589, "Analysis of Capsule 38° From the ... Unit 1 Reactor Vessel Radiation Surveillance Program," dated October 2000; WCAP-13935, "Analysis of Capsule 137° From the ... Unit No. 2 Reactor Vessel Radiation Surveillance Program," dated February 1994; and WCAP-14208, "Analysis of Capsule No. 4 From the ... Unit No. 3 Reactor Vessel Radiation Surveillance Program," dated January 1995.

Based on the NRC staff's review of the three WCAPs listed above, it appears that the FERRET Code was used to adjust the measured neutron fluence from the analysis of the material surveillance capsules. Because the NRC staff has not reviewed and approved the FERRET Code for this use, the NRC staff believes that the reported fluence values for the units could be underestimated and the reported fluence value for Unit 1 could be underestimated by as much as 17 percent. The information in the WCAPs for Units 2 and 3 was not enough for the NRC staff to provide an estimate for these units; however, the staff assumes that the 17 percent underestimation also applies to Units 2 and 3. Because of this uncertainty in the adjusted measured neutron fluence values, you are requested to provide (1) neutron fluence values for the three units based on the capsule reports using an adjustment code that has been approved for this use by the NRC staff, (2) a justification of the use of the FERRET Code for adjusting the measured neutron fluence from the material surveillance capsules without underestimating the neutron fluence, or (3) update the pressure/temperature (P/T) limits for the three units to account for the 17 percent underestimation of the neutron fluence values.

G. Overbeck

- 2 -

April 27, 2001

Because the current P/T limits for the three units are 32 effective full power years (EFPY) and the 17 percent underestimation would not reduce the EFPY to within the next operating cycle of Unit 1, you are requested to submit your response to our request within one year of the receipt of this letter.

If there is any questions concerning this letter, please contact me at 301-415-1307, or through the Internet at [jnd@nrc.gov](mailto:jnd@nrc.gov).

Sincerely,

*/RA/*

Jack N. Donohew, Senior Project Manager, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-528, STN 50-529,  
and STN 50-530

cc: See next page

Unit 1, you are requested to submit your response to our request within one year of the receipt of this letter.

If there is any questions concerning this letter, please contact me at 301-415-1307, or through the Internet at jnd@nrc.gov.

Sincerely,

*/RA/*

Jack N. Donohew, Senior Project Manager, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-528, STN 50-529,  
and STN 50-530

cc: See next page

DISTRIBUTION

PUBLIC

PDIV-2 r/f

RidsNrrDlpm (C.Carpenter)

RidsNrrDlpmLpdiv (S.Richards)

RidsNrrDlpmLpdiv2 (S.Dembek)

RidsNrrPMJDonohew

RidsNrrLAMMcAllister

RidsAcraAcnwMailCenter

RidsOgcRp

RidsRgn4MailCenter (L. Smith, L. Hurley, D. Bujol)

LBerry

SSheng

LLois

**ACCESSION NO: ML011170117**

OFFICE	PDIV-2/PM	PDIV-D/LA	EMCB	PDIV-2/SC
NAME	JDonohew:am	MMcAllister	SSheng	SDembek
DATE	4/25/2001	4/24/01	4/25/01	4/26/01

OFFICIAL RECORD COPY

Palo Verde Generating Station, Units 1, 2, and 3

cc:

Mr. Steve Olea  
Arizona Corporation Commission  
1200 W. Washington Street  
Phoenix, AZ 85007

Douglas Kent Porter  
Senior Counsel  
Southern California Edison Company  
Law Department, Generation Resources  
P.O. Box 800  
Rosemead, CA 91770

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 40  
Buckeye, AZ 85326

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavillion  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

Chairman  
Maricopa County Board of Supervisors  
301 W. Jefferson, 10th Floor  
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director

Arizona Radiation Regulatory Agency  
4814 South 40 Street  
Phoenix, AZ 85040

Mr. Craig K. Seaman, Director  
Regulatory Affairs  
Arizona Public Service Company  
P.O. Box 52034  
Phoenix, AZ 85072-2034

Mr. John C. Horne  
Vice President, Power Generation  
El Paso Electric Company  
2702 N. Third Street, Suite 3040  
Phoenix, AZ 85004

Mr. David Summers  
Public Service Company of New Mexico  
414 Silver SW, #1206  
Albuquerque, NM 87102

Mr. Jarlath Curran  
Southern California Edison Company  
5000 Pacific Coast Hwy Bldg DIN  
San Clemente, CA 92672

Mr. Robert Henry  
Salt River Project  
6504 East Thomas Road

Scottsdale, AZ 85251

Terry Bassham, Esq.  
General Counsel  
El Paso Electric Company  
123 W. Mills  
El Paso, TX 79901

Mr. John Schumann  
Los Angeles Department of Water & Power  
Southern California Public Power Authority  
P.O. Box 51111, Room 1255-C  
Los Angeles, CA 90051-0100