

J. Bernie Beasley, Jr., P.E.
Vice President
Vogtle Project

**Southern Nuclear
Operating Company, Inc.**
40 Inverness Center Parkway
P.O. Box 1295
Birmingham, Alabama 35201

Tel 205.992.7110
Fax 205.992.0403



May 2, 2001

LCV-1536

Docket No. 50-425

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

VOGTLE ELECTRIC GENERATING PLANT
TECHNICAL SPECIFICATION REPORT 2-2001-1
NUMBER OF STEAM GENERATOR TUBES PLUGGED DURING 2R8


Gentlemen:

In accordance with the requirements of Vogtle Electric Generating Plant Technical Specification 5.6.10, Southern Nuclear Operating Company submits this report of the number of steam generator (SG) tubes plugged during the Unit 2 eighth maintenance/refueling outage (2R8).

During the outage, inservice inspections were conducted on SG #2 and SG #3. As a result of these SG tube inspections completed on April 24, 2001, no tubes were plugged.

Should there be any questions, please contact this office.

Sincerely,


J. B. Beasley, Jr.

JBB/BHW

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser
Mr. M. Sheibani
SNC Document Management

cc: U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. R. R. Assa, Vogtle Project Manager, NRR
Mr. J. Zeiler, Senior Resident Inspector - Vogtle

A001