

1/12/2000

Conf Call - Garth Pary, re, Mike Cheek  
Tim Leahy, Soti Kherulia, Harold Blackman

What questions or problems do they have?

"We will present it as an NRC analysis with INEEL input."

We need ET<sub>2</sub>, FT, + cutsets.

Fax what they have. Then convert to WP and email to me.

We want repair models done just as we asked for LOI and LOC.

LOI  $\lambda$   $10^{-2} \rightarrow 10^{-3}$  change based on commitments.

HEP walkdown  $1 \times 10^{-5} \rightarrow 5 \times 10^{-3}$  changed because timing was short for the small leak. Chose 30 gpm as leak rate. Gave them 4 hrs to check it out. Garth changed SPAR sheets. Only can find through the walkdown, alarms are failed.

OIS  $1.5 \times 10^{-3} \rightarrow 1.3 \times 10^{-3}$  <sup>calc error?</sup> LOI-OISN

LOI-IND-L - No dependence

4105