

From: Tanya Eaton / *NAR*
To: George Hubbard
Date: Tue, Aug 22, 2000 9:48 AM
Subject: Cover Letter for TWG report

George,

The cover letter is attached. Also, if you want to access it from the G drive, it is saved in
G:\SPLB\SECTIONA\DECOM.GRP\FinalReport\cover letter.wpd

I will see you at 1:00.

Tanya

4278

February 14, 2000

MEMORANDUM TO: Chairman Meserve
Commissioner Dicus
Commissioner Diaz
Commissioner McGaffigan
Commissioner Merrifield

FROM: William D. Travers */RA by Frank J. Miraglia Acting For/*
Executive Director for Operations

SUBJECT: DRAFT FINAL TECHNICAL STUDY ON SPENT FUEL POOL ACCIDENT
RISK AT DECOMMISSIONING NUCLEAR POWER PLANTS

In March 1999, the NRC staff met with the Commission to discuss an ongoing effort to improve decommissioning regulations. An area of particular interest to the Commission was the perception that the risks at decommissioning nuclear power plants are very low yet many of the regulations governing decommissioning plants remain the same as those required for operating reactors. The staff proposed to take a risk-informed look at power reactor decommissioning requirements and to use the risk insights derived from this review to guide the promulgation of new regulations. The staff subsequently initiated a technical study on spent fuel pool accident risks at decommissioning plants. A preliminary study was completed in June 1999 and concluded that the risks at decommissioning nuclear power plants with recently irradiated fuel in the spent fuel pool could not be dismissed as low when compared to operating reactors due to the frequency and consequences of postulated events leading to drainage of the spent fuel pool and a subsequent zirconium fire. The staff then performed a more comprehensive study to better quantify the risk from a decommissioning nuclear power plant spent fuel pool and provide recommendations, where appropriate, on the factors that have the biggest impact on the risk. The results of the study are intended to support rulemaking in regulatory areas such as emergency planning, safeguards, and insurance for decommissioning plants. The details of this effort are discussed in SECY-99-168, "Improving Decommissioning Regulations for Nuclear Power Plants," dated June 30, 1999.

The staff has now completed a review and requantification of its preliminary risk assessment including independent outside technical review of its analyses and assumptions. Substantial efforts to involve public and industry representatives throughout this effort have been expended. The NRC solicited feedback on its June study assumptions and methods and held numerous public meetings including a 2-day public workshop. Attached for your information is the draft final technical study on spent fuel pool accident risks at decommissioning nuclear power plants.

CONTACTS: George Hubbard, NRR/DSSA/SPLB
301-415-2870
Mark Rubin, NRR/DSSA/SPSB
301-415-3234

ML003680337

After a period of one year following permanent shutdown, the results of this report estimated the generic frequency of events leading to zirconium fires at decommissioning plants to be less than 3×10^{-6} per year for a plant that implements the design and operational characteristics assumed in the risk assessment performed by the staff. This frequency was estimated based on the assumption that the industry commitments plus additional staff assumptions would be implemented. This estimate could be much higher for a plant that does not implement these operational characteristics. The most significant contributor to this risk is a seismic event which exceeds the design basis earthquake. However, the overall frequency of this event is within the staff developed spent fuel pool performance guideline for large radionuclide releases (related to a zirconium fire) of 1×10^{-5} per year.

The focus of this report is the risk associated with wet storage of spent fuel during decommissioning. However, during this study, the staff was alert to any implications on the storage of spent fuel during power operation. With regard to power operation, the resolution of Generic Issue (GI) 82, "Beyond Design Basis Accidents in Spent Fuel Pools," and other studies of operating reactor spent fuel pools concluded that existing requirements for operating reactor spent fuel pools are sufficient. During this study, the staff evaluated one additional issue concerning the drop of a cask on the spent fuel pool floor. Due to the industry's commitment to Phase II of NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants, Resolution of Generic Technical Activity A-36," this is not a concern for decommissioning reactors.

Operating reactors are not required to implement Phase II of NUREG-0612. The risk for spent fuel pools at operating plants is limited by the lower expected frequency of heavy load lifts as compared to decommissioning plants. Nonetheless, this issue will be further examined as part of the Office of Nuclear Regulatory Research's prioritization of Generic Safety Issue 186, "Potential Risk and Consequences of Heavy Load Drops in Nuclear Power Plants," which was accepted in May 1999.

Concurrent with providing the Commission a copy of this draft report, the staff will be issuing it for public comment via the Federal Register and an NRC web page. Following resolution of any Commission and public comments and review by the ACRS, the staff will publish the final report

The Commissioners

- 3 -

in May 2000. The staff will utilize the industry commitments and the conclusions in this report to support an integrated decommissioning rulemaking plan to be submitted in June 2000 and develop interim guidance for any future plants that elect to decommission prior to establishing revised regulations.

Attachment: Draft Final Study on Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants

cc w/att: SECY
OGC
OCA
OPA
CFO
CIO

in May 2000. The staff will utilize the industry commitments and the conclusions in this report to support an integrated decommissioning rulemaking plan to be submitted in June 2000 and develop interim guidance for any future plants that elect to decommission prior to establishing revised regulations.

Attachment: Draft Final Study on Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants

cc w/att: SECY
OGC
OCA
OPA
CFO
CIO

DISTRIBUTION:

File Center	EDO r/f	FMiraglia	SCollins/RZimmerman	MTschil tzPDIV- D r/f
WHuffman	RDudley	AThadani	GHubbard	ACRS
FKantor	RRosano	LCamper	TEaton	DJackson
				BZalc a n MMalloy JJohns o n (ADIP)

NRR Mailroom (WITS 199900131)

PMagnanelli (WITS 199900131)

ACCESSION NUMBER: ML003680337 TEMPLATE NUMBER: EDO-004 *See previous concurrence

To receive a copy of this document, indicate "C" in the box										
OFFICE	SPLB/SC	C	Tech ED	C	SPLB/BC	C	SRSB/SC	C	SRSB/BC	C
NAME	GHubbard *				JHannon *		MRubin *		RBarrett *	
DATE	02/02/00		02/02/00		02/02/00		02/02/00		02/02/00	
To receive a copy of this document, indicate "C" in the box										
OFFICE	SRXB/BC	C	RGEBC/BC	C	DE	C	DE/D	C	IOLB/BC	C
NAME	JWermiel *		CCarpenter *		GBagchi *		JStrosnider *		HChristensen *	
DATE	01/21/00		02/03/00		02/02/00		02/02/00		02/03/00	
To receive a copy of this document, indicate "C" in the box										
OFFICE	DSSA/D	C	PDIV-D/D		DLPM/D		RES		DCB (NMSS)	
NAME	GHolahan *		SRichards *		JZwolinski *		AThadani *		LWCamper *	
DATE	02/03/00		02/02/00		02/04/00		02/04/00		02/02/00	
To receive a copy of this document, indicate "C" in the box										
OFFICE	ADPT/NRR		NRR/D		EDO					
NAME	BSheron *		SCollins *		WTravers					
DATE	02/04/00		2/4/00		2/14/00					

DOCUMENT NAME: G:\SPLB\SECTIONA\DECOM.GRP\FinalOutput\FinalSFPRReport417.WPD

OFFICIAL RECORD COPY