

## EQUATIONS AND CONVERSIONS HANDOUT SHEET

---

### EQUATIONS

$$\dot{Q} = \dot{m}c_p\Delta T$$

$$\dot{Q} = \dot{m}\Delta h$$

$$\dot{Q} = UA\Delta T$$

$$\dot{Q} \propto \dot{m}_{\text{Nat Circ}}^2$$

$$\Delta T \propto \dot{m}_{\text{Nat Circ}}^2$$

$$K_{\text{eff}} = 1(1 - \rho)$$

$$\rho = (K_{\text{eff}} - 1)/K_{\text{eff}}$$

$$\text{SUR} = 26.06/\tau$$

$$\tau = \frac{\bar{\beta} - \rho}{\lambda_{\text{eff}}\rho}$$

$$\rho = \frac{\ell \cdot}{\tau} + \frac{\bar{\beta}}{1 + \lambda_{\text{eff}}\tau}$$

$$\ell \cdot = 1 \times 10^{-4} \text{ seconds}$$

$$\lambda_{\text{eff}} = 0.1 \text{ seconds}^{-1}$$

$$\text{DRW} \propto \phi_{\text{tip}}^2 / \phi_{\text{avg}}^2$$

$$\text{Leakage} \propto \sqrt{\Delta P}$$

$$P = P_o 10^{\text{SUR}(t)}$$

$$P = P_o e^{(t/\tau)}$$

$$A = A_o e^{-\lambda \tau}$$

$$CR_{S/D} = S/(1 - K_{\text{eff}})$$

$$CR_1(1 - K_{\text{eff}1}) = CR_2(1 - K_{\text{eff}2})$$

$$1/M = CR_1/CR_X$$

$$A = \pi r^2$$

$$F = PA$$

$$\dot{m} = \rho A \bar{v}$$

$$\dot{W}_{\text{pump}} = \dot{m} \Delta P v$$

$$E = IR$$

$$\text{Eff.} = \text{Net Work Out/Energy In}$$

$$v(P_2 - P_1) + \frac{(\bar{v}_2^2 - \bar{v}_1^2)}{2g_c} + \frac{g(z_2 - z_1)}{g_c} = 0$$

$$g_c = 32.2 \text{ lbm-ft/lbf-sec}^2$$

---

### CONVERSIONS

$$1 \text{ Mw} = 3.41 \times 10^6 \text{ Btu/hr}$$

$$1 \text{ hp} = 2.54 \times 10^3 \text{ Btu/hr}$$

$$1 \text{ Btu} = 778 \text{ ft-lbf}$$

$$^{\circ}\text{C} = (5/9)(^{\circ}\text{F} - 32)$$

$$^{\circ}\text{F} = (9/5)(^{\circ}\text{C}) + 32$$

$$1 \text{ Curie} = 3.7 \times 10^{10} \text{ dps}$$


$$1 \text{ kg} = 2.21 \text{ lbm}$$

$$1 \text{ gal}_{\text{water}} = 8.35 \text{ lbm}$$

$$1 \text{ ft}^3_{\text{water}} = 7.48 \text{ gal}$$

CONDENSATE STORAGE TANK (T-24 A/B)

CONDENSATE STORAGE TANK



NUCLEAR POWER BUSINESS UNIT  
TANK LEVEL BOOK

TLB 34  
MINOR  
Revision 5  
January 15, 1998

CONDENSATE STORAGE TANK (T-24 A/B)

---

ID GRAVER M21-014 (L23944)(W-3827)  
T-24 A/B

1. Approximately 2,350 gal/ft
2. Reference Calculation - N97-155, PBNP-IC-42

NOTE 1: Volume discontinuity due to transmitter tap at approximately 1 foot height of tank.

NOTE 2: Technical Specification requirement is 13,000 gallons of useable water for one unit. This is represented as the lowest CST indicated level which maintains 13,000 gallons above the CST level where the AFW pump could trip on low suction pressure (including all uncertainties).

$$\begin{aligned}\text{CST Technical Specification Level} &= 13,000 \text{ gal} / 2350 \text{ gal/ft} + \text{CST trip level} \\ &= 5.532 \text{ ft} + 1.867 \text{ ft} = 7.399 \text{ ft}\end{aligned}$$

NOTE 3: Technical Specification requirement is 26,000 gallons of useable water for two units. This is represented as a CST indicated level which maintains 26,000 gallons above the CST level where the AFW pump could trip on low suction pressure (including all uncertainties).

$$\begin{aligned}\text{CST Technical Specification Level} &= 26,000 \text{ gal} / 2350 \text{ gal/ft} + \text{CST trip level} \\ &= 11.064 \text{ ft} + 1.867 \text{ ft} = 12.931 \text{ ft}\end{aligned}$$



POINT BEACH NUCLEAR PLANT  
SHUTDOWN EMERGENCY PROCEDURES


DEGRADED RHR SYSTEM CAPABILITY

UNIT 1



SEP-1 Unit 1  
MAJOR  
Revision 1  
September 23, 1994

Figure 1  
Page 1 of 1

"RHR System Elevations"



RHR PUMP, PIPING & INTERCONNECTIONS  
RELATIVE ELEVATIONS (APPROXIMATE)



HALON LOGIC CIRCUIT  
FIGURE 11.14.15