



1. PIPING SHOWN IN BLUE IN THE FOLLOWING LINE LISTINGS IS EXEMPT DUE TO NOT BEING CONSIDERED A PART OF D-A CATEGORY PER ENG. NOTE DATED 5/22/00: WG05, WG08, WG09, WG12, WG15, WG16, WG19, WG21, WG26, WG30.
2. PIPING SHOWN IN BLUE IN THE FOLLOWING LINE LISTINGS IS EXEMPT PER IWC-1222(a): WG11.
3. PIPING SHOWN IN BLUE IN THE FOLLOWING LINE LISTINGS IS EXEMPT PER IWD-1220(a)(1): NC17.

ISI CLASS 1 —
ISI CLASS 2 —
ISI CLASS 3 —
ISI EXEMPT —
NON-ISI —

ORIG	RELEASED FOR ISI USE ONLY
------	---------------------------

DESIGNER	TIM MYERS	DATE	11-7-00	INSP	WAIVED	DATE	---
DRAWN	TIM MYERS	DATE	11-7-00	INSP	WAIVED	DATE	---
CHECKED	GARY D. SCARBORO	DATE	11-7-00	APPR	R. KEVIN RHYNE	DATE	12-14-00
CH	SCALE	DWG. NO. MC-SIN-1567-02.01					REV 0

DUKE POWER COMPANY
MCGUIRE NUCLEAR STATION UNIT 1 AND 2
ASME SECTION XI
INSERVICE INSPECTION NDE BOUNDARY OF
WASTE GAS SYSTEM
(WG)

DESIGNER	TIM MYERS	DATE	11-7-00	INSP	WAIVED	DATE	—
DRAWN	TIM MYERS	DATE	11-7-00	INSP	WAIVED	DATE	—
CHECKED	GARY D SCARBORO	DATE	11-7-00	APPR	R. KEVIN RHYNE	DATE	12-14-00
SCALE	DWG. NO. MC-ISIN-1567-02.01						REV 0

REFERENCE FLOW DIAGRAM
MCFD-1567-02.01 REV. 1
ERN:MC0099X8