State of New Jersey

DONALD T. DIFRANCESCO
Acting Governor

Department of Environmental Protection
Division of Environmental Safety, Health, and Analytical Programs
Bureau of Nuclear Engineering
P.O.Box - 415
Trenton, NJ 08625-0415

Robert C. Shinn, Jr.
Commissioner

June 4, 2001

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
Amendment to Facility Operating License
License Change Request H00-06

The subject request was submitted to the NRC by PSE&G letter dated April 11, 2001. The request proposes to modify Technical Specification sections 3/4.6.3.4, and Bases 3/4.6.3 Primary Containment Isolation Valves. The purpose of this request is to increase the required testing interval from once every 18 months, to once every 120 months.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10CFR50.91 (b). The State of New Jersey has no comment.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

c: Distribution

J. Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

J. Shoppy
NRC Sr. Resident Inspector

R. Ennis
NRC Project Manager

G. Salamon
PSE&G