

June 13, 2001

CCN: P-6-01-05

Docket No. 50-346  
License No. NPF-3

Document Control Desk  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738


Ladies and Gentlemen:

Monthly Operating Report, May 2001  
Davis-Besse Nuclear Power Station Unit 1

Enclosed is a copy of the Monthly Operating Report for the Davis-Besse Nuclear Power Station for the month of May 2001.

If you have any questions, please contact Cheryl A. Kraemer at (419) 321-7153.

Very truly yours,

 for H. W. Bergendahl

Howard W. Bergendahl  
Plant Manager  
Davis-Besse Nuclear Power Station

CAK/ljk

Enclosure

cc: S. P. Sands  
NRC Project Manager

J. E. Dyer  
NRC Region III Administrator

K. S. Zellers  
NRC Senior Resident Inspector

IE24

## OPERATING DATA REPORT

<b>DOCKET NO.</b>	<u>50-0346</u>
<b>UNIT NAME</b>	<u>Davis-Besse Unit 1</u>
<b>DATE</b>	<u>June 4, 2001</u>
<b>COMPLETED BY</b>	<u>A. S. Quaderer</u>
<b>TELEPHONE</b>	<u>419-321-7384</u>
 <b>REPORTING PERIOD</b>	 <u>May, 2001</u>

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
<b>1 Design Electrical Rating (MWe-Net).</b> The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.		906	
<b>2 Maximum Dependable Capacity (MWe-Net).</b> The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.		882	
<b>3 Number of Hours the Reactor Was Critical.</b> The total number of hours during the gross hours of the reporting period that the reactor was critical.	744.0	3,623.0	141,389.7
<b>4 Number of Hours the Generator Was On Line.</b> (Also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	744.0	3,623.0	138,839.8
<b>5 Unit Reserve Shutdown Hours.</b> The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0.0	0.0	5,532.0
<b>6 Net Electrical Energy (MWH).</b> The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	658,726	3,217,517	113,715,286

# UNIT SHUTDOWNS

DOCKET NO. 50-346

UNIT NAME Davis-Besse #1

DATE June 4, 2001

COMPLETED BY A. S. Quaderer

TELEPHONE (419) 321-7384

REPORTING PERIOD: May, 2001

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
						No Unit Shutdowns

## SUMMARY:

The reactor remained at approximately 100% power for most of the month. Plant power was reduced on May 6, 2001 at 0004 hours from 100 percent power to approximately 95 percent power to conduct testing of the turbine control valves. Plant was returned to 100 percent power at 0240 hours on May 6, 2001. Plant power also was reduced on May 27, 2001 at 0001 hours, from 100 percent power to approximately 92 percent power to conduct testing of the turbine control valves. Power was returned to approximately 97 percent on May 28, 2001, at 1208 hours to conduct Control Rod Drive testing. At 2334 hours on May 28, 2001, a power increase commenced to 100 percent power which was attained at 0219 hours on May 29, 2001.

### (1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Exam
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

### (2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

Docket Number 50-346  
License Number NPF-3  
P-6-01-05  
Attachment 1  
Page 1 of 1

### COMMITMENT LIST

The following list identifies those actions committed to by Davis-Besse Nuclear Power Station in this document. Any other actions discussed in the submittal represent intended or planned actions by Davis-Besse. They are described only as information and are not regulatory commitments. Please notify the Manager - Regulatory Affairs (419-321-8450) at Davis-Besse of any questions regarding this document or any associated regulatory commitments.

Commitments

Due Date

None