



444 South 16th Street Mall  
Omaha NE 68102-2247

June 13, 2001  
LIC-01-0051

U. S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Reference: Docket No. 50-285

**SUBJECT: May 2001 Monthly Operating Report (MOR)**

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPDD) submits the attached MOR for May 2001.

If you have any questions, please contact me.

Sincerely,

S. K. Gambhir  
Division Manager  
Nuclear Operations

SKG/EPM/epm

**Attachments**

c: E. W. Merschoff, NRC Regional Administrator, Region IV  
A. B. Wang, NRC Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
INPO Records Center  
Winston & Strawn

JE24

**ATTACHMENT 1  
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>June 6, 2001</u>
COMPLETED BY	<u>E. P. Matzke</u>
TELEPHONE	<u>(402) 533-6855</u>

**REPORT PERIOD: May 2001**

- |                                |            |            |
|--------------------------------|------------|------------|
| 1. Design Electrical Rating    | (MWe-Net): | <u>478</u> |
| 2. Maximum Dependable Capacity | (MWe-Net): | <u>478</u> |

**OPERATING STATUS**

	<b>THIS MONTH</b>	<b>YR-TO-DATE</b>	<b>CUMULATIVE</b>
3. Number of Hours Reactor was Critical:	744	2,598	194,744
4. Number of Hours Generator was On-line:	744	2,565	192,732
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy Generated (MWh):	339,737	1,064,611	82,748,018

**ATTACHMENT 2  
UNIT SHUTDOWNS**

**REPORT MONTH May 2001**

DOCKET NO. 50-285  
UNIT NAME Fort Calhoun Station  
DATE June 6, 2001  
COMPLETED BY E. P. Matzke  
TELEPHONE (402) 533-6855

No.	Date (YY/MM/DD)	Type F: Forced S: Scheduled	Duration (Hours)	Reason <sup>1</sup>	Method of Shutting Down Reactor <sup>2</sup>	Cause & Corrective Action to Prevent Recurrence
none						

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

**OPERATIONS SUMMARY**

The Fort Calhoun Station (FCS) started the month operating at a reactor power of 30 percent following the refueling outage. The ascension to full power began on May 2, 2001, and was completed on May 6, 2001. On May 12, 2001, a 5 percent power reduction was completed in order to perform reactivity testing on May 13, 2001. The test was completed satisfactorily, and power was restored to 100 percent on May 14th. The plant remained at 100 percent power for the balance of the month.

**SAFETY VALVE OR PORV CHALLENGES/FAILURES**

No failures or challenges to safety valves or PORVs occurred during the month.