



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37384-2000

June 12, 2001

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT - MAY MONTHLY OPERATING REPORT

The enclosure provides the May Monthly Operating Report as required by Sequoyah Technical Specifications Section 6.9.1.10.

In accordance with NRC RIS 2001-05, only one paper copy of this document is being sent to the NRC Document Control Desk. If you have any questions concerning this matter, please call me at (423) 843-7170 or J. D. Smith at (423) 843-6672.

Sincerely,

A handwritten signature in black ink, appearing to read "Pedro Salas", written over a large, stylized, circular flourish.

Pedro Salas

Enclosure
cc: See page 2

JE24

U.S. Nuclear Regulatory Commission
Page 2
June 12, 2001

JDS:JWP:SJM

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5947

Ms. Barbara Lewis, Assistant Editor, Database
McGraw-Hill, Inc.
1200 G Street, NW, Suite 1100
Washington, D.C. 20005

(Via NRC Electronic Distribution)
Mr. R. W. Hernan, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37384-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

ENCLOSURE

TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT (SQN)

MONTHLY OPERATING REPORT

MAY 2001

UNIT 1

DOCKET NUMBER 50-327

LICENSE NUMBER DPR-77

UNIT 2

DOCKET NUMBER 50-328

LICENSE NUMBER DPR-79

OPERATIONAL SUMMARY

May 2001

I. SEQUOYAH OPERATIONAL SUMMARY

UNIT 1

Unit 1 generated 874,456 megawatthours (MWh) (gross) electrical power during May with a capacity factor of 101.2 percent. Unit 1 operated at 100 percent power throughout the month of May, with the exception of a short duration power reduction for scheduled inlet valve testing.

UNIT 2

Unit 2 generated 867,829 MWh (gross) electrical power during May with a capacity factor of 100.9 percent. Unit 2 operated at 100 percent power throughout the month of May with the exception of a scheduled power reduction to perform planned maintenance on the 2A Main Feedwater Pump on May 20, 2001.

II. CHALLENGES TO THE PRESSURIZER POWER-OPERATED RELIEF VALVES (PORVs) OR PRESSURIZER SAFETY VALVES

No PORVs or safety valves were challenged in May.

OPERATING DATA REPORT

Docket No. 50-327
 Unit Name SQN Unit 1
 Date June 5, 2001
 Completed By T. J. Hollomon
 Telephone (423) 843-7528

Reporting Period

1. Design Electrical Rating (Net MWe): 1148
2. Maximum Dependable Capacity (MWe-Net) 1122

	Month	Yr-to-Date	Cumulative
3. Number of Hours Reactor was Critical	744.0	3,623	112,316.7
4. Hours Generator On-Line	744.0	3,623.0	110,414.0
5. Unit Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh)	848,676	4,158,632	119,470,207

Docket No. 50-328
 Unit Name SQN Unit 2
 Date June 5, 2001
 Completed By T. J. Hollomon
 Telephone (423) 843-7528

Reporting Period

1. Design Electrical Rating (Net MWe): 1148
2. Maximum Dependable Capacity (MWe-Net): 1117

	Month	Yr-to-Date	Cumulative
3. Number of Hours Reactor was Critical	744.0	3,623.0	116,369
4. Hours Generator On-Line	744.0	3,623.0	114,317.1
5. Unit Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh)	843,025	4,136,373	121,378,562

UNIT SHUTDOWNS

DOCKET NO: 50-327
UNIT NAME: SQN-1
DATE: June 5, 2001
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

REPORT PERIOD: MAY 2001

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause and Corrective Action to Prevent Recurrence
						There were no outages or power reductions of greater than 20 percent in the average daily power level during May.

¹ Reason:

A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H- Other (Explain)

² Method

1-Manual
 2-Manual Trip/Scram
 3-Automatic Trip/Scram
 4-Continuation Outage
 5-Other (Explain)

UNIT SHUTDOWNS

DOCKET NO: 50-328
UNIT NAME: SQN-2
DATE: June 5, 2001
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

REPORT PERIOD: May 2001

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause and Corrective Action to Prevent Recurrence
2	010520	S		B		On May 20 at 0003 EDT, a power reduction was initiated to allow removal of the 2A main feedwater pump from service for scheduled maintenance. Reactor power was reduced to approximately 64 percent. Power increase was initiated on May 20 at 1357 EDT following completion of the maintenance activity.

¹ Reason:

A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H- Other (Explain)

² Method

1-Manual
 2-Manual Trip/Scram
 3-Automatic Trip/Scram
 4-Continuation Outage
 5-Other (Explain)