

REGISTRY OF RADIOACTIVE SEALED SOURCES AND DEVICES
SAFETY EVALUATION OF DEVICE

NO: NR-8122-D-801-E DATE: March 22, 2001 PAGE: 1 OF 2

DEVICE TYPE: Smoke Detector

MODEL: VA-2000 Series

DISTRIBUTOR: Ventek, Inc.
 (formerly Flash Alert)
 4137 White Oak Drive
 P.O. Box 43527
 Birmingham, AL 35243

MANUFACTURER: KBM Enterprises, Inc.
 15980 Chaney Thompson Road
 Huntsville, AL 35803

SEALED SOURCE MODEL DESIGNATION: Amersham Model AMM-1001H

<u>ISOTOPE:</u>	<u>ACTIVITY:</u>	<u>MAXIMUM</u>
Americium-241	(37 kBq)	1.0 microcurie

LEAK TEST FREQUENCY: Not required

PRINCIPAL USE: Detectors (P) Ion Generators, Smoke

REGISTRY OF RADIOACTIVE SEALED SOURCES AND DEVICES
SAFETY EVALUATION OF DEVICE

NO: NR-8122-D-801-E

DATE: March 22, 2001

PAGE: 2 OF 2

DEVICE TYPE: Smoke Detector

CUSTOM DEVICE:

 YES X NO

REGISTRY OF RADIOACTIVE SEALED SOURCES AND DEVICES
SAFETY EVALUATION OF DEVICE

NO: NR-8122-D-801-E DATE: March 22, 2001 PAGE: 3 OF 2

DEVICE TYPE: Smoke Detector

DESCRIPTION:

The VA-2000 Series is a combination audio/visual smoke detector for the hearing impaired. There are two models within the VA-2000 Series, the VA-2000P and VA-2000HW. The only difference between these models is that the VA-2000P is a portable unit which can plug into a common electrical outlet and the VA-2000HW is hardwired.

This registration certificate is inactivated because the distributor is out of business since October, 1995.

REFERENCES:

The following supporting documents for the VA-2000 Series smoke detector device are hereby incorporated by reference and are made a part of this registry document:

- Ventek's letters dated February 8, 1993, July 8, 1993, June 21, 1994, August 1, 1994, September 13, 1994, and September 21, 1994, with enclosures thereto.

ISSUING AGENCY:

U.S. Nuclear Regulatory Commission

Date: March 22, 2001 Reviewer: _____ */RA/*
Seung J. Lee

Date: March 22, 2001 Concurrence: _____ */RA/*
John P. Jankovich