

5.7 Procedures, Programs and Manuals

5.6.2.19 Reactor Coolant System (RCS) PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR) (continued)

- e. The reactor vessel pressure and temperature limits, including those for heatup and cooldown rates, shall be determined so that all applicable limits (e.g., heatup limits, cooldown limits, and inservice leak and hydrostatic testing limits) of the analysis are met.
- f. The PTLR, including revisions or supplements thereto, shall be provided upon issuance for each reactor vessel fluency period.

5.6.2.20 Containment Leakage Rate Testing Program

A program shall be established to implement the leakage rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak Test Program," dated September 1995, as modified by the following exception:

1. NEI 94-01-1995, Section 9.2.3: The first Type A test performed after the November 7, 1991 Type A test shall be performed no later than November 6, 2006.

The peak calculated containment internal pressure for the design basis loss of coolant accident, P_a , is 54.2 psig. The containment design pressure is 55 psig.

The maximum allowable primary containment leakage rate, L_a , at P_a , shall be 0.25% of primary containment air weight per day.

Leakage Rate acceptance criteria are:

1. Containment leakage rate acceptance criterion is $\leq 1.0 L_a$. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are $\leq 0.60 L_a$ for the Type B and Type C Tests and $\leq 0.75 L_a$ for Type A Tests.
2. Air lock testing acceptance criteria are:
 - a. Overall air lock leakage range is $\leq 0.05 L_a$ when tested at $\geq P_a$.
 - b. For each door, leakage rate is $\leq 0.01 L_a$ when tested at ≥ 8.0 psig.

The provisions of SR 3.0.2 do not apply to the test frequencies specified in the Containment Leakage Rate Testing Program.

The provisions of SR 3.0.3 are applicable to the Containment Leakage Rate Testing Program.