


Bryce L. Shriver
Vice President - Nuclear Site Operations

PPL Susquehanna, LLC
707 Salem Boulevard
P.O. Box 467
Berwick, PA 18603-0467
Tel. 570.542.3120 Fax 570.542.1504
bshriver@ppiweb.com




September 12, 2001

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
MONTHLY OPERATING REPORTS
Docket Nos. 50-387/NPF-14 and 50-388/NPF-22
PLA - 005367 FILE: R41-2A

The August 2001 Monthly Operating Reports for Susquehanna SES Units 1 and 2 are attached.

Very truly yours,




Bryce L. Shriver

LLF/cmm

cc: NRC Region 1
NRC Sr. Resident Inspector, Mr. S. Hansell
NRC Sr. Project Manager, Mr. R. G. Schaaf

IE24

OPERATING DATA REPORT



DOCKET NO.	50-387
UNIT	One
DATE	09-10-01
COMPLETED BY	L. L. Fuller
TELEPHONE	(570) 542-3858


OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U1)
2. Reporting Period: August 2001
3. Design Electrical Rating (Net MWe): 1100
4. Maximum Dependable Capacity (Net MWe): 1090

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>5,831</u>	<u>159,840</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>5,831.0</u>	<u>131,373.2</u>
7. Hours Generator On-Line	<u>744</u>	<u>5,809.4</u>	<u>129,250.9</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>798,652</u>	<u>6,263,959</u>	<u>132,077,908</u>

NOTES:

UNIT SHUTDOWNS



DOCKET NO. 50-387
 UNIT One
 DATE 9-10-01
 COMPLETED BY L. L. Fuller
 TELEPHONE (570) 542-3858

REPORT MONTH August 2001

No.	Date	Type ₁	Duration (Hours)	Reason ₂	Method of Shutting Down Reactor ₃	Cause & Corrective Action To Prevent Recurrence
						No shutdowns this month.

Summary: Unit 1 operated at 100% power for entire month of August.

1.
F. Forced
S. Scheduled

2.
Reason:
A – Equipment Failure (Explain)
B – Maintenance or Test
C – Refueling
D – Regulatory Restriction

E – Operator Training & Licensee Exam
F – Administrative
G – Operational Error (Explain)

3.
Method:
1 – Manual
2 – Manual Scram
3 – Automatic Scram
4 – Continuation from
previous month
5 – Other

SUSQUEHANNA STEAM ELECTRIC STATION


Docket Number: 50-387
Completed by: L. L. Fuller

Date: 9-10-01
Telephone: (570) 542-3858

Challenges to Main Steam Safety Relief Valves

None.

OPERATING DATA REPORT



DOCKET NO.	50-388
UNIT	Two
DATE	9-10-01
COMPLETED BY	L. L. Fuller
TELEPHONE	(570) 542-3858


OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U2)
2. Reporting Period: August 2001
3. Design Electrical Rating (Net MWe): 1117
4. Maximum Dependable Capacity (Net MWe): 1111

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>5831</u>	<u>145,080</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>4,811.4</u>	<u>124,728.0</u>
7. Hours Generator On-Line	<u>744</u>	<u>4,764.8</u>	<u>122,837.7</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>815,111</u>	<u>5,128,221</u>	<u>127,535,906</u>

NOTES:

UNIT SHUTDOWNS



DOCKET NO. 50-388
 UNIT Two
 DATE 9-10-01
 COMPLETED BY L. L. Fuller
 TELEPHONE (570) 542-3858

REPORT MONTH August 2001

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Cause & Corrective Action to Prevent Recurrence
						No Shutdowns this month.

Summary: Unit 2 reduced power to 76% on August 11 for Control Rod sequence exchange. The unit returned to 100% power on August 12.

1.

2.

3.

F. Forced
 S. Scheduled

Reason:

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction

E - Operator Training & Licensee Exam
 F - Administrative
 G - Operational Error (Explain)

Method:

1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation from
 previous month
 5 - Other

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-388
Completed by: L. L. Fuller

Date: 9-10-01
Telephone: (570) 542-3858

Challenges to Main Steam Safety Relief Valves

None.