

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2.1 A minimum of one pressurizer code safety valve shall be OPERABLE* with a lift setting of 2485 psig \pm 3%.**,***

APPLICABILITY: Mode 4 and 5

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE RHR loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

4.4.2.1 No additional Surveillance Requirements other than those required by Specification 4.0.5.

* While in Mode 5, an equivalent size vent pathway may be used provided that the vent pathway is not isolated or sealed.

** The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

*** Following testing the lift setting shall be reset to within \pm 1%.

3/4.4 REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.2.2 All pressurizer code safety valve shall be OPERABLE with a lift setting of 2485 psig \pm 3%.*,**

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes, or be in HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.2.2 No additional Surveillance Requirements other than those required by Specification 4.0.5

* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

** Following testing the lift setting shall be reset to within \pm 1%.

3/4.7 PLANT SYSTEMS

3/4.7.1 TURBINE CYCLE

SAFETY VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.1 All main steam line code safety valves (MSSVs) associated with each steam generator shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one or two main steam line code safety valves inoperable in one or more steam generators, operation in Modes 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or reduce power to less than or equal to the applicable percent of RATED THERMAL POWER per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With three main steam line code safety valves inoperable in one or more steam generators, operation in Modes 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valves are restored to OPERABLE status or reduce power to less than or equal to the applicable percent of RATED THERMAL POWER per Table 3.7-1 and within 36 hours, reduce the Power Range Neutron Flux High trip setpoint to less than or equal to the RATED THERMAL POWER per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

- 4.7.1.1 Verify each required MSSV lift setpoint per Table 4.7-1. No additional Surveillance Requirements other than those required by Specification 4.0.5.

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER
WITH INOPERABLE STEAM LINE SAFETY VALVES

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Power* (Percent of RATED THERMAL POWER)</u>
1	87
2	59
3	39

*The values do not provide any allowance for calorimetric error.

This Page Intentionally Blank

TABLE 4.7-1
STEAM LINE SAFETY VALVES PER LOOP

<u>VALVE NUMBER</u>					<u>LIFT SETTING ($\pm 3\%$) *</u>	<u>ORIFICE SIZE (sq. inches)</u>
	<u>Loop A</u>	<u>Loop B</u>	<u>Loop C</u>	<u>Loop D</u>		
a.	11MS11	12MS11	13MS11	14MS11	1125 psig	16.0
b.	11MS12	12MS12	13MS12	14MS12	1120 psig	16.0
c.	11MS13	12MS13	13MS13	14MS13	1110 psig	16.0
d.	11MS14	12MS14	13MS14	14MS14	1100 psig	16.0
e.	11MS15	12MS15	13MS15	14MS15	1070 psig	16.0

*Following testing the lift setting shall be reset to within $\pm 1\%$.

BASES

3/4.4.2 SAFETY VALVES

The pressurizer code safety valves operate to prevent the RCS from being pressurized above its Safety Limit of 2735 psig. Each safety valve is designed to relieve 420,000 pounds per hour of saturated steam at the valve setpoint. The relief capacity of a single safety valve is adequate to relieve any overpressure condition which could occur during shutdown. In the event that no safety valves are OPERABLE, an operating RHR loop, connected to the RCS, provides overpressure relief capability and will prevent RCS overpressurization. In addition, the Overpressure Protection System provides a diverse means of protection against RCS overpressurization at low temperature. While in Mode 5 the safety valve requirement may be met by establishing a vent path of equivalent relieving capacity when no code safety valves are OPERABLE.

During operation, all pressurizer code safety valves must be OPERABLE to prevent the RCS from being pressurized above its safety limit of 2735 psig. The combined relief capacity of all of these valves is greater than the maximum surge rate resulting from a complete loss of load assuming no reactor trip until the first Reactor Protective System trip setpoint is reached (i.e., no credit is taken for a direct reactor trip on the loss of load) and also assuming no operation of the power operated relief valves or steam dump valves.

Demonstration of the safety valves lift settings will occur only during shutdown and will be performed in accordance with the provisions of Section XI of the ASME Boiler and Pressure Code.

Surveillance testing allows a $\pm 3\%$ lift setpoint tolerance. However, to allow for drift during subsequent operation, the valves must be reset to within $\pm 1\%$ of the lift setpoint following testing.

3/4.4.3 RELIEF VALVES

The OPERABILITY of the PORVs and block valves is determined on the basis of their being capable of performing the following functions:

- A. Manual control of PORVs to control reactor coolant system pressure. This is a function that is used for the steam generator tube rupture accident and for plant shutdown.
- B. Automatic control of PORVs to control reactor coolant system pressure. This is a function that reduces challenges to the code safety valves for overpressurization events, including an inadvertent actuation of the Safety Injection System.
- C. Maintaining the integrity of the reactor coolant pressure boundary. This is a function that is related to controlling identified leakage and ensuring the ability to detect unidentified reactor coolant pressure boundary leakage.

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2 A minimum of one pressurizer code safety valve shall be OPERABLE* with a lift setting of 2485 psig \pm 3%.**,***

APPLICABILITY: Mode 4 and 5

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE RHR loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

4.4.2.1 No additional Surveillance Requirements other than those required by Specification 4.0.5.

* While in Mode 5, an equivalent size vent pathway may be used provided that the vent pathway is not isolated or sealed.

** The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

*** Following testing the lift setting shall be reset to within \pm 1%.

REACTOR COOLANT SYSTEM

3/4.4.3 SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.3 All pressurizer code safety valves shall be OPERABLE with a lift setting of 2485 psig \pm 3%.*,**

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.3 No additional Surveillance Requirements other than those required by Specification 4.0.5.

* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

** Following testing the lift setting shall be reset to \pm 1%.

3/4.7 PLANT SYSTEMS

3/4.7.1 TURBINE CYCLE

SAFETY VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.1 All main steam line code safety valves (MSSVs) associated with each steam generator shall be OPERABLE with lift settings as specified in Table 3.7-4.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one or two main steam line code safety valves inoperable in one or more steam generators, operation in Modes 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or reduce power to less than or equal to the applicable percent of RATED THERMAL POWER per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With three main steam line code safety valves inoperable in one or more steam generators, operation in Modes 1, 2 and 3 may proceed provided, that within 4 hours, either the inoperable valves are restored to OPERABLE status or reduce power to less than or equal to the applicable percent of RATED THERMAL POWER per Table 3.7-1 and within 36 hours, reduce the Power Range Neutron Flux High trip setpoint to less than or equal to the RATED THERMAL POWER per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

- 4.7.1.1 Verify each required MSSV lift setpoint per Table 3.7-4. No additional Surveillance Requirements other than those required by Specification 4.0.5.

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER WITH INOPERABLE
STEAM LINE SAFETY VALVES

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Power* (Percent of RATED THERMAL POWER)</u>
1	87
2	59
3	39

* The values do not provide any allowance for calorimetric error.

THIS PAGE INTENTIONALLY BLANK

TABLE 3.7-4

STEAM LINE SAFETY VALVES PER LOOP

<u>VALVE NUMBER</u>					<u>LIFT SETTING ($\pm 3\%$)*</u>	<u>ORIFICE SIZE</u> (sq. inches)
	<u>Loop A</u>	<u>Loop B</u>	<u>Loop C</u>	<u>Loop D</u>		
a.	21MS11	22MS11	23MS11	24MS11	1125 psig	16.0
b.	21MS12	22MS12	23MS12	24MS12	1120 psig	16.0
c.	21MS13	22MS13	23MS13	24MS13	1110 psig	16.0
d.	21MS14	22MS14	23MS14	24MS14	1100 psig	16.0
e.	21MS15	22MS15	23MS15	24MS15	1070 psig	16.0

* Following testing the lift setting shall be reset to within $\pm 1\%$.

3/4.4.2 and 3/4.4.3 SAFETY VALVES

The pressurizer code safety valves operate to prevent the RCS from being pressurized above its Safety Limit of 2735 psig. Each safety valve is designed to relieve 420,000 pounds per hour of saturated steam at the valve setpoint. The relief capacity of a single safety valve is adequate to relieve any overpressure condition which could occur during shutdown. In the event that no safety valves are OPERABLE, an operating RHR loop, connected to the RCS, provides overpressure relief capability and will prevent RCS overpressurization. In addition, the Overpressure Protection System provides a diverse means of protection against RCS overpressurization at low temperature. While in Mode 5 the safety valve requirement may be met by establishing a vent path of equivalent relieving capacity when no code safety valves are OPERABLE.

During operation, all pressurizer code safety valves must be OPERABLE to prevent the RCS from being pressurized above its safety limit of 2735 psig. The combined relief capacity of all of these valves is greater than the maximum surge rate resulting from a complete loss of load assuming no reactor trip until the first Reactor Protective System trip setpoint is reached (i.e., no credit is taken for a direct reactor trip on the loss of load) and also assuming no operation of the power operated relief valves or steam dump valves.

Demonstration of the safety valves lift settings will occur only during shutdown and will be performed in accordance with the provisions of Section XI of the ASME Boiler and Pressure Code.

Surveillance testing allows a $\pm 3\%$ lift setpoint tolerance. However, to allow for drift during subsequent operation, the valves must be reset to within $\pm 1\%$ of the lift setpoint following testing.

3/4.4.4 PRESSURIZER

The limit on the maximum water volume in the pressurizer assures that the parameter is maintained within the normal steady-state envelope of operation assumed in the SAR. The limit is consistent with the initial SAR assumptions.

The 12 hour periodic surveillance is sufficient to ensure that the parameter is restored to within its limit following expected transient operation. The maximum water volume also ensures that a steam bubble is formed and thus the RCS is not a hydraulically solid system. The requirement that a minimum number of pressurizer heaters be OPERABLE enhances the capability of the plant to control RCS pressure and establish natural circulation.

3/4.4.5 RELIEF VALVES

The OPERABILITY of the PORVs and block valves is determined on the basis of their being capable of performing the following functions:

- A. Manual control of PORVs to control reactor coolant system pressure. This is a function that is used for the steam generator tube rupture accident and for plant shutdown.

BASES

3/4.7.1 TURBINE CYCLE3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam line code safety valves ensures that the secondary system pressure will be limited to within 110% of its design pressure of 1085 psig during the most severe anticipated system operational transient. The MSSVs also provide protection against overpressurization of the Reactor Coolant Pressure Boundary by providing a heat sink for the removal of energy from the Reactor Coolant System if the preferred heat sink is not available. The maximum relieving capacity is associated with a turbine trip from 100% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink (i.e., no steam bypass to the condenser).

The specified valve lift settings and relieving capacities are in accordance with the requirements of Section III of the ASME Boiler and Pressure Code, 1971 Edition. The total relieving capacity for all valves on all of the steam lines is 16.66×10^6 lbs/hr which is 110.4% of the maximum calculated steam flow of 15.08×10^6 lbs/hr at 100% RATED THERMAL POWER. A minimum of 2 OPERABLE safety valves per OPERABLE steam generator ensures that sufficient relieving capacity is available for the allowable THERMAL POWER restriction in Table 3.7-2.

STARTUP and/or POWER OPERATION is allowable with inoperable safety valves within the limitations of the ACTION requirements on the basis of the reduction in secondary steam flow associated with the required reduction of RATED THERMAL POWER. The acceptable power level (in percent RATED THERMAL POWER) for operation with inoperable safety valves was determined by performing explicit transient analysis.

The events that challenge the relief capacity of the safety valves are those resulting in decreased heat removal capability. In this category of events, a loss of external electrical load and/or turbine trip is the limiting anticipated operational occurrence. A series of cases was analyzed for this transient covering up to two inoperable safety valves on each steam generator.

The results of these cases were used to determine a maximum thermal power level from which the event could be initiated without exceeding the primary and secondary side design pressure limits. Thus, the maximum allowed power level as a function of the number of inoperable MSSVs on any steam generator is presented in Table 3.7-1. Note that the power level values presented on this table are the direct inputs into the transient analysis cases and do not include any allowance for calorimetric error. Actual power level reductions must include calorimetric uncertainty and other allowances for operating margin as deemed necessary.

Specific accident analyses for RCCA Bank Withdrawal at Power scenarios demonstrate that adequate safety valve relief capacity exist with up to two inoperable safety relief valves on each steam generator. These cases demonstrate that the reactor trip on OTDT along with the relief from the available main steam safety valves is sufficient to meet secondary side pressurization limits.

BASES

For three inoperable main steam safety valves in one or more steam generators, thermal reactor power must be reduced in conjunction with a reduction in the Power Range Neutron Flux High trip setpoint to prevent overpressurization of the main steam system.

The transient analysis assumes that the MSSVs will start to open at the lift setpoint with 3% allowance for setpoint tolerance. In addition, the analysis accounts for accumulation by including a 5 psi ramp for the valve to reach its fully open position. Inoperable MSSVs are assumed to be those with the lowest lift setting. Surveillance testing as covered in Table 3.7-4 allows a $\pm 3\%$ lift setpoint tolerance. However, to allow for drift during subsequent operation, the valves must be reset to within $\pm 1\%$ of the lift setpoint following testing.

3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the auxiliary feedwater system ensures that the Reactor Coolant System can be cooled down to less than 350 F from normal operating conditions in the event of a total loss of offsite power.

Verifying that each Auxiliary Feedwater (AFW) pump's developed head at the flow test point is greater than or equal to the required minimum developed head ensures that the AFW pump performance has not degraded during the cycle, and that the assumption made in the accident analysis remain valid. Flow and differential head are normal tests of centrifugal pump performance required by Section XI of the ASME Code. Because it is undesirable to introduce cold AFW into the steam generators while operating, the test is performed on recirculation flow. This test confirms one point on the pump design curve (head vs flow curve), and is indicative of pump performance. Inservice testing confirms pump operability, trends performance and detects incipient failures by indication of pump performance.

The flow path to each steam generator is ensured by maintaining all manual maintenance valves locked open. A spool piece consisting of a length of pipe may be used as an equivalent to a locked open manual valve. The manual valves in the flow path are: 2AF1, 21AF3, 22AF3, 23AF3, 21AF10, 22AF10, 23AF10, 24AF10, 21AF20, 22AF20, 23AF20, 24AF20, 21AF22, 22AF22, 23AF22, 24AF22, 21AF86, 22AF86, 23AF86, and 24AF86.

3/4.7.1.3 AUXILIARY FEED STORAGE TANK

The OPERABILITY of the auxiliary feed storage tank with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 8 hours with steam discharge to the atmosphere concurrent with total loss of offsite power. The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.