



444 South 16th Street Mall
Omaha NE 68102-2247

September 13, 2001
LIC-01-0078

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, D.C. 20555

Reference: Docket No. 50-285

SUBJECT: August 2001 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for August 2001.

If you have any questions, please contact me.

Sincerely,

S. K. Gambhir
Division Manager
Nuclear Operations

SKG/EPM/epm

Attachments

- c: E. W. Merschoff, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
W. C. Walker, NRC Senior Resident Inspector
INPO Records Center
Winston & Strawn

**ATTACHMENT 1
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>September 4, 2001</u>
COMPLETED BY	<u>E. P. Matzke</u>
TELEPHONE	<u>(402) 533-6855</u>

REPORT PERIOD: August 2001

- | | | | |
|----|-----------------------------|------------|------------|
| 1. | Design Electrical Rating | (MWe-Net): | <u>478</u> |
| 2. | Maximum Dependable Capacity | (MWe-Net): | <u>478</u> |

OPERATING STATUS

	MONTH	YEAR TO DATE	CUMULATIVE
3. Number of Hours Reactor was Critical:	744	4,806	196,951
4. Number of Hours Generator was On-line:	744	4,773	194,939
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy Generated (MWh):	350,337	2,100,412	83,783,818

**ATTACHMENT 2
UNIT SHUTDOWNS**

REPORT MONTH August 2001

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE September 4, 2001
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

No.	Date (YY/MM/DD)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
none						

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station (FCS) was operated at a nominal 100% power throughout the month of August. On August 3, the lower seal on Reactor Coolant Pump (RCP) RC-3D failed. The other two seals on RCP RC-3D continue to operate as designed. Fuel reliability problems continue to be a challenge.

SAFETY VALVE OR PORV CHALLENGES/FAILURES

No failures or challenges to safety valves or PORVs occurred during the month.