



Salem Generating Station Unit 1

Inservice Inspection Program
Long Term Plan

Third Interval

Revision 0

July 2001

APPENDIX H

ISI Long Term Plan (Class 3)

PSE & G

ISI

PUBLIC SERVICE ELEC. & GAS

SALEM NUCLEAR GENERATING STATION UNIT 1

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
ALL STATUS CLASS III COMPONENTS

July 16, 2001
REVISION 0

Prepared By:

J. J. M. Y.

Date

July 16, 2001.

Peer Review:

John R. O'Neil

Date

7/20/01

ANIL Review:

John R. O'Neil

Date

07/30/01

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**
				1	2	3	4	1	2	3	4	1	2	3	4	
	AF1030 (REF. DWG. NO. AF-1-2B 01)															
500000	1AFG-173	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	P	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																
95RF - PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).																
500005	1AFH-174A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	HANGER	F1.30-L		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500010	1AFG-175	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500015	1AFG-211	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500020	1AFA-174-1A	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522450
	PIPE TO ANCHOR	D1.20		2	-	C	-	-	-	-	-	-	-	-	-	(1AFA-174).
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1035 (REF. DWG. NO. AF-1-2A 01)															
500025	1AFG-255	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1037 (REF. DWG. NO. AF-1-2B 01)															
500030	1AFG-171	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
	AF1039 (REF. DWG. NO. AF-1-2B 01)							O	U	T	A	G	E				
500035	1AFG-169	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	C	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).																	
500040	1AFG-212	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	C	-	-	-	-	-	-	-		
				3	-	-	-	X	-	-	-	-	-	-	-		
500045	1AFG-176	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	C	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
500050	1AFH-177A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	HANGER	F1.30-L		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
500055	1AFA-177-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522340		
	PIPE TO ANCHOR	D1.20		2	-	-	-	-	-	-	-	C	-	-	(1AFA-177).		
				3	-	-	-	-	-	-	-	-	-	-			
01RF - 01RF - W/O# 50009730 TO PERFORM NDE.																	
	AF1044 (REF. DWG. NO. AF-1-2B 01)																
500060	1AFS-167-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522350		
	PIPE TO SUPPORT	D1.20		2	-	-	-	C	-	-	-	-	-	-	(1AFS-167).		
				3	-	-	-	-	-	-	-	-	-	-			
	AF1046 (REF. DWG. NO. AF-1-2B 01)																
500065	1AFG-160-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522360		
	PIPE TO GUIDE	D1.20		2	-	-	-	-	-	-	-	-	-	-	(1AFG-160).		
				3	-	-	-	-	-	-	-	-	-	-			

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
500070	1AFS-161 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500075	1AFA-162-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522330 (1AFA-162).
				2	-	K	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
	AF1049 (REF. DWG. NO. AF-1-2B 01)																
500080	1AFS-163 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																	
	AF1050 (REF. DWG. NO. AF-1-2B 01)																
500085	1AFS-165 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																	
	AF1053 (REF. DWG. NO. AF-1-2B 01)																
500090	1AFA-188-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522370 (1AFA-188).
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).																	
500095	1AFG-184 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
500100	1AFG-192 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 4

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
500105	1AFG-197 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500110	1AFG-200 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
500115	1AFG-205 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																	
500120	1AFG-208 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																	
500125	1AFG-180 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500130	1AFG-178 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	
500135	1AFS-172-1A PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522380 (1AFS-172).
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE : 5

AUXILIARY FEEDWATER SYSTEM

[illegible]

REVISION: 0

[illegible]

AUXILIARY FEEDWATER SYSTEM

[illegible]

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
500355	1AFG-196 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500360	1AFG-193 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-
500365	1AFG-187 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500370	1AFA-182 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500375	1AFG-181 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500380	1AFS-170-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522390 (1AFS-170).
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
AF1063 (REF. DWG. NO. AF-1-3A 01)																
500385	13AFWH-047 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500390	13AFWA-046-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522260 (13AFWA-046).
				2	-	-	-	-	C	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

93 - PRESERVICE PER IEC-3226-01, W.O.# 930203123, CJP# PS-93-004.

REVISION: 0

PAGE : 9

INSPECTION INTERVAL_

PLAN STATUS

[illegible]

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				- - - - -				O U T A G E - - - - -				- - - - -				
				1	2	3	4	1	2	3	4	1	2	3	4	
AF1065 (REF. DWG. NO. AF-1-2B 01)																
500430	1AFG-190 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
AF1073 (REF. DWG. NO. AF-1-2A 01)																
500435	1AFG-260 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
AF1075 (REF. DWG. NO. AF-1-2B 01)																
500440	1AFA-166-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522400
				2	-	-	-	-	-	-	-	-	-	-	(1AFA-166).	
				3	-	-	-	-	-	-	-	-	-	-	-	
500445	1AFG-207 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500450	1AFG-206 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
500455	1AFG-199 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
500460	1AFG-198 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

AUXILIARY FEEDWATER SYSTEM

[illegible]

REVISION: 0

PAGE: 12

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
500505	12AFWH-036 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500510	12AFWH-035 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500515	12AFWA-034 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500520	12AFWS-033 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-	-
.....																	
500525	12AFWG-032 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500530	12AFWA-031 ANCHOR	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500535	12AFWH-030 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-	-
.....																	
500560	12AFWS-025 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**	
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
500565	12AFWS-024 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500590	12AFWS-018 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500595	12AFWS-017 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500620	12AFWS-012 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500625	12AFWS-001 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500630	12AFWG-002 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE PER 1EC-3226-01, W.O.# 930203123, CJP# PS-93-004.																
500635	12AFWG-003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500640	12AFWG-004 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 14

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
								O U T A G E								
				1	2	3	4	1	2	3	4	1	2	3	4	
500645	12AFWG-042 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500650	12AFWG-005 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500655	12AFWS-006 SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-M		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500680	12AFWA-011 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-M		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500685	1AFG-210 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500690	1AFG-203 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	C	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500695	1AFG-202 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	C	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
500700	1AFG-195 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-

REVISION: 0

PAGE: 15

INSPECTION INTERVAL_

PLAN STATUS

[illegible]

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
500745	11AFWA-044-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522310 (11AFWA-044).
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
500750	11AFWG-045 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
500755	11AFWA-046-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522320 (11AFWA-046).
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
500760	11AFWG-047 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).																		
500765	11AFWG-048 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
500770	11AFWS-050 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 - PRESERVICE PER 1EC-3226-01, W.O.# 930203123, CJP# PS-93-004.																		
500775	11AFWG-049 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
500780	11AFWG-049A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI															
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
500785	11AFWG-050A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - PRESERVICE PER IEC-3226-01, W.O.# 930203123, CJP# PS-93-004.																	
500790	11AFWG-043	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1097 (REF. DWG. NO. AF-1-2B 01)																	
500795	1AFG-253A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500800	1AFG-252A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1098 (REF. DWG. NO. AF-1-2A 01)																	
500805	1AFG-149	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
500810	1AFG-151	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1099 (REF. DWG. NO. AF-1-2A 01)																	
500815	1AFG-119	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

[illegible]

REVISION: 0

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI															
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
500900	1AFH-145 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500905	1AFG-147 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
500910	1AFA-148-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522440
				2	-	-	-	-	-	P	-	-	-	-	-	-	(1AFA-148).
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
95RF - PSI BASELINE PERFORMED PER IEC-3396-4 / PS-95-070 / 951114131 (MODIFIED).																	
.....																	
AF1115 (REF. DWG. NO. AF-1-2A 01)																	
500965	1AFH-257 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
500970	1AFG-256 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
AF1116 (REF. DWG. NO. AF-1-2A 01)																	
500975	1AFH-259 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
500980	1AFG-258 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**
				1	2	3	4	1	2	3	4	1	2	3	4	
AF1120 (REF. DWG. NO. AF-1-2A 01)																
500985	1AFA-215-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522230 (1AFA-215).
				2	C	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
500990	1AFG-219 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
500995	1AFH-220 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
501000	1AFG-224 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
501005	1AFG-214 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
AF1125 (REF. DWG. NO. AF-1-2A 01)																
501010	1AFG-223 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
AF1131 (REF. DWG. NO. AF-1-2A 01)																
501015	1AFA-216-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522240 (1AFA-216).
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 22

INSPECTION INTERVAL_____

PLAN STATUS

[illegible]

AUXILIARY FEEDWATER SYSTEM

[illegible]

DATE: 07/16/2001
REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 24

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY ITEM NO						O U T A G E								
				1	2	3	4	1	2	3	4	1	2	3	4	
501160	1AFH-289	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	HANGER	F1.30-L		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	
AF1172 (REF. DWG. NO. AF-1-2B 01)																
501165	1AFS-229	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	SUPPORT	F1.30-M		2	-	-	-	-	-	-	-	-	C	-	-	-
				3	-	-	-	-	-	-	-	X	-	-	-	

01RF - 01RF - W/O# 50009730 TO PERFORM NDE.

REVISION: 0

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

PAGE: 26

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

PAGE: 27

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				-				O U T A G E				-						
				1	2	3	4	1	2	3	4	1	2	3	4			
501245	1A-CCH-022-1A PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520130 (1A-CCH-022).

CC1010 (REF. DWG. NO. CC-1-2A 02)																		
501260	1A-CCH-049 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

501270	1A-CCS-051 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

501275	1A-CCH-054 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																		

501280	1A-CCS-057 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	

CC1010 (REF. DWG. NO. CC-1-1A 01)																		
501285	1A-CCG-055 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

501290	1A-CCA-015-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520140 (1A-CCA-015).
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

501295	1A-CCG-014 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
501300	1A-CCG-013 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	P	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
01RF - NDE PSI TO BE DONE UNDER W/O# 60015970 & CJP# PS-01-002.																			
501305	1A-CCA-012-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
REF. SUM# 520070 (1P-CCA-012).																			
501310	1A-CCS-011 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	C	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																			
501315	1A-CCH-010 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	C	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																			
501320	1A-CCS-009 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
501325	1A-CCA-003B-IA PIPE TO ANCHOR PAD	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
REF. SUM# 522480 (1A-CCA-003B). REF. DWG. 207491, PAD DETAIL C.																			
501330	1A-CCH-008-IA PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
REF. SUM# 511230 (1A-CCH-008).																			

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

[illegible]

REVISION: 0

PAGE: 30

INSPECTION INTERVAL

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	CC1047 (REF. DWG. NO. CC-1-2A 02)															
501375	1A-CCS-040-1A TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520310 (1A-CCS-040).	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	CC1051 (REF. DWG. NO. CC-1-2A 02)															
501385	1A-CCG-041-1A PIPE TO GUIDE	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520030. (1A-CCG-041). REF. DWG. 26130.	
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	X	-	-	-	-	-		
	CC1051 (REF. DWG. NO. CC-1-2A 2A)															
501395	1A-CCH-042 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	CC1051 (REF. DWG. NO. CC-1-2A 2A)															
501400	1A-CCG-413 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	CC1051 (REF. DWG. NO. CC-1-2A 2A)															
501405	1A-CCG-412A GUIDE	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	C	-	-	-	H	-		
				3	-	-	-	-	X	-	-	-	-	-		
01RF -	NDE TO BE PERFORMED UNDER W/O# 50009730.															
93 -	RESCHEDULED TO SIRFO#13 (NEXT PERIOD).															
	CC1051 (REF. DWG. NO. CC-1-2A 2A)															
501410	1A-CCH-412 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	C	-	-	-	H	-		
				3	-	-	-	-	-	-	-	-	-	-		
01RF -	NDE TO BE PERFORMED UNDER W/O# 50009730.															
93 -	RESCHEDULED TO SIRFO#13, (NEXT PERIOD).															

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI															
		CATEGORY ITEM NO															
				1	2	3	4	1	2	3	4	1	2	3	4		
CC1051 (REF. DWG. NO. CC-1-2A 02)																	
501415	1A-CCG-419 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
		F1.30-N		2	-	C	-	-	-	-	-	-	-	-			
				3	-	X	-	-	-	-	-	-	-	-			
.....																	
501420	1A-CCH-043 HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
		F1.30-L		2	C	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
.....																	
501430	1A-CCH-082 HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
		F1.30-L		2	-	-	-	-	P	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
.....																	
93 -	PRESERVICE PER 1EC-3255-1, CJP# PS-93-50 & W.O.# 930610082.																
.....																	
501435	1A-CCA-066-1A TRUNNION	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520320	
		D1.20		2	-	-	-	-	-	-	-	-	-	(1A-CCA-066).			
				3	-	-	-	-	-	-	-	-	-	-			
.....																	
501445	1A-CCS-064 SUPPORT	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
		F1.30-M		2	-	C	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
.....																	
501450	1A-CCG-063 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
		F1.30-N		2	-	-	-	-	C	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
.....																	
501455	1A-CCA-062-1A PIPE TO ATTACHMENT	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	6'6"W OF HH,9'4"S OF	
		D1.20		2	-	-	-	-	D	-	-	-	-	-	13.2 ANCHOR ABANDONED		
				3	-	-	-	-	-	-	-	-	-	-	PER 1EC-1076, M299/0		
																WELDED ATTACHMENT	
																REMAINS.	

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
501460	1A-CCG-061 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
501465	1A-CCH-060 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1091 (REF. DWG. NO. CC-1-2A 02)															
501475	1A-CCH-121 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
501480	1A-CCG-123 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
501485	1A-CCA-124-1A TRUNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520330
				2	-	C	-	-	-	-	-	-	-	-	-	(1A-CCA-124).
				3	-	-	-	-	-	-	-	-	-	-	-	
501490	1A-CCH-125 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
501500	1P-CCA-321-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520040 (
				2	-	-	-	-	-	-	-	-	C	-	-	1P-CCA-321).
				3	-	-	-	-	-	-	-	-	-	-	-	

01RF - W/O# 50009730 TO PERFORM NDE.

DATE: 07/16/2001
 REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
 INSERVICE INSPECTION PROGRAM LONG TERM PLAN
 CLASS 3 ALL STATUS COMPONENTS

PAGE: 33

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST				SECOND				THIRD				
		SEC. XI		PERIOD				PERIOD				PERIOD				
		CATEGORY		1	2	3	4	1	2	3	4	1	2	3	4	
ITEM NO	METH	1	2	3	4	1	2	3	4	1	2	3	4			
CC1091 (REF. DWG. NO. CC-1-3A 02)																
501505	1P-CCG-324 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	C	-	-	-	-	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
501510	1P-CCG-326 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	C	-	-	-	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
501515	1P-CCG-322 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
CC1092 (REF. DWG. NO. CC-1-2A 02)																
501520	1A-CCH-067 HANGER	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-L		2	C	-	-	-	-	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
CC1092 (REF. DWG. NO. CC-1-1A 01)																
501525	1A-CCG-068 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
501530	1A-CCA-007-1A PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520150 (1A-CCA-007).
		D1.20		2	-	-	-	-	-	-	-	-	-	-	-	
		3		-	-	-	-	-	-	-	-	-	-	-	-	
.....																
501535	1A-CCG-006 GUIDE	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
		F1.30-N		2	-	-	-	-	-	-	-	-	C	-	-	
		3		-	-	-	-	-	-	-	-	X	-	-	-	

01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 34

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
501540	1A-CCA-005-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520080 (1A-CCA-005) .
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
501545	1A-CCG-004 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
501550	1A-CCA-003C-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520160 (1A-CCA-003C) .
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
501555	1A-CCH-001-IA PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520170 (1A-CCH-001) .
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
501560	1A-CCG-002-IA PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520180 (1A-CCG-002) .
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
	CC1123 (REF. DWG. NO. CC-1-1A 01)																
501565	1A-CCG-078 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
501570	1A-CCA-021-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520190 (1A-CCA-021) .
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
501575	1A-CCG-020 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE : 35

INSPECTION INTERVAL_____

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
501580	1A-CCA-019-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520430 (1A-CCA-019).
501585	1A-CCG-018 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
501590	1A-CCA-023C-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520200 (1A-CCA-023C).
501595	1A-CCH-016-1A PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520210 (1A-CCH-016).
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																
93 - RESCHEDULED TO S1RFO#13 (NEXT PERIOD).																
501600	1A-CCG-017-1A PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520220 (1A-CCG-017).
501605	CC1160 (REF. DWG. NO. CC-1-2A 02) 1A-CCG-090 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
501610	1A-CCG-089 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
501615	1A-CCA-088-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520340 (1A-CCA-088).

REVISION: 0

PAGE : 36

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
								O U T A G E										
				1	2	3	4	1	2	3	4	1	2	3	4			
501620	1A-CCG-087 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501625	1A-CCG-086 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501630	1A-CCA-084-1A TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520350 (1A-CCA-084) .
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501635	1A-CCH-083 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501640	1A-CCH-085 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
	CC1161 (REF. DWG. NO. CC-1-2B 01)																	
501645	1A-CCS-091 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501650	1A-CCG-092 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
501655	1A-CCA-093-1A TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520360 (1A-CCA-093) .
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

[illegible]

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

REVISION: 0

PAGE: 40

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				-				O U T A G E				-					
				1	2	3	4	1	2	3	4	1	2	3	4		
501770	1A-CCS-504 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
501775	1A-CCG-505 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
CC1208 (REF. DWG. NO. CC-1-2B 01)																	
501780	1A-CCG-130 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
501785	1A-CCH-128 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
CC1229 (REF. DWG. NO. CC-1-2A 02)																	
501790	1P-CCA-320-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520050 (1P-CCA-320).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
501795	1A-CCS-120 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
501800	1A-CCH-119 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
.....																	
501805	1A-CCA-118 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520025 (1A-CCA-118). REF. DWG. 207489.
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 41

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

PAGE : 42

INSPECTION INTERVAL_____

PLAN STATUS

[illegible]

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

PAGE : 44

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

PAGE: 45

COMPONENT COOLING SYSTEM

[illegible]

DATE: 07/16/2001
 REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
 INSERVICE INSPECTION PROGRAM LONG TERM PLAN
 CLASS 3 ALL STATUS COMPONENTS

PAGE: 46

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
502000	1A-CCG-501 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
502005	1A-CCS-500 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
CC1424 (REF. DWG. NO. CC-1-2B 01)																	
502010	1A-CCG-129 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
502015	1A-CCH-127 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
CC1424 (REF. DWG. NO. CC-1-1D 01)																	
502020	1A-CCH-276 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
CC1479 (REF. DWG. NO. CC-1-2A 2A)																	
502025	1A-CCH-418 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
CC1480 (REF. DWG. NO. CC-1-2A 2A)																	
502030	1A-CCH-417 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		

92 - PSI BASELINE PERFORMED PER 1EC-3029 / P90-054 / 900906156 (VT, 05-23-92).

REVISION: 0

PAGE: 47

COMPONENT COOLING SYSTEM

[illegible]

REVISION: 0

CLASS 3 ALL STATUS COMPONENTS

CONTAINMENT SPRAY SYSTEM

[illegible]

PAGE : 50

CONTAINMENT SPRAY SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
502900	1A-CSG-153 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
.....																
502905	1A-CSG-173 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
.....																
95RF -	PSI BASELINE PERFORMED PER 1EC-3715-2 / PS-97-116 / 970815173 (HANGER MOD. PER ENGR'G RE-ANALYSIS).															
.....																
502910	1A-CSS-158 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	H	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-
.....																
93 -	W.O.#931121035 TO PERFORM NDE. RE-EXAM FROM 1RFO#10.															
.....																
502915	1A-CSG-157 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
.....																
502920	1A-CSA-156-1A PIPE SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	C	-	-	-
				3	-	-	-	-	-	-	-	-	X	-	-	-
.....																

01RF - 01RF - W/O# 50009730 TO PERFORM NDE.

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

MAIN STEAM SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	MS1018 (REF. DWG. NO. MS-1-4 01)															
504450	1A-MSALH-015	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-I		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
504455	1A-MSAH-125	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-I		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
504460	1P-MSAG-132	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
504465	1P-MSAG-131	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
504470	1A-MSAS-129-1A	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522200
	PIPE TO SUPPORT	D1.20		2	-	-	-	-	-	-	-	-	-	-	-	(1A-MSAS-129). REF. DWG.
				3	-	-	-	-	-	-	-	-	-	-	-	232475, SHT. 15.
504475	1A-MSAR-133	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	RESTRAINT	F1.30-E		2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
504480	1A-MSAH-127	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-E		2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
504485	1A-MSAH-128	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-I		2	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	

01RF - W/O# 50009730 TO PERFORM NDE.

REVISION: 0

MAIN STEAM SYSTEM

		INSPECTION INTERVAL				PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**			
				- - - - -				O U T A G E -				- - - - -							
				1	2	3	4	1	2	3	4	1	2	3	4				
504490	1A-MSAS-126-1A PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522210 (1A-MSAS-126). REF. DWG. 232475, SHT.14.		
504495	1A-MSAA-130-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522220 (1A-MSAA-130).		
				2	C	-	-	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-	-	-			

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL

PLAN STATUS[illegible]

PAGE : 54

SAFETY INJECTION SYSTEM

[illegible]

SAFETY INJECTION SYSTEM

[illegible]

REVISION: 0

PAGE: 57

SAFETY INJECTION SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**	
				1	2	3	4	1	2	3	4	1	2	3	4		
507765	1A-SIS-203-1A PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522030 (1A-SIS-203). REF. DWG. 231510, TRUNNION T-203.
SJ1009 (REF. DWG. NO. RH-1-2B 02)																	
507770	1A-SIG-163 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
SJ1010 (REF. DWG. NO. RH-1-2A 01)																	
507775	1A-SIS-162-1A PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 522000 (1A-SIS-162).
SJ1011 (REF. DWG. NO. RH-1-2A 01)																	
507780	1A-SIS-160 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
SJ1012 (REF. DWG. NO. RH-1-2A 01)																	
507785	1A-SIG-201 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
SJ1013 (REF. DWG. NO. RH-1-2A 01)																	
507790	1A-SIS-204-1A PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM#522040 (1A-SIS-204). REF. DWG. 231510, TRUNNION T-204.

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
		SEC. XI		-----				O U T A G E -----				-----				
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-15A)																
508200	1C-15SWA-5001 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520625 (1C-15SWA-5001-IA) .	
				2	P	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
508205	1C-15SWG-5002 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	P	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
508210	1C-15SWG-5003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	P	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																
508215	1C-15SWA-5007 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520635 (1C-15SWA-5007-IA) .	
				2	-	P	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-14A)																
508220	1C-14SWA-4001 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520645 (1C-14SWA-4001-IA) .	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
92RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-15B)																
508225	1C-15SWG-5008 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	P	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																
508230	1C-15SWG-5009 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	P	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 59

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI		-				-				-				
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-14A)																
508235	1C-14SWG-4002	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-15B)																
508240	1C-15SWG-5011	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-14A)																
508245	1C-14SWG-4003	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO.)																
508250	1C-15SWG-5010	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-12A)																
508255	1C-12SWA-2001	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520665
	ANCHOR	F1.30-A		2	P	-	-	-	-	-	-	-	-	-	-	(1C-12SWA-2001-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																
(REF. DWG. NO. SW-1-14B)																
508260	1C-14SWA-4007	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520675
	ANCHOR	F1.30-A		2	-	P	-	-	-	-	-	-	-	-	-	(1C-14SWA-4007-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																

REVISION: 0

PAGE: 60

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS															
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**			
		SEC. XI																	
		CATEGORY ITEM NO						O U T A G E											
				1	2	3	4	1	2	3	4	1	2	3	4				
	(REF. DWG. NO. SW-1-11A)																		
508265	1C-11SWA-1001	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520655			
	ANCHOR	F1.30-A		2	P	-	-	-	-	-	-	-	-	-	-	(1C-11SWA-1001-1A) .			
				3	-	-	-	-	-	-	-	-	-	-	-				
89RF - PSI BASELINE PERFORMED PER 1EC-2270.																			
	(REF. DWG. NO. SW-1-12A)																		
508270	1C-12SWG-2003	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-				
	GUIDE	F1.30-N		2	-	P	-	-	-	-	-	-	C	-	-				
				3	-	-	-	-	-	-	-	-	X	-	-				
01RF - W/O# 50009730 TO PERFORM NDE.																			
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																			
	(REF. DWG. NO. SW-1-14B)																		
508275	1C-14SWG-4008	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-				
	GUIDE	F1.30-N		2	-	P	-	-	-	-	-	-	-	-	-				
				3	-	-	-	-	-	-	-	-	-	-	-				
91RF - PSI BASELINE PERFORMED PER 1EC-2270.																			
508280	1C-14SWG-4009	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-				
	GUIDE	F1.30-N		2	-	-	-	P	-	-	-	-	-	-	-				
				3	-	-	-	-	-	-	-	-	-	-	-				
92RF - PSI BASELINE PERFORMED PER 1EC-2270.																			
	(REF. DWG. NO. SW-1-11A)																		
508285	1C-11SWG-1002	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-				
	GUIDE	F1.30-N		2	-	-	-	P	-	-	-	-	-	-	-				
				3	-	-	-	-	-	-	-	-	-	-	-				
92RF - PSI BASELINE PERFORMED PER 1EC-2270.																			
	(REF. DWG. NO. SW-1-12A)																		
508290	1C-12SWG-2004	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)			
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-				
				3	-	-	-	-	-	-	-	-	-	-	-				

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E - - - - -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
(REF. DWG. NO. SW-1-14B)																	
508295	1C-14SWG-4011 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-11A)																	
508300	1C-11SWG-1003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-14B)																	
508305	1C-14SWG-4010 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-12B)																	
508310	1C-12SWA-2008 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520685 (1C-12SWA-2008-IA). (PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-14B)																	
508315	1C-14SWS-4012 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520695 (1C-14SWS-4012-IA). (PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-11B)																	
508320	1C-11SWA-1007 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520705 (1C-11SWA-1007-IA). (PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-12B)																
508325	1C-12SWG-2009 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
508330	1C-12SWG-2010 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
508335	1C-12SWG-2012 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
(REF. DWG. NO. SW-1-11B)																
508340	1C-11SWG-1008 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
508345	1C-11SWG-1009 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
508350	1C-11SWG-1011 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																
(REF. DWG. NO. SW-1-12B)																
508355	1C-12SWG-2011 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-13A)																
508360	1C-13SWA-3001 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520715 (1C-13SWA-3001-IA) . (PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-11B)																
508365	1C-11SWG-1010 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-12B)																
508370	1C-12SWS-2013 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520725 (1C-12SWS-2013-IA) . (PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-13A)																
508375	1C-13SWG-3002 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-11B)																
508380	1C-11SWS-1012 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520735 (1C-11SWS-1012-IA) . (PSI, 1EC-2270, 2/1/1)

REVISION: 0

PAGE : 64

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				- - - - -				O U T A G E - - - - -				- - - - -				
				1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-13B)																
508385	1C-13SWA-3007 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520745 (1C-13SWA-3007-IA) . (PSI, 1EC-2270, 2/1/1)
508390	1C-13SWG-3008 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
508395	1C-13SWG-3009 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
508400	1C-13SWG-3011 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
508405	1C-13SWG-3010 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-2270, 2/1/1)
508410	1C-13SWS-3012 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 520755 (1C-13SWS-3012-IA) . (PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-13D)																
508430	1P-13SWG-011 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)

PAGE: 65

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
508435	1P-15SWG-012 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
(REF. DWG. NO. SW-1-1B 10)																	
508440	1P-15SWH-013 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)
				2	P	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
508445	1P-13SWG-016 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
(REF. DWG. NO. SW-1-1B 07)																	
508450	1P-13SWR-017 RESTRAINT	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053 (2/2/1))
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
(REF. DWG. NO. SW-1-9K 01)																	
508455	1P-14SWG-017 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)
				2	P	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
(REF. DWG. NO. SW-1-1B 07)																	
508460	1P-15SWG-017 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3053, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

PAGE: 66

SERVICE WATER SYSTEM

[illegible]

SERVICE WATER SYSTEM

[illegible]

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
508535	1A-SWG-102 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508540	1A-SWG-103 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508545	1A-SWG-104 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508550	1A-SWG-105 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508555	1A-SWS-2056 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - 01RF - W/O# 50009730 TO PERFORM NDE.																	
508560	1M-SWR-605 RESTRAINT	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508565	1M-SWR-611 RESTRAINT	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
508570	1M-SWG-612 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 69

INSPECTION INTERVAL

PLAN STATUS

[illegible]

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 70

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**
				1	2	3	4	1	2	3	4	1	2	3	4	
SW1000 (REF. DWG. NO. SW-1-7H 01)																
508710	1-SWPS-001	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521155
	SUPPORT	F1.30-M		2	P	-	-	-	-	-	-	-	-	-	-	(1-SWPS-001-IA). (PSI,
				3	-	-	-	-	-	-	-	-	-	-	-	1SC-2256, 2/1/1)
SW1001 (REF. DWG. NO. SW-1-7H 01)																
508715	1-SWPS-029-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	FOR THE ASSOCIATED IWF
	SUPPORT	D1.20		2	-	C	-	-	-	P	-	-	-	-	-	COMPONENT SEE SUM#
				3	-	-	-	-	-	-	-	-	-	-	-	511070. (1-SWPS-029).
95 - PSI BASELINE PERFORMED PER S-95-040 / 950215277 (REPAIR PERFORMED IN FORCED OUTAGE ON 2/95).																
SW1002 (REF. DWG. NO. SW-1-7H 01)																
508720	1-SWPS-002	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521165
	SUPPORT	F1.30-M		2	P	-	-	-	-	-	-	-	C	-	-	(1-SWPS-002-IA). (PSI,
				3	-	-	-	-	-	-	-	-	X	-	-	1SC-2256, 2/1/1)
01RF - 01RF - W/O# 50009730 TO PERFORM NDE.																
SW1003 (REF. DWG. NO. SW-1-7H 01)																
508725	1-SWPS-003	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521175
	SUPPORT	F1.30-M		2	P	-	-	-	-	-	-	-	-	-	-	(1-SWPS-003-IA). (PSI,
				3	-	-	-	-	-	-	-	-	-	-	-	1SC-2256, 2/1/1)
SW1004 (REF. DWG. NO. SW-1-7H 01)																
508730	1-SWPH-058-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 508731 FOR
	VARIABLE SPRING CAN	D1.20		2	-	-	-	-	-	P	-	-	C	-	-	IWF SUPPORT.
	HANGER			3	-	-	-	-	-	-	-	-	X	-	-	
01RF - 01RF - W/O# 50009730 TO PERFORM NDE.																
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

95RF - PSI BASELINE PERFORMED PER 1EC-3323 / PS-94-035 / 940811075 (GUIDE WAS REMOVED & REINSTALLED TO FACILITATE OTHER DCP WORK).

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	O U T A G E												INSTRUCTIONS **CALIBRATION BLOCK**	
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
SWI013 (REF. DWG. NO. SW-1-7B 03)																	
508750	1MSWH-032 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	P	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
91 - W.O.#901127015 TO PERFORM NDE.																	
92 - PSI IAW 1SC-2256-1 / P-91-091 / 910611126.																	
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																	
SWI016 (REF. DWG. NO. SW-1-7U 02)																	
508755	1MSWG-035-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520930
				2	-	-	-	-	P	-	-	-	-	-	-	-	(1MSWG-035). (PSI,
				3	-	-	-	-	-	-	-	-	-	-	-	-	4/28/92
																	(1SC-2256/P91-091/910611
																	126), 2/2/1.
SWI019 (REF. DWG. NO. SW-1-7U 02)																	
508760	1MSWG-037-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520940
				2	-	-	-	-	P	-	-	-	-	-	-	-	(1MSWG-037). (PSI,
				3	-	-	-	-	-	-	-	-	-	-	-	-	4/27/92
																	(1SC-2256/P91-091/910611
																	126), 2/2/1.
SWI019 (REF. DWG. NO. SW-1-7B 03)																	
508765	1MSWG-036A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	P	-	-	E	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE. 03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:																	
92 - PSI PER 1SC-2256-1 / P91-091 / 910611126.																	
95RF - 1) PSI BASELINE PERFORMED PER S-95-210 / 950809300 (REPLACED MISSING U-BOLT). 2) PSI BASELINE PERFORMED PER 1EE-0282-1 / PS-96-142 / 960523251 (MODIFIED).																	
508770	1MSWG-036 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	P	-	-	E	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:																	
92 - PSI PER 1SC-2226-1 / P91-091 / 910611126.																	
95RF - PSI BASELINE PERFORMED PER 1EE-0282-1 / PS-96-142 / 960523251 (MODIFIED).																	

SERVICE WATER SYSTEM

[illegible]

REVISION: 0

PAGE: 74

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
SW1067 (REF. DWG. NO. SW-1-7K 01)																
508805	1-SWPG-023-IA PIPE TO P-7 PAD.	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521180 (1-SWPG-023). REF. DWG. 212599, DET. P-7. & 217121, SHT 1.
				2	C	-	-	-	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).																
508815	1-SWPS-052-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521200 (1-SWPS-52).
				2	-	-	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).																
508820	1-SWPS-051-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521210 (1-SWPS-051). REF. DWG. 212599.
				2	-	-	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).																
SW1067 (REF. DWG. NO. SW-1-7H 01)																
508825	1-SWPS-009 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521225 (1-SWPS-009-IA).
				2	-	-	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-032 / 950913288 (MODIFIED).																
SW1068 (REF. DWG. NO. SW-1-7K 01)																
508835	1-SWPH-063-IA VARIABLE SPRING HANGER	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508836, FOR IWF SUPPORT.
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (REMOVE & REINSTALL ONLY).																
508836	1-SWPH-063 VARIABLE SPRING HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508835 FOR INTERGAL ATTACHMENT. VARIABLE SUPPORT UNIT - FIG. S-805, TYPE A, SIZE 16, MVT = 0", COLD LOAD = 6610#.
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (REMOVE & REINSTALL ONLY).																

CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
508840	1-SWPH-064-IA VARIABLE SPRING SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508841, FOR IWF SUPPORT.
92 -	PSI IAW 1SC-2256-2 / P-91-092 / 910611130.																
95 -	PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (REPLACEMENT).																
508841	1-SWPH-064 VARIABLE SPRING SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508840, FOR INTEGRAL ATTACHMENT. VARIABLE SUPPORT UNIT - FIG. S-805, TYPE A, SIZE 15, MVT. = 0", COLD LOAD = 5980#.
92 -	PSI PER 1SC-2256-2 / P91-092 / 910611130.																
95 -	PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (REPLACEMENT).																
SW1069 (REF. DWG. NO. SW-1-7K 01)																	
508845	1-SWPS-043-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521240 (1-SWPS-043). (PSI, 5/13/92 (1SC-2256/P91-092/910611 130), 2/2/1.
SW1070 (REF. DWG. NO. SW-1-7K 01)																	
508850	1-SWPS-044-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521250 (1-SWPS-044). (PSI, 5/21/92 (1SC-2256/P91-091/910611 130), 2/2/1.

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				- - - - -				O U T A G E - - - - -				- - - - -				
				1	2	3	4	1	2	3	4	1	2	3	4	
SW1071 (REF. DWG. NO. SW-1-7K 01)																
508855	1-SWPS-045-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521260 (
				2	-	C	-	-	P	-	-	-	-	-	1-SWPS-045). (PSI,	
				3	-	-	-	-	-	-	-	-	-	-	5/21/92	
																(1SC-2256/P91-092/910611
																130), 2/2/1.
SW1072 (REF. DWG. NO. SW-1-7K 01)																
508860	1-SWPS-053-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521270
				2	-	-	-	-	C	-	P	-	-	-	-	(1-SWPS-053).
				3	-	-	-	-	-	-	-	-	-	-	-	
95 -	PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).															
SW1083 (REF. DWG. NO. SW-1-7B 03)																
508865	1MSWH-030 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	P	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
92 -	PSI IAW 1SC-2256-1 / P-91-092 / 910611130.															
95 -	PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (REMOVE & REPLACE ONLY). AR# 951214066 WAS WRITTEN TO ADDRESS INCORRECT BOLTING, THINNING OF SUPPORT STEEL MEMBER, BOLT THREAD ENGAGEMENT & ROD ALIGNMENT PROBLEMS.															
508870	1MSWG-046 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/1/1)
				2	P	-	-	-	-	-	-	-	E	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
01RF -	W/O# 50009730 TO PERFORM NDE.03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:															
508875	1MSWG-047 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/1/2)
				2	-	P	-	-	-	-	-	-	E	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
01RF -	W/O# 50009730 TO PERFORM NDE.03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:															

SERVICE WATER SYSTEM

[illegible]

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1101 (REF. DWG. NO. SW-1-7V 02)															
508905	1MSWG-044-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520960 (1MSWG-044). (PSI, 1SC-2256, 2/1/2)	
				2	-	P	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	SW1101 (REF. DWG. NO. SW-1-7B 03)															
508910	1MSWG-043A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2256, 2/2/1)	
				2	-	-	-	-	P	-	-	-	E	-		
				3	-	-	-	-	-	-	-	-	-	-		
01RF -	W/O# 50009730 TO PERFORM NDE.03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:															
	SW1101 (REF. DWG. NO. SW-1-7V 02)															
508915	1MSWG-043 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 5/20/92 (1SC-2256/P91-092/910611 130), 2/2/1.	
				2	-	-	-	-	P	-	-	-	C	-		
				3	J	-	-	-	-	-	-	-	X	-		
01RF -	NDE TO BR PERFORMED UNDER W/O# 50009730. 03/08/01 VT-3 EXAM NOTED LOOSE NUT. MAINT TO DO REPAIRS UNDER NOTIFICATION# 20058850. 03/12/01 VT-3 PERFORMED AFTER REPAIRS AND WAS SATISFACTORY.															
	SW1136 (REF. DWG. NO. SW-1-7K 01)															
508920	1-SWPG-049A-IA PIPE TO L-I LUG	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521280 (1-SWPG-049). REF. DWGS. 219813 & 217121, SHT 1.	
				2	-	-	-	-	P	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS GUIDE WAS DISSASSEMBLED AND A NEW WELD WAS ADDED TO FACILITATE THE REMOVAL OF PIPE SPOOL RD-1-SW-75, UNDER CJP #S-92-332 AND W.O. #920512075.															
95RF -	PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).															
508925	1-SWPG-022-IA PIPE TO P-7 PAD	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521290 (1-SWPG-022). REF. DWGS. 212599 & 217121, SHT 1.	
				2	-	-	-	-	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
95RF -	PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-033 / 950913228 (MOD.).															

REVISION: 0

PAGE: 79

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
SW1136 (REF. DWG. NO. SW-1-7H 01)																	
508930	1-SWPS-005 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521305
				2	-	-	-	-	C	-	P	-	-	-	-	(1-SWPS-005-IA).	
				3	-	-	-	-	-	-	-	-	-	-	-		
93 - RESCHEDULED TO SIRFO#13 (NEXT PERIOD).																	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-032 / 950913288 (MODIFIED).																	
508935	1-SWPG-007 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521315
				2	-	-	-	-	-	P	-	-	-	-	-	(1-SWPG-007-IA). REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 212599.	
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-032 / 950913288 (MODIFIED).																	
SW1137 (REF. DWG. NO. SW-1-7H 01)																	
508955	1-SWPS-004 TRUNNION SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508956 FOR
				2	-	-	-	-	-	P	-	-	P	-	-	INTEGRAL ATTACHMENT.	
				3	-	-	-	-	-	-	-	-	-	-	-		
01RF - W/O# 50009730 TO PERFORM NDE.																	
05 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 951206286 (MODIFICATION).																	
508956	1-SWPS-004-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508955 FOR IWF
				2	-	-	-	-	-	P	-	-	-	-	-	SUPPORT.	
				3	-	-	-	-	-	-	-	-	-	-	-		
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 951206286 (MODIFICATION).																	
SW1149 (REF. DWG. NO. SW-1-7H 01)																	
508960	1-SWPS-008 TRUNNION SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508961 FOR
				2	-	-	-	-	-	P	-	-	-	-	-	INTEGRAL ATTACHMENT.	
				3	-	-	-	-	-	-	-	-	-	-	-		
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																	
508961	1-SWPS-008-IA TRUNNION SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508960 FOR IWF
				2	-	-	-	-	-	P	-	-	-	-	-	SUPPORT.	
				3	-	-	-	-	-	-	-	-	-	-	-		
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																	
508965	1-SWPS-010 TRUNNION SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508966 FOR
				2	-	-	-	-	-	P	-	-	-	-	-	INTERGAL ATTACHMENT.	
				3	-	-	-	-	-	-	-	-	-	-	-		
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																	

REVISION: 0

PAGE : 80

SERVICE WATER SYSTEM

		INSPECTION INTERVAL		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**	
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
508966	1-SWPS-010-IA TRUNNION SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508965 FOR IWF SUPPORT.
95 - PSI BASELINE PERFORMED PER 1EC-3323-1 / PS-94-035 / 940811075 (MODIFICATION).																	
SW1153 (REF. DWG. NO. SW-1-1B 02)																	
508975	1P-11SWS-001 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. DWG. 207486 & 207488 FOR LOCATION.
89 - W.O.#890407007 TO PERFORM NDE.																	
91 - PSI IAW 1SC-2257 / MD97.																	
92 - W.O.#921019031 TO PERFORM NDE.																	
95 - PSI BASELINE PERFORMED PER 1EC-3322-1 / PS-94-033 / 940811073 (MODIFICATION).																	
SW1153 (REF. DWG. NO. SW-1-1B 2)																	
508980	1P-11SWS-004 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. DWG. 207486 FOR LOCATION.
91 - PSI IAW 1SC-2257 / MD102																	
95 - 1) PSI BASELINE PERFORMED PER 1EC-3322-1 / PS-94-033 / 940811073 (MODIFICATION). 2) PSI BASELINE PERFORMED PER 1EC-3322-3 / PS-95-050 / 950914129 (MODIFICATION).																	
SW1169 (REF. DWG. NO. SW-1-3C 01)																	
508990	1A-SWG-364 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
508995	1A-SWA-354 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521045 (1A-SWA-354-IA) .
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1169 (REF. DWG. NO. SW-1-3B 01)																	
509000	1A-SWG-366 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	

PAGE: 81

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
509005	1A-SWG-367 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	X	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1176 (REF. DWG. NO. SW-1-3B 01)																
509010	1A-SWA-345 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509015	1A-SWG-344 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	P	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509020	1A-SWG-316 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	P	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1176 (REF. DWG. NO. SW-1-3C 01)																
509025	1A-SWA-315-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521050 (1A-SWA-315).
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1176 (REF. DWG. NO. SW-1-3B 01)																
509030	1A-SWH-314 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509035	1A-SWG-313 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																

REVISION: 0

PAGE: 82

SERVICE WATER SYSTEM

		INSPECTION INTERVAL		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**	
								O U T A G E									
				1	2	3	4	1	2	3	4	1	2	3	4		
509040	1A-SWG-324 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1176 (REF. DWG. NO. SW-1-3C 01)																
509045	1A-SWH-323 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF -	W/O# 50009730 TO PERFORM NDE.																
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509050	1A-SWA-WS08-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521000 (1A-SWA-WS08) .
				2	-	-	-	-	P	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	
01RF -	W/O# 50009730 TO PERFORM NDE.																
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1181 (REF. DWG. NO. SW-1-3C 01)																
509055	1A-SWG-378 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, CJP S90-300, 2/1/1)
				2	P	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509060	1A-SWA-358 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521065 (1A-SWA-358-1A) .
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1181 (REF. DWG. NO. SW-1-3B 01)																
509065	1A-SWG-377 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509070	1A-SWG-376 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
509080	1A-SWG-347 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509085	1A-SWG-346 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1185 (REF. DWG. NO. SW-1-3B 01)																	
509090	1A-SWS-369 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509095	1A-SWG-368 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1185 (REF. DWG. NO. SW-1-3C 01)																	
509100	1A-SWA-356 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521075 (1A-SWA-356-1A).
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509105	1A-SWG-370 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, CJP S90-298, 2/1/1)
				2	P	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1191 (REF. DWG. NO. SW-1-1B 12)																	
509110	1P-SWA-WS12-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521140 (1A-SWA-WS12).
				2	C	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - PRESERVICE PER 1EC-3150-1/PS-93-006/930615162.																	

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

[illegible]

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
509225	1C-13SWH-017 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/05/92 (1EC-3054/P91-060/910611 133), 2/2/1.
509230	1C-13SWS-018 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/03/92 (1EC-3054/P91-060/910611 133), 2/2/1.
509235	1C-13SWG-019 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/06/92 (1EC-3054/P91-060/910611 133), 2/2/1.
509270	1C-12SWH-1 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
509275	1C-11SWG-3B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
509285	1C-11SWG-5B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
509290	1C-12SWG-3A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
509295	1C-12SWG-4 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
509305	1C-11SWG-11A GUIDE	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
509310	1C-11SWG-6 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509390 (1C-11SWG-6-IA).
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
509315	1C-12SWG-7A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/2)
				2	-	P	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																	
509320	1C-12SWH-9 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
SW1220 (REF. DWG. NO. SW-1-5B 02)																	
509345	1C-12SWG-12 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
SW1238 (REF. DWG. NO. SW-1-1A 02)																	
509370	1C-11SWH-1 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	
509375	1C-11SWG-3A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY														
		ITEM NO	METH		1	2	3	4	1	2	3	4	1	2	3	4
509385	1C-11SWG-5A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.															
	SW1238 (REF. DWG. NO. SW-1-11D 0)															
509390	1C-11SWG-6-1A PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
	REF. SUM# 509310 (1C-11SWG-6). REF. DWG. 604229 (B,7-8)															
	SW1238 (REF. DWG. NO. SW-1-1A 02)															
509395	1C-11SWG-8A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
509400	1C-11SWG-9A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.															
509405	1C-11SWH-10 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
	SW1238 (REF. DWG. NO. SW-1-5A 02)															
509425	1C-11SWG-13 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															

SERVICE WATER SYSTEM

[illegible]

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
SW1280 (REF. DWG. NO. SW-1-2B 02)																
509470	1A-SWG-074	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3048, 2/1/2)
	GUIDE	F1.30-N		2	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
SW1280 (REF. DWG. NO. SW-1-2G 01)																
509475	1A-SWA-073	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	ANCHOR	F1.30-A		2	-	-	-	-	P	-	-	-	-	C	-	
				3	-	-	-	-	-	-	-	-	-	X	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																
92 - PSI PER 1EC-3048-1 / P91-078 / 911008145.																
SW1280 (REF. DWG. NO. SW-1-2B 02)																
509485	1A-SWH-075	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-I		2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
92 - PSI PER 1EC-3048-1 / P91-079 / 911008131.																
SW1296 (REF. DWG. NO. SW-1-9G 01)																
509490	1A-SWH-039	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3322-4 / PS-95-035 / 950914127 (MOD.).																
(REF. DWG. NO. SW-1-2B 01)																
509495	1A-SWA-WS04-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520870 (1A-SWA-WS04). REF. ARRANGEMENT DWG. 207484.
	PIPE TO ANCHOR	D1.20		2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3322-4 / PS-95-035 / 950914127 (MOD.).																
SW1343 (REF. DWG. NO. SW-1-7K 01)																
509500	1-SWPG-046-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509501 FOR IWF SUPPORT.
	PIPE TO P-7 PAD	D1.20		2	C	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (MODIFICATION).																

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
509501	1-SWPG-046 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509500 FOR INTERGAL ATTACHMENT.
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (MODIFICATION).																	
509505	1-SWPS-047-IA TRUNNION SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509506 FOR IWF SUPPORT.
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (MODIFICATION).																	
509506	1-SWPS-047 TRUNNION SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509505 FOR INTEGRAL ATTACHMENT.
95 - PSI BASELINE PERFORMED PER 1EC-3323-2 / PS-94-036 / 940811077 (MODIFICATION).																	
SW1346 (REF. DWG. NO. SW-1-1B 02)																	
509515	1P-12SWS-001 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 3/31/91 (1SC-2257, 2/1/2). VT PERFORMED 6/03/92 (92109031), 2/2/1.
95 - PSI BASELINE PERFORMED PER 1EC-3322-2 / PS-94-034 / 940811076 (MODIFICATION).																	
SW1365 (REF. DWG. NO. SW-1-3B 01)																	
509525	1A-SWG-343 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509530	1A-SWG-325 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE : 92

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI		-				-				-					
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
	SW1366 (REF. DWG. NO. SW-1-3B 01)																
509535	1A-SWG-326	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	-	-	-	C	P	-	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509540	1A-SWG-327	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	-	-	-	C	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509545	1A-SWG-304	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	-	-	-	-	P	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1366 (REF. DWG. NO. SW-1-3C 01)																
509550	1A-SWA-303A-1A	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521080
	PIPE TO ANCHOR	D1.20		2	C	-	-	-	-	P	-	-	-	-	-	-	(1A-SWA-303A) .
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
	SW1366 (REF. DWG. NO. SW-1-3B 01)																
509555	1A-SWG-303	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	C	-	-	-	P	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509560	1A-SWH-302	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	HANGER	F1.30-I		2	-	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509565	1A-SWG-301	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
509570	1A-SWG-300 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509575	1A-SWG-318 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509580	1A-SWH-317 HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1373 (REF. DWG. NO. SW-1-3B 01)																	
509590	1A-SWG-328 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
SW1380 (REF. DWG. NO. SW-1-1B 02)																	
509610	1P-12SWG-005 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2257, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																	
509615	1P-12SWG-003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED.
				2	-	P	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
91 - PSI PER 1SC-2257.																	
95RF - PSI BASELINE PERFORMED PER 1EC-3668-9 / PS-97-071 / 970318121 (MODIFICATION).																	
SW1384 (REF. DWG. NO. SW-1-14D 0)																	
509635	1C-14SWH-2 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																	

REVISION: 0

PAGE: 94

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
SW1384 (REF. DWG. NO. SW-1-1A 02)																	
509640	1C-13SWG-3D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/2)
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 - PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																	
509650	1C-13SWG-005D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/2)
				2	-	P	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
509655	1C-13SWG-006D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/2/1)
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
509660	1C-13SWH-007D HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/14/92 (1EC-3054/P91-060/910611 133), 2/2/1.
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
509665	1C-14SWH-005B HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
92 - PSI PER 1EC-3054-1 / P91-060 / 910611133.																	
509670	1C-13SWH-011D HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/14/92 (1EC-3054/P91-060/910611 133), 2/2/1.
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
509675	1C-13SWG-012D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
89 - W.O.#890407007 TO PERFORM NDE.																	
92 - PSI PER 1EC-3054-1 / P91-060 / 910611133.																	

DATE: 07/16/2001
REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 95

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
509680	1C-13SWG-013D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/14/92 (1EC-3054/P91-060/910611 133) 2/2/1.
509685	1C-14SWH-007 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 4/30/92 (1EC-3054/P91-060/910611 133), 2/2/1.
SW1384 (REF. DWG. NO. SW-1-5D 02)																
509690	1C-14SWG-008 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 4/30/92 (1EC-3054/P91-060/910611 133), 2/2/1.
SW1384 (REF. DWG. NO. SW-1-1A 02)																
509710	1C-14SWG-004 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/3)
SW1404 (REF. DWG. NO. SW-1-1A 02)																
509740	1C-15SWS-001 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
SW1404 (REF. DWG. NO. SW-1-5E 02)																
509745	1C-15SWG-003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/16/92 (1EC-3054/P91-060/910611 133), 2/2/1.

SERVICE WATER SYSTEM

[illegible]

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1496 (REF. DWG. NO. SW-1-2B 02)															
509800	1A-SWH-049 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
95RF -	PSI BASELINE PERFORMED PER 1EC-3322-4 / PS-95-035 / 950914127 (MOD.).															
	SW1496 (REF. DWG. NO. SW-1-9H 01)															
509805	1A-SWS-091 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029(2/2/1)	
				2	-	-	-	-	P	P	P	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORTS VERTICAL MEMBERS WERE REPLACED UNDER CJP #S-93-141 AND W.O. #920530148.															
95 -	PSI BASELINE PERFORMED PER 1EC-3322-4 / PS-95-035 / 950914127 (MOD.).															
	(REF. DWG. NO. SW-1-2B 01)															
509810	1A-SWA-WS03-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520880	
				2	-	-	-	-	-	P	-	-	-	-	(1A-SWA-WS03). REF.	
				3	-	-	-	-	-	-	-	-	-	-	ARRANGEMENT DWG. 207484.	
95RF -	PSI BASELINE PERFORMED PER 1EC-3322-4 / PS-95-035 / 950914127 (MOD.).															
	SW1498 (REF. DWG. NO. SW-1-3B 01)															
509815	1A-SWS-340 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1506 (REF. DWG. NO. SW-1-1B 02)															
509820	1P-11SWS-002 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF DWG. 207486 & 207488	
				2	-	P	-	-	-	P	-	-	-	-	FOR LOCATION.	
				3	-	-	-	-	-	-	-	-	-	-		
91 -	PSI IAW 1SC-2257 / MD101.															
95 -	1) PSI BASELINE PERFORMED PER 1EC-3322-1 / PS-94-033 / 940811073 (MODIFICATION). 2) PSI BASELINE PERFORMED PER 1EC-3668-8 / PS-97-070 / 970318111 (MODIFICATION).															

SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1507 (REF. DWG. NO. SW-1-1B 02)															
509830	1P-12SWS-002 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 2/12/91 (1SC-2257, 2/1/2). VT PERFORMED 6/3/92 (921019031), 2/2/1.
				2	-	P	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95 -	1) PSI BASELINE PERFORMED PER 1EC-3322-2 / PS-94034 / 940811076 (MODIFICATION). 2) PSI BASELINE PERFORMED PER 1EC-3668-9 / PS-97-071 / 970318121 (MODIFICATION).															
	SW1541 (REF. DWG. NO. SW-1-3B 01)															
509840	1A-SWG-349 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509845	1A-SWG-330 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509850	1A-SWS-350 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509855	1A-SWG-382 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1541 (REF. DWG. NO. SW-1-3D 01)															
509860	1A-SWA-357 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 521095 (1A-SWA-357-IA).
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															

REVISION: 0

PAGE: 99

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI		-				O U T A G E -				-				
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
SW1541 (REF. DWG. NO. SW-1-3B 01)																
509865	1A-SWG-385 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, CJP S90-301, 2/1/1)
				2	P	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
SW1542 (REF. DWG. NO. SW-1-3B 01)																
509870	1A-SWS-332 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509875	1A-SWG-312 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
SW1542 (REF. DWG. NO. SW-1-3D 01)																
509880	1A-SWA-311-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521100 (1A-SWA-311).
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
SW1542 (REF. DWG. NO. SW-1-3B 01)																
509885	1A-SWG-310 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																
509890	1A-SWG-309 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.																

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1545 (REF. DWG. NO. SW-1-3B 01)															
509895	1A-SWG-341	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509900	1A-SWG-342	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1546 (REF. DWG. NO. SW-1-3B 01)															
509910	1A-SWS-339	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509915	1A-SWG-375	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509920	1A-SWS-374	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1546 (REF. DWG. NO. SW-1-3D 01)															
509925	1A-SWA-355	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	ANCHOR	F1.30-A		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1546 (REF. DWG. NO. SW-1-3B 01)															
509930	1A-SWG-384	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	P	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															

REVISION: 0

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
		SEC. XI CATEGORY		ITEM NO	O U T A G E											
					1	2	3	4	1	2	3	4	1	2	3	
	SW1550 (REF. DWG. NO. SW-1-3D 01)															
509935	1A-SWA-353	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF SUM# 521125	
	ANCHOR	F1.30-A		2	-	-	-	-	P	-	-	-	-	-	(1A-SWA-353-1A).	
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1550 (REF. DWG. NO. SW-1-3B 01)															
509940	1A-SWG-359	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509945	1A-SWG-360	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509950	1A-SWG-361	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509955	1A-SWS-334	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509960	1A-SWG-333	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509965	1A-SWG-383	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, CJP S90-297,	
	GUIDE	F1.30-N		2	P	-	-	-	P	-	-	-	-	-	2/1/1)	
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
	(REF. DWG. NO. SW-1-3B 01)															
509966	1A-SWG-2433	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073. ANCHOR A1-SWA-383 WAS REPLACED WITH GUIDE A1-SWG-2433.															
	SW1551 (REF. DWG. NO. SW-1-3B 01)															
509970	1A-SWG-322	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509975	1A-SWH-321	F-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	
	HANGER	F1.30-L		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1556 (REF. DWG. NO. SW-1-3B 01)															
509985	1A-SWS-338	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509990	1A-SWS-336	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
509995	1A-SWS-335	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
510000	1A-SWG-337	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO	METH	-	-	-	-	O	U	T	A	G	E	-	-		
				1	2	3	4	1	2	3	4	1	2	3	4		
	SW1557 (REF. DWG. NO. SW-1-3B 01)																
510005	1A-SWG-308	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER IEC-3149/PS-93-030/930422073.																
	SW1557 (REF. DWG. NO. SW-1-3D 01)																
510010	1A-SWA-307A-1A	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521130	
	PIPE TO ANCHOR	D1.20		2	-	-	-	-	P	-	-	-	-	-	-	(1A-SWA-307A).	
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER IEC-3149/PS-93-030/930422073.																
	SW1557 (REF. DWG. NO. SW-1-3B 01)																
510015	1A-SWG-307	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	C	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER IEC-3149/PS-93-030/930422073.																
510020	1A-SWG-306	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	C	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER IEC-3149/PS-93-030/930422073.																
510025	1A-SWG-305	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	C	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER IEC-3149/PS-93-030/930422073.																
	SW1597 (REF. DWG. NO. SW-1-1A 02)																
510060	1C-15SWS-002	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 5/18/92	
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	(IEC-3054/P91-060/910611	
				3	-	-	-	-	-	-	-	-	-	-	-	133), 2/2/1.	

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1597 (REF. DWG. NO. SW-1-5E 02)															
510065	1C-15SWG-007 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/2/1)	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	SW1599 (REF. DWG. NO. SW-1-1B 02)															
510110	1P-15SWR-011 RESTRAINT	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2257, 2/2/1)	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	SW1619 (REF. DWG. NO. SW-1-1A 02)															
510135	1C-14SWH-1 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	C	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
510145	1C-13SWG-005B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/2/1)	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
510150	1C-13SWG-006B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 5/20/92	
				2	-	-	-	-	P	-	-	-	-	-	(1EC-3054/P91-060/910611	
				3	-	-	-	-	-	-	-	-	-	-	133), 2/2/1.	
510155	1C-13SWH-007B HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
510160	1C-14SWG-003 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E - - - - -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
510165	1C-14SWH-005A HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/1)
				2	P	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
510170	1C-13SWH-011B HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/2)
				2	-	P	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
510175	1C-13SWG-012B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/2/1)
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
510180	1C-13SWG-013B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI 5/14/92
				2	-	-	-	-	P	-	-	-	-	-	-	-	(1EC-3054/P91-060/910611
				3	-	-	-	-	-	-	-	-	-	-	-	-	133), 2/2/1.
.....																	
510185	1C-14SWH-006 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.																
.....																	
	SW1619 (REF. DWG. NO. SW-1-5D 02)																
510190	1C-14SWG-012 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 4/28/92
				2	-	-	-	-	P	-	-	-	-	-	-	-	(1EC-3054/P91-060/910611
				3	-	-	-	-	-	-	-	-	-	-	-	-	133), 2/2/1.
.....																	
	SW1619 (REF. DWG. NO. SW-1-1A 02)																
510225	1C-13SWG-3B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
95RF -	PSI BASELINE PERFORMED PER 1EC-3668-15 / PS-97-092 / 970318133 (COMPONENT SUPPORT MOD).																

CLASS 3 ALL STATUS COMPONENTS

[illegible]

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	(REF. DWG. NO. SW-1-13E 0)															
510285	1C-13SWG-009 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF SUM# 520785 (1C-13SWG-009-IA).	
				2	-	-	-	-	P	-	-	-	C	-		
				3	-	-	-	-	-	-	-	-	X	-		
01RF - W/O# 50009730 TO PERFORM NDE.																
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
	SW1640 (REF. DWG. NO. SW-1-1A 02)															
510290	1C-13SWH-011A HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 5/14/92 (1EC-3054/P91-060/910611 133), 2/2/1.	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
510295	1C-13SWG-012A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	C	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
89 -	W.O.#890407007 TO PERFORM NDE.															
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
510300	1C-13SWG-013A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	C	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
91 -	W.O.#901127015 TO PERFORM NDE.															
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
510305	1C-13SWH-014A HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 5/10/92 (1EC-3054/P91-060/910611 133), 2/2/1.	
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
510310	1C-13SWG-015A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
510315	1C-13SWS-016 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															

CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1640 (REF. DWG. NO. SW-1-5C 02)															
510320	1C-13SWG-023	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	C	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
91 -	W.O.#901127015 TO PERFORM NDE.															
92 -	PSI PER 1EC-3054-1 / P91-060 / 910611133.															
	(REF. DWG. NO. SW-1-1B 07)															
510365	1P-SWA-109-1A	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520890	
	PIPE TO ANCHOR	D1.20		2	-	-	C	-	-	-	-	-	-	-	(1P-SWA-109). REF. DWG.	
				3	-	-	-	-	-	-	-	-	-	-	602711, DET. 14.	
	(REF. DWG. NO. SW-1-1B 02)															
510375	1P-12SWG-006	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2257, 2/1/1)	
	GUIDE	F1.30-N		2	P	-	-	-	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
95RF -	PSI BASELINE PERFORMED PER 1EC-3668-9 / PS-97-071 / 970318121 (MODIFICATION).															
510380	1P-12SWG-004	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI. 1EC-3053, 2/1/1)	
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
	(REF. DWG. NO. SW-1-1B 06)															
510385	1P-11SWG-006	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 1SC-2257, 2/1/1).	
	GUIDE	F1.30-N		2	P	-	-	-	-	P	-	-	-	-	REF. DWG. 602711 &	
				3	-	-	-	-	-	-	-	-	-	-	231503, SHT. 3 FOR	
															LOCATION.	
95RF -	PSI BASELINE PERFORMED PER 1EC-3322-1 / PS-94-033 / 940811073 (TO FACILITATE PIPE REPACEMENT)															

PAGE: 109

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
(REF. DWG. NO. SW-1-1B 04)																	
510390	1P-SWA-WS10-1A PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520900 (1P-SWA-WS10). REF. DWG. 602712 (G,7) & 602711, DET 15.
				2	-	-	-	-	C	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
SW1664 (REF. DWG. NO. SW-1-1A 02)																	
510395	1C-12SWH-2 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
SW1664 (REF. DWG. NO. SW-1-12E 0)																	
510400	1C-11SWG-3D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	-	X	-	-		
01RF -	W/O# 50009730 TO PERFORM NDE.																
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
SW1664 (REF. DWG. NO. SW-1-1A 02)																	
510410	1C-11SWG-5D GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510415	1C-12SWG-3B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510420	1C-12SWG-5 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-		
				3	-	-	-	-	X	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
510430	1C-11SWG-11C GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
510433	1C-12SWG-6A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510435	1C-12SWG-5B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510440	1C-12SWG-7B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3054, 2/1/2)
				2	-	P	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510445	1C-12SWG-8 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.																
510450	1C-12SWG-10 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
510455	1C-12SWH-11 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																
SW1664 (REF. DWG. NO. SW-1-5B 02)																	
510485	1C-12SWG-16 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.																

SERVICE WATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1666 (REF. DWG. NO. SW-1-1B 1A)															
510515	1P-12SWR-030 RESTRAINT	F-A F1.30-G	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	P	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	X	-	-	-	-	-	-	-
	SW1684 (REF. DWG. NO. SW-1-5A 02)															
510520	1C-11SWG-17 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
	SW1684 (REF. DWG. NO. SW-1-1A 02)															
510555	1C-11SWH-2 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
510560	1C-11SWG-3C GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	C	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
510570	1C-11SWG-5C GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.															
510575	1C-11SWG-7 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	C	-	-	-	-	P	-	-	-	-	-	-
				3	X	-	-	-	-	-	-	-	-	-	-	-
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3054-2/PS-93-021/920115113.															
510580	1C-11SWG-8B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
93 -	PRESERVICE (NO MOD.) PER 1EC-3054-2/PS-93-021/920115113.															

PAGE: 112

SERVICE WATER SYSTEM

[illegible]

REVISION: 0

PAGE: 113

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
		SEC. XI		ITEM NO	METH													
		CATEGORY																
				1	2	3	4	1	2	3	4	1	2	3	4			
SW1897 (REF. DWG. NO. SW-1-9F 01)																		
510645	1A-SWG-066	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3048, 2/1/1)		
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-			
					3	-	-	-	-	-	-	-	-	-	-			

510650	1A-SWG-067	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3048, 2/1/1)		
	GUIDE	F1.30-N		2	P	-	-	-	-	-	-	-	-	-	-			
					3	-	-	-	-	-	-	-	-	-	-			

510655	1A-SWS-068	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED		
	SUPPORT	F1.30-M		2	-	-	-	-	-	-	-	-	-	-	-			
					3	-	-	-	-	-	-	-	-	-	-			

510665	SW1907 (REF. DWG. NO. SW-1-1B 1A)																	
	1P-13SWR-010	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	PSI-1EC-3054 (2/1/2)		
	RESTRAINT	F1.30-G		2	-	P	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-	-			

510680	SW1955 (REF. DWG. NO. SW-1-9J 01)																	
	1A-SWH-087	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 1EC-3029, 2/1/1)		
	HANGER	F1.30-I		2	P	-	-	-	-	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-	-			

510690	SW1957 (REF. DWG. NO. SW-1-9J 01)																	
	1A-SWG-090	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-			
	GUIDE	F1.30-N		2	-	P	-	-	P	-	-	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-	-			

91 -	PSI PER CJP S91-209.																	
92 -	PSI PER 1EC-3029-1 / P90-054 / 900906156.																	

SERVICE WATER SYSTEM

[illegible]

REVISION: 0

PAGE: 115

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				- - - - -				O U T A G E - - - - -				- - - - -				
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1974 (REF. DWG. NO. SW-1-7J 01)															
510745	1MSWG-606	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 4/92	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	(1SC-2256/P91-092/910611	
				3	-	-	-	-	-	-	-	-	-	-	130), 2/2/1.	
	SW1980 (REF. DWG. NO. SW-1-7J 01)															
510765	1MSWG-600	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 4/17/92	
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-	(1SC-2256/P91-091/910611	
				3	-	-	-	-	-	-	-	-	-	-	126), 2/2/1.	
	SW1986 (REF. DWG. NO. SW-1-3B 01)															
510785	1A-SWG-320	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	GUIDE	F1.30-N		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
510790	1A-SWH-319	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-		
	HANGER	F1.30-L		2	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3149/PS-93-030/930422073.															
	SW1589 (REF. DWG. NO. SW-1-1J)															
510800	1P-12SWS-10	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	(PSI, 12-14-92	
		F1.30-M		2	-	-	-	-	P	-	-	-	-	-	(1EC-3108-1, W.O.#	
				3	-	-	-	-	-	-	-	-	-	-	920818151), 2/2/1. NOTE:	
															THIS PORTION OF LINE	
															REMAINS IN PROGRAM.	
510805	1P-SWA-WS14	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF. SUM# 520995	
	ANCHOR	F1.30-A		2	-	-	-	-	P	-	-	-	-	-	(1P-SWA-WS14-1A). (PSI,	
				3	-	-	-	-	-	-	-	-	-	-	12-11-92 (1EC-3108-1,	
															W.O.# 920818151), 2/2/1.	
															NOTE: THIS PORTION OF	
															LINE REMAINS IN PROGRAM.	

REVISION: 0

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		ITEM NO	METH	-	-	-	-	O	U	T	A	G	E	-	-	
				1	2	3	4	1	2	3	4	1	2	3	4	
	SW1422 (REF. DWG. NO. SW-1-1J)															
510810	1P-12SWS-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	(PSI, 12-14-92
	SUPPORT	F1.30-M		2	-	-	-	-	P	-	-	-	-	-	-	(IEC-3108-1, W.O.#
				3	-	-	-	-	-	-	-	-	-	-	-	920818151), 2/2/1.
																NOTE: THIS PORTION OF
																LINE 6"-1SW1422 REMAINS
																IN PROGRAM.
510815	1P-SWA-102	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509765
	ANCHOR	F1.30-A		2	-	-	-	-	P	-	-	-	-	-	-	(1P-SWA-102-IA). (PSI,
				3	-	-	-	-	-	-	-	-	-	-	-	12-11-92 (IEC-3108-1,
																W.O.# 920818151), 2/2/1.

SERVICE WATER - NUCLEAR

[illegible]

REVISION: 0

PAGE: 118

[illegible]

REVISION: 0

PAGE : 119

INSPECTION INTERVAL_

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
		SEC. XI		O U T A G E												
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
	AF1000 (REF. DWG. NO. AF-1-2A 01)															
511040	1AFG-128	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	GUIDE	F1.30-N		2	-	-	-	-	-	P	-	-	D	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
95RF -	PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED). AR# 960112158 WRITTEN BY QA TO ADDRESS AS-BUILT DISCREPANCY.															
	AF1146 (REF. DWG. NO. AF-1-1A- 0)															
511050	1AFSA-24	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	ANCHOR	F1.30-A		2	-	-	-	-	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
95RF -	PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).															
	AF1147 (REF. DWG. NO. AF-1-1A 0)															
511060	1AFSA-23	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	ANCHOR	F1.30-A		2	-	-	-	-	-	P	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
95RF -	PSI BASELINE PERFORMED PER 1EC-3396-4 / PS-95-070 / 951114131 (MODIFIED).															

REVISION: 0

PAGE: 120

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
(REF. DWG. NO.)																	
511070	1-SWPS-029 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	FOR THE ASSOCIATED I-A SEE SUM# 508715 (1-SWPS-029-IA).
95RF - PSI BASELINE PERFORMED PER 1EC-3323-3 / PS-95-032 / 950913288 (MODIFIED).																	
511080	1A-SWG-047 U-BOLT GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3322-3 / PS-95-050 / 950914129 (MODIFICATION).																	

PAGE: 121

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
#11 SW ACCUMULATOR VESSEL PIPING (REF. DWG. NO.)																
511170	1Y-11SWG-3247	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3668-3 / PS-97-085 / 970318099 (S.W. ACCUMULATOR PIPING MOD.)																
#12 SW ACCUMULATOR VESSEL PIPING (REF. DWG. NO.)																
511175	1Y-12SWG-3248	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3668-3 / PS-97-085 / 970318099 (S.W. ACCUMULATOR PIPING MOD.)																
11 SERVICE WATER ACCUMULATOR TANK (REF. DWG. NO.)																
511180	11SW-ACCUM-VES-SUP	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511185, FOR
	SUPPORT	F1.40-K		2	-	-	-	-	-	P	-	-	-	-	-	THE ASSOCIATED IWD
				3	-	-	-	-	-	-	-	-	-	-	-	INTERGRAL ATTACHMENT.
97RF - 1) PSI BASELINE PERFORMED PER 1EC-3668-3 / PS-97-084 / 970318099 (ADDITION OF NEW VESSEL SUPPORT). 2) PSI BASELINE PERFORMED PER 1EC-3668-7 / PS-97-129 / 970318108 (WELDING ON STRUCT. STEEL)																
511185	11SW-ACCUM-VES-SUP-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511180, FOR
	INTEGRAL ATTACHMENT	D1.10		2	-	-	-	-	-	P	-	-	-	-	-	THE ASSOCIATED IWF
				3	-	-	-	-	-	-	-	-	-	-	-	COMPONENT SUPPORT.
97RF - PSI BASELINE PERFORMED PER 1EC-3668-3 / PS-97-084 / 970318099 (ADDITION OF NEW VESSEL SUPPORT).																
12 SERVICE WATER ACCUMULATOR TANK (REF. DWG. NO. 605388 01)																
511190	12SW-ACCUM-VES-SUP	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511195, FOR
	SUPPORT	F1.40-K		2	-	-	-	-	-	P	-	-	C	-	-	THE ASSOCIATED IWD
				3	-	-	-	-	-	-	-	-	X	-	-	INTERGRAL ATTACHMENT.
01RF - W/O# 50009730 TO PERFORM NDE.																
97RF - 1) PSI BASELINE PERFORMED PER 1EC-3668-3 / PS-97-084 / 970318099 (ADDITION OF NEW VESSEL SUPPORT). 2) PSI BASELINE PERFORMED PER 1EC-3668-7 / PS-97-129 / 970318108 (WELDING ON STRUCT. STEEL)																
511195	12SW-ACCUM-VES-SUP-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511190, FOR
	INTEGRAL ATTACHMENT	D1.10		2	-	-	-	-	-	P	-	-	C	-	-	THE ASSOCIATED IWF
				3	-	-	-	-	-	-	-	-	X	-	-	COMPONENT SUPPORT.

REVISION: 0

PAGE: 122

SERVICE WATER

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
#12 SW ACCUMULATOR VESSEL PIPING (REF. DWG. NO.)																	
511200	1P-12SWA-3256 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGERS).																	
511205	1P-12SWA-3256-IA ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511200 (1P-12SWA-3256).	
				2	-	-	-	-	-	P	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGERS).																	
511210	1P-12SWG-3258 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGERS).																	
511215	1P-12SWG-3260 STRUT	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-			
				3	-	-	-	-	-	-	-	-	-	-			
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGERS).																	

DATE: 07/16/2001

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 123

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY														
ITEM NO	METH															
O U T A G E																
1	2	3	4	1	2	3	4	1	2	3	4					
CC1010 (REF. DWG. NO. CC-1-1A 01)																
511230	1A-CCH-008	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501330
	VARIABLE SPRING	F1.30-I		2	-	-	-	C	-	P	-	-	-	-	-	(1A-CCH-008-1A) .
	SUPPORT			3	-	-	-	-	-	-	-	-	-	-	-	

95RF - PERFORM PSI BASELINE EXAM PER 1EO-2600-1 / 961011186 / PS-97-039 (REPLACE SPRING CAN ASSEMBLY WITH NEW BERGEN PATTERSON) .

SERVICE WATER

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
	#11 SW ACCUMULATOR VESSEL PIPING (REF. DWG. NO.)																
511240	1P-11SWA-3257 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511245 (IA).	
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511245	1P-11SWA-3257-IA ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511240 (IWF).	
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511250	1P-11SWS-3259 STRUT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511260	1P-11SWS-3261 GUIDE	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511270	1P-11SWS-3263 STRUT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511280	1P-11SWG-3265 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511290	1P-11SWG-3267 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	
511300	1P-11SWS-3269 GUIDE	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																	

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
511310	1P-11SWG-3271 STRUT	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																
511320	1P-11SWS-3233 STRUT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3688-4 / PS-97-090 / 970318103. (ADDITION OF NEW CFCU PIPE SUPPORTS).																
#12 SW ACCUMULATOR VESSEL PIPING (REF. DWG. NO.)																
511330	1P-12SWG-3262 STRUT	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																
511340	1P-12SWS-3264 STRUT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																
511350	1P-12SWG-3266 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																
511360	1P-12SWG-3268 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																
511370	1P-12SWS-3270 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																
511380	1P-12SWG-3272 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-2668-5 / PS-97-091 / 970318104 (NEW CFCU PIPING HGRS).																

REVISION: 0

PLAN STATUS[illegible]

DATE: 07/16/2001

SALEM NUCLEAR GENERATING STATION UNIT 1

PAGE: 127

REVISION: 0

INSERVICE INSPECTION PROGRAM LONG TERM PLAN

CLASS 3 ALL STATUS COMPONENTS

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY														
		ITEM NO														
				1	2	3	4	1	2	3	4	1	2	3	4	
511415	1AFE006	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 511410
	PUMP SUPPORT	F1.40-K		2	C	-	-	-	-	-	-	-	-	-	-	(1AFE006-IA). 2/1/1 EXAM
				3	X	-	-	-	-	-	-	-	-	-	-	COMPLETED UNDER W.O.#
																901120026-73

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
11 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511420	1CCE002-IA PUMP SUPPORT	D-A D1.30	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED, SEE SUM# 511430.
12 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511425	1CCE002 PUMP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED, SEE SUM# 511435.
12 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511430	1CCE003-IA PUMP SUPPORT	D-A D1.30	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	2/1/1 EXAM COMPLETED UNDER W.O.# 901120026-74
12 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511435	1CCE003 PUMP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	2/1/1 EXAM COMPLETED UNDER W.O.# 901120026-74
13 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511440	1CCE004-IA PUMP SUPPORT	D-A D1.30	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED, SEE SUM# 511430.
13 COMPONENT COOLING PUMP (REF. DWG. NO.)																	
511445	1CCE004 PUMP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED, SEE SUM# 511435.
COMPONENT COOLING SURGE TANK (REF. DWG. NO.)																	
511450	1CCE1-IA TANK SUPPORT	D-A D1.10	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	2/2/1 EXAM COMPLETED UNDER W.O.# 920430122.

REVISION: 0

COMPONENT COOLING

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
511455	1CCE1 TANK SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	2/2/1 EXAM COMPLETED UNDER W.O.# 920430122.
11 COMPONENT COOLING HEAT EXCHANGER (REF. DWG. NO.)																	
511460	1CCE5-1A HEAT EXCHANGER SUPPORT	D-A D1.10	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	2/2/1 EXAM COMPLETED UNDER W.O.# 920430124.
12 COMPONENT COOLING HEAT EXCHANGER (REF. DWG. NO.)																	
511465	1CCE5 HEAT EXCHANGER SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	2/2/1 EXAM COMPLETED UNDER W.O.# 920430124.
12 COMPONENT COOLING HEAT EXCHANGER (REF. DWG. NO.)																	
511470	1CCE6-1A HEAT EXCHANGER SUPPORT	D-A D1.10	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	2/1/1 EXAM COMPLETED UNDER W.O.# 901120026-75.
12 COMPONENT COOLING HEAT EXCHANGER (REF. DWG. NO.)																	
511475	1CCE6 HEAT EXCHANGER SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	2/1/1 EXAM COMPLETED UNDER W.O.# 901120026-75.

DATE: 07/16/2001
 REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
 INSERVICE INSPECTION PROGRAM LONG TERM PLAN
 CLASS 3 ALL STATUS COMPONENTS

PAGE: 130

CONTAINMENT SPRAY

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
CONTAINMENT SPRAY ADDITIVE TANK (REF. DWG. NO.)																
511480	1CSE005	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 510840
	TANK SUPPORT	D1.10		2	-	-	-	-	-	-	-	-	C	-	-	(CONTAINMENT SPRAY
				3	-	-	-	-	-	-	-	-	X	-	-	CHEMICAL ADDITIVE TANK)

01RF - W/O# 50009730 TO PERFORM NDE.

CHEMICAL AND VOLUME CONTROL

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4	
SEAL WATER HEAT EXCHANGER (REF. DWG. NO.)																
511490	1CVE010-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-
	HEAT EXCHANGER SUPPORT	D1.10		2	-	-	-	-	-	-	-	-	C	-	-	-
				3	-	-	-	-	-	-	-	-	X	-	-	-
01RF - W/O# 50009730 TO PERFORM NDE.																
511495	1CVE010	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	HEAT EXCHANGER SUPPORT	F1.40-K		2	-	-	-	-	-	-	-	-	C	-	-	-
				3	-	-	-	-	-	-	-	-	X	-	-	-
01RF - W/O# 50009730 TO PERFORM NDE.																
11 SEAL WATER INJECTION FILTER (REF. DWG. NO.)																
511500	1CVE018-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-
	FILTER SUPPORT	D1.10		2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	X	-	-	-
																AREA SHIELDED. 2/2/1
																EXAM COMPLETED UNDER
																W.O.# 920522140.
511505	1CVE018	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	FILTER SUPPORT	F1.40-K		2	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	X	-	-	-
																AREA SHIELDED. 2/2/1
																EXAM COMPLETED UNDER
																W.O.# 920522140.
12 SEAL WATER INJECTION FILTER (REF. DWG. NO.)																
511510	1CVE019-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-
	FILTER SUPPORT	D1.10		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
																AREA SHIELDED. NOT
																SELECTED, SEE SUM#
																511500.
511515	1CVE019	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-
	FILTER SUPPORT	F1.40-K		2	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-
																AREA SHIELDED. NOT
																SELECTED, SEE SUM#
																511505.

SERVICE WATER

[illegible]

INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

[illegible]

REVISION: 0

PAGE: 134

COMPONENT COOLING SYSTEM

[illegible]

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
	CC1092 (REF. DWG. NO. CC-1-1A 01)															
520080	1A-CCA-005	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501540
	ANCHOR	F1.30-A		2	C	-	-	-	-	-	-	-	-	-	-	(1A-CCA-005-IA) .
				3	X	-	-	-	-	-	-	-	-	-	-	

	CC1200 (REF. DWG. NO. CC-1-1C 01)															
520090	1A-CCA-260	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501720
	ANCHOR	F1.30-A		2	-	-	-	-	C	-	-	-	-	-	-	(1A-CCA-260-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

	CC1424 (REF. DWG. NO. CC-1-1D 01)															
520100	1A-CCA-275	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501990
	ANCHOR	F1.30-A		2	-	-	-	-	C	-	-	-	-	-	-	(1A-CCA-275-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

	CC1000 (REF. DWG. NO. CC-1-1A 01)															
520110	1A-CCA-028	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501215
	ANCHOR	F1.30-A		2	-	-	-	-	C	-	-	-	-	-	-	(1A-CCA-028-IA) .
				3	-	-	-	-	X	-	-	-	-	-	-	

520120	1A-CCA-023B	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501240
	ANCHOR	F1.30-A		2	-	C	-	-	-	-	-	-	-	-	-	(1A-CCA-023B-IA)
				3	-	-	-	-	-	-	-	-	-	-	-	

520130	1A-CCH-022	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501245
	HANGER	F1.30-I		2	-	-	-	-	C	-	-	-	-	-	-	(1A-CCH-022-IA) .
				3	-	-	-	-	X	-	-	-	-	-	-	

COMPONENT COOLING SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
520210	1A-CCH-016 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501595 (1A-CCH-016-IA).
				2	-	-	-	-	C	-	-	-	-	H	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
520220	1A-CCG-017 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501600 (1A-CCG-017-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
CC1167 (REF. DWG. NO. CC-1-1C 01)																	
520230	1A-CCA-268 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501670 (1A-CCA-268-IA).
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
CC1169 (REF. DWG. NO. CC-1-1C 01)																	
520240	1A-CCH-273 HANGER	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501700 (1A-CCH-273-IA).
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	
CC1208 (REF. DWG. NO. CC-1-1D 01)																	
520250	1A-CCA-284 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501745 (1A-CCA-284-IA).
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
CC1000 (REF. DWG. NO. CC-1-2A 02)																	
520260	1A-CCS-038 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501170 (1A-CCS-038-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520270	1A-CCA-036 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501180 (1A-CCA-036-IA).
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE : 138

INSPECTION INTERVAL_____

PLAN STATUS

[illegible]

REVISION: 0

PAGE: 139

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
				O U T A G E				O U T A G E				O U T A G E				
				1	2	3	4	1	2	3	4	1	2	3	4	
	CC1161 (REF. DWG. NO. CC-1-2B 01)															
520360	1A-CCA-093 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501655 (1A-CCA-093-IA).
				2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1162 (REF. DWG. NO. CC-1-2B 01)															
520370	1A-CCG-095 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501665 (1A-CCG-095-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1239 (REF. DWG. NO. CC-1-2B 01)															
520380	1A-CCA-107 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501840 (1A-CCA-107-IA).
				2	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1255 (REF. DWG. NO. CC-1-2A 02)															
520390	1A-CCG-103 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501875 (1A-CCG-103-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1313 (REF. DWG. NO. CC-1-3A 02)															
520400	1C-CCS-038 SUPPORT	F-A F1.30-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501920 (1A-CCS-038-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	CC1480 (REF. DWG. NO. CC-1-2A 2A)															
520410	1A-CCG-416 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 502035 (1A-CCG-416-IA).
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

[illegible]

REVISION: 0

PAGE: 141

COMPONENT COOLING SYSTEM

[illegible]

CONTAINMENT SPRAY SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY														
		ITEM NO	METH					O U T A G E								
				1	2	3	4	1	2	3	4	1	2	3	4	
	CS1000 (REF. DWG. NO. CS-1-1A 01)															
520590	1A-CSH-150	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 502095
	HANGER	F1.30-I		2	-	-	-	-	C	-	-	-	-	-	-	(1A-CSH-150-IA).
				3	-	-	-	-	X	-	-	-	-	-	-	
	CS1003 (REF. DWG. NO. CS-1-1A 01)															
520600	1A-CSS-152A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 502105
	SUPPORT	F1.30-I		2	-	-	-	-	-	-	-	-	-	-	-	(1A-CSS-152A-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	
	SJ1094 (REF. DWG. NO. CS-1-1A 01)															
520610	1A-CSA-156	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 502920
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	C	-	-	(1A-CSA-156-IA).
				3	-	-	-	-	-	-	-	-	X	-	-	

01RF - W/O# 50009730 TO PERFORM NDE.

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
	(REF. DWG. NO. SW-1-15A)							O	U	T	A	G	E				**CALIBRATION BLOCK**
520625	1C-15SWA-5001-IA TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508200 (1C-15SWA-5001).
				2	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520635	1C-15SWA-5007-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508215 (1C-15SWA-5007).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520645	1C-14SWA-4001-IA ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508220 (1C-14SWA-4001).
				2	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520655	1C-11SWA-1001-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508265 (1C-11SWA-1001).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520665	1C-12SWA-2001-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508255 (1C-12SWA-2001).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
520675	1C-14SWA-4007-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508260 (1C-14SWA-4007).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
(REF. DWG. NO. SW-1-12B)																	
520685	1C-12SWA-2008-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508310
				2	-	-	-	-	-	-	-	-	-	-	-	(1C-12SWA-2008). (PSI,	
				3	-	-	-	-	-	-	-	-	-	-	-	1EC-2270, 2/1/1)	
(REF. DWG. NO. SW-1-14B)																	
520695	1C-14SWS-4012-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508315
				2	-	-	-	-	-	-	-	-	-	-	-	(1C-14SWS-4012). (PSI,	
				3	-	-	-	-	-	-	-	-	-	-	-	1EC-2270, 2/1/1)	
(REF. DWG. NO. SW-1-11B)																	
520705	1C-11SWA-1007-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508320
				2	-	-	-	-	-	-	-	-	-	-	-	(1C-11SWA-1007). (PSI,	
				3	-	-	-	-	-	-	-	-	-	-	-	1EC-2270, 2/1/1)	
(REF. DWG. NO. SW-1-13A)																	
520715	1C-13SWA-3001-IA TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508365
				2	-	-	-	-	-	-	-	-	-	-	-	(1C-13SWA-3001). REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 601769, DET. A. (PSI, 1EC-2270, 2/1/1)	
(REF. DWG. NO. SW-1-12B)																	
520725	1C-12SWS-2013-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508370
				2	-	-	-	-	-	-	-	-	-	-	-	(1C-12SWS-2013). REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 601769, DET. D. (PSI, 1EC-2270, 2/1/1)	

REVISION: 0

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**
				1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-11B)																
520735	1C-11SWS-1012-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508380 (1C-11SWS-1012). REF. DWG. 601769, DET. D. (PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-13B)																
520745	1C-13SWA-3007-IA TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508385 (1C-13SWA-3007). REF. DWG. 610769, DET. A. (PSI, 1EC-2270, 2/1/1)
520755	1C-13SWS-3012-IA PIPE TO SUPPORT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508410 (1C-13SWS-3012). REF. DWG. 601769, DET. A. (PSI, 1EC-2270, 2/1/1)
(REF. DWG. NO. SW-1-13E 0)																
520785	1C-13SWG-009-IA PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 510285 (1C-13SWG-009). REF. DWG. 604229, DET X.
01RF - W/O# 50009730 TO PERFORM NDE.																
(REF. DWG. NO. SW-1-3D 01)																
520795	1C-13SWG-010-IA PIPE LUGS	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509195 (1C-13SWG-010). REF. DWG. 604229, DET. D. (PSI, 1EC-3054, 2/2/1)

PAGE: 146

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		-		-	-	-	O	U	T	A	G	E	-	-	-	-	
				1	2	3	4	1	2	3	4	1	2	3	4		
SW1256 (REF. DWG. NO. SW-1-2B 04)																	
520800	1A-SWA-WS01	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509445	
	ANCHOR	F1.30-A		2	-	-	-	-	C	-	P	-	-	-	-	(1A-SWA-WS01-IA) .	
				3	-	-	-	-	X	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-2B 04)																	
520810	1A-SWA-WS02	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509795	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	P	-	-	-	-	(1A-SWA-WS02-IA) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-1B 06)																	
520860	1P-SWA-WS09	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509155	
	ANCHOR	F1.30-A		2	-	C	-	-	-	-	-	-	-	-	-	(1P-SWA-WS09-IA) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
(REF. DWG. NO. SW-1-2B 01)																	
520870	1A-SWA-WS04	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509495	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	P	-	-	-	-	(1A-SWA-WS04-IA) . REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	ARRANGEMENT DWG. 207484 .	
(REF. DWG. NO. SW-1-1B 07)																	
520880	1A-SWA-WS03	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 509810	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	P	-	-	-	-	(1A-SWA-WS03-IA) . REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	ARRANGEMENT DWG. 207484 .	
(REF. DWG. NO. SW-1-1B 07)																	
520890	1P-SWA-109	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 510365	
	ANCHOR	F1.30-A		2	-	-	C	-	-	-	-	-	-	-	-	(1P-SWA-109-IA) . REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 602711, DET. 14.	

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

01RF - W/O# 50009730 TO PERFORM NDE. 03/12/01 EXPANDED NDE VT-3 EXAM ADDED TO MEET CODE REQUIREMENTS DUE TO FAILURE OF SUM# 508915 GUIDE 1MSWG-43.:

REVISION: 0

PAGE: 148

PLAN STATUS

[illegible]

REVISION: 0

PAGE: 149

SERVICE WATER SYSTEM

[illegible]

REVISION: 0

PAGE: 150

[illegible]

SERVICE WATER SYSTEM

[illegible]

REVISION: 0

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD - - - - - 1 2 3 4	SECOND PERIOD O U T A G E 1 2 3 4	THIRD PERIOD - - - - - 1 2 3 4	INSTRUCTIONS **CALIBRATION BLOCK**
	SW1067 (REF. DWG. NO.	SW-1-7K 01)					
521180	1-SWPG-023 GUIDE	F-A F1.30-N	VT-3	1 - - - - 2 C - - - 3 - - - -	- - - - P -	- - - -	REF. SUM# 508805 (1-SWPG-023-IA).
521200	1-SWPS-052 SUPPORT	F-A F1.30-M	VT-3	1 - - - - 2 - - - - 3 - - - -	- - - - C - P -	- - - -	REF. SUM# 508815 (1-SWPS-52-IA).
521210	1-SWPS-051 SUPPORT	F-A F1.30-M	VT-3	1 - - - - 2 - - - - 3 - - - -	- - - - C - P -	- - - -	REF. SUM# 508820 (1-SWPS-051-IA).
	SW1067 (REF. DWG. NO.	SW-1-7H 01)					
521225	1-SWPS-009-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1 - - - - 2 - - - - 3 - - - -	- - - - C - P -	- - - -	REF. SUM# 508825 (1-SWPS-009). REF DWG. 212599..
	SW1069 (REF. DWG. NO.	SW-1-7K 01)					
521240	1-SWPS-043 SUPPORT	F-A F1.30-M	VT-3	1 - - - - 2 - - - - 3 - - - -	- - - - P - - -	- - - -	REF. SUM# 508845 (1-SWPS-043-IA). (PSI, 5/13/92 (ISC-2256/P91-092/910611 130), 2/2/1.
	SW1070 (REF. DWG. NO.	SW-1-7K 01)					
521250	1-SWPS-044 SUPPORT	F-A F1.30-M	VT-3	1 - - - - 2 - C - - - 3 - - - -	- - - - P - - -	- - - -	REF. SUM# 508850 (1-SWPS-044-IA). (PSI, 5/21/92 (ISC-2256/P91-091/910611 130), 2/2/1.

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				-				O U T A G E				-					
				1	2	3	4	1	2	3	4	1	2	3	4		
	SW1071 (REF. DWG. NO. SW-1-7K 01)																
521260	1-SWPS-045 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508855 (1-SWPS-045-IA). (PSI, 5/21/92 (1SC-2256/P91-092/910611 130), 2/2/1.	
				2	-	C	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		-
	SW1072 (REF. DWG. NO. SW-1-7K 01)																
521270	1-SWPS-053 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508860 (1-SWPS-053-IA).	
				2	-	-	-	-	C	-	P	-	-	-	-		-
				3	-	-	-	-	-	-	-	-	-	-	-		-
	SW1136 (REF. DWG. NO. SW-1-7K 01)																
521280	1-SWPG-049A GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508920 (1-SWPG-049-IA). REF. DWGS. 219813 & 217121, SHT 1.	
				2	-	-	-	-	P	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		-
	SW1136 (REF. DWG. NO. SW-1-7H 01)																
521290	1-SWPG-022 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508925 (1-SWPG-022-IA). REF. DWGS. 212599 & 217121, SHT 1.	
				2	-	-	-	-	-	P	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		-
	SW1136 (REF. DWG. NO. SW-1-7H 01)																
521305	1-SWPS-005-IA PIPE TO TRUNNION	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 508930 (1-SWPS-005).	
				2	-	-	-	-	C	-	P	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		-
	SW1136 (REF. DWG. NO. SW-1-7H 01)																
521315	1-SWPG-007-IA PIPE TO P-7 PAD	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 508935 (1-SWPG-007). REF. DWG. 212599.	
				2	-	-	-	-	P	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		-

REVISION: 0

PAGE: 154

SERVICE WATER SYSTEM

[illegible]

DATE: 07/16/2001
REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

PAGE: 155

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				-				O U T A G E				-				
				1	2	3	4	1	2	3	4	1	2	3	4	
(REF. DWG. NO. SW-1-1B 08)																
521440	1P-SWA-PS48 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521445
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1P-SWA-PS48-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).
521445	1P-SWA-PS48-IA PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521440
		D1.20		2	-	-	-	-	-	-	-	-	-	-	-	(1P-SWA-PS48). REF.DWG.
				3	-	-	-	-	-	-	-	-	-	-	-	207486, SHT. 2, DETAIL (G-H, 1-3).
521450	1P-SWA-PS50 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521455
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1P-SWA-PS50-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).
521455	1P-SWA-PS50-IA PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521450
		D1.20		2	-	-	-	-	-	-	-	-	-	-	-	(1P-SWA-PS50). REF.DWG.
				3	-	-	-	-	-	-	-	-	-	-	-	207486, SHT. 2, DETAIL (G-H, 1-3).
(REF. DWG. NO. SW-1-1B 10)																
521460	1P-SWA-PS51 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521465
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1P-SWA-PS51-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	REF.DWG. 207486, SHT. 4 & SHT. 2, DETAIL (G-H, 1-3).

REVISION: 0

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				- - - - -				O U T A G E -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
521465	1P-SWA-PS51-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521460 (1P-SWA-PS51). REF.DWG. 207486, SHT. 4 & SHT. 2, DETAIL (G-H, 1-3).
(REF. DWG. NO. SW-1-1B 09)																	
521470	1P-SWA-PS52 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521475 (1P-SWA-PS52-IA). REF.DWG. 207486, SHT. 3 & SHT. 2, DETAIL (G-H, 1-3).
521475	1P-SWA-PS52-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521470 (1P-SWA-PS52). REF.DWG. 207486, SHT. 3 & SHT. 2, DETAIL (G-H, 1-3).
(REF. DWG. NO. SW-1-1B 08)																	
521480	1P-SWA-PS53 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521485 (1P-SWA-PS53-IA). REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).
521485	1P-SWA-PS53-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521480 (1P-SWA-PS53). REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).

SERVICE WATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
		SEC. XI														
		CATEGORY ITEM NO														
O U T A G E																
1 2 3 4 1 2 3 4 1 2 3 4																
(REF. DWG. NO. SW-1-1B 09)																
521490	1P-SWA-PS54 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521495 (1P-SWA-PS54-IA). REF.DWG. 207486, SHT. 3 & SHT. 2, DETAIL (G-H, 1-3).
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		
.....																
521495	1P-SWA-PS54-IA PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521490 (1P-SWA-PS54). REF.DWG. 207486, SHT. 3 & SHT. 2, DETAIL (G-H, 1-3).
		D1.20		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		
.....																
(REF. DWG. NO. SW-1-1B 08)																
521500	1P-SWA-PS55 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521505 (1P-SWA-PS55-IA). REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		
.....																
521505	1P-SWA-PS55-IA PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521500 (1P-SWA-PS55). REF.DWG. 207486, SHT. 2, DETAIL (G-H, 1-3).
		D1.20		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		
.....																
(REF. DWG. NO. SW-1-7U 03)																
521510	1MSWA-615 ANCHOR	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521515 (1MSWA-615-IA).
		F1.30-A		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		
.....																
521515	1MSWA-615-IA PIPE TO ANCHOR	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521510 (1MSWA-615).
		D1.20		2	-	-	-	-	-	-	-	-	-	-		
		3		-	-	-	-	-	-	-	-	-	-	-		

REVISION: 0

PAGE : 158

INSPECTION INTERVAL

PLAN STATUS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**
		SEC. XI		O U T A G E												
		CATEGORY ITEM NO		METH	1	2	3	4	1	2	3	4	1	2	3	
	(REF. DWG. NO. SW-1-7V 03)															
521520	1MSWA-619 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521525 (1MSWA-619-IA) .
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
521525	1MSWA-619-IA PIPE TO ANCHOR	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 521520 (1MSWA-619) .
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	SW1664 (REF. DWG. NO. SW-1-12E 0)															
521530	1C-12SWG-6B GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

PAGE: 159

CLASS 3 ALL STATUS COMPONENTS

[illegible]

REVISION: 0

PAGE: 160

SAFETY INJECTION SYSTEM

[illegible]

REVISION: 0

PAGE : 161

MAIN STEAM SYSTEM

		INSPECTION INTERVAL		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**	
				- - - - -				O U T A G E - - - - -				- - - - -					
				1	2	3	4	1	2	3	4	1	2	3	4		
	MS1034 (REF. DWG. NO. MS-1-4 01)																
522200	1A-MSAS-129	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 504470	
	SUPPORT	F1.30-I		2	-	-	-	-	-	-	-	-	-	-	-	(1A-MSAS-129-IA). REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 232475, SHT 15.	
522210	1A-MSAS-126	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 504490	
	SUPPORT	F1.30-I		2	-	-	-	-	-	-	-	-	-	-	-	(1A-MSAS-126-IA). REF.	
				3	-	-	-	X	-	-	-	-	-	-	-	DWG. 232475, SHT. 14.	
522220	1A-MSAA-130	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 504495	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1A-MSAA-130-IA). REF.	
				3	-	-	-	-	-	-	-	-	-	-	-	DWG. 207607 (F.1)	

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				O U T A G E												
				1	2	3	4	1	2	3	4	1	2	3	4	
	AF1120 (REF. DWG. NO. AF-1-2A 01)															
522230	1AFA-215	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500985
	ANCHOR	F1.30-A		2	C	-	-	-	-	-	-	-	-	-	-	(1AFA-215-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

	AF1131 (REF. DWG. NO. AF-1-2A 01)															
522240	1AFA-216	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 501015
	ANCHOR	F1.30-A		2	C	-	-	-	-	-	-	-	-	-	-	(1AFA-216-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

	AF1053 (REF. DWG. NO. AF-1-3A 01)															
522250	14AFWA-041	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500325
	ANCHOR	F1.30-A		2	C	-	-	-	-	-	-	-	-	-	-	(14AFWA-041-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

	AF1063 (REF. DWG. NO. AF-1-3A 01)															
522260	13AFWA-046	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500390
	ANCHOR	F1.30-A		2	-	-	-	-	C	P	-	-	-	-	-	(13AFWA-046-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

522270	13AFWA-044	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500400
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(13AFWA-044-IA) .
				3	-	-	-	-	-	-	-	-	-	-	-	

522280	13AFWA-041	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500420
	ANCHOR	F1.30-A		2	-	-	-	-	C	-	-	-	-	-	-	(13AFWA-041-IA) .
				3	-	-	-	-	X	-	-	-	-	-	-	

CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL

PLAN STATUS

01RF - W/O# 50009730 TO PERFORM NDE.

PAGE: 164

CLASS 3 ALL STATUS COMPONENTS

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI CATEGORY ITEM NO		METH	1	2	3	4	1	2	3	4	1	2	3		
AF1044 (REF. DWG. NO. AF-1-2B 01)																	
522350	1AFS-167 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500060 (1AFS-167-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1046 (REF. DWG. NO. AF-1-2B 01)																	
522360	1AFG-160 GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500065 (1AFG-160-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1053 (REF. DWG. NO. AF-1-2B 01)																	
522370	1AFA-188 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500090 (1AFA-188-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1063 (REF. DWG. NO. AF-1-2B 01)																	
522380	1AFS-172 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500135 (1AFS-172-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1063 (REF. DWG. NO. AF-1-2B 01)																	
522390	1AFS-170 SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500380 (1AFS-170-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1075 (REF. DWG. NO. AF-1-2B 01)																	
522400	1AFA-166 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500440 (1AFA-166-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1075 (REF. DWG. NO. AF-1-2B 01)																	
522410	1AFA-189 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500470 (1AFA-189-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		SEC. XI CATEGORY ITEM NO		1	2	3	4	1	2	3	4	1	2	3	4		
AF1089 (REF. DWG. NO. AF-1-2B 01)																	
522420	1AFS-168	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500725
	SUPPORT	F1.30-M		2	-	-	-	-	-	-	-	-	-	-	-	-	(1AFS-168-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1099 (REF. DWG. NO. AF-1-2A 01)																	
522430	1AFA-139	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500885
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	-	(1AFA-139-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1030 (REF. DWG. NO. AF-1-2B 01)																	
522440	1AFA-148	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500910
	ANCHOR	F1.30-A		2	-	-	-	-	-	P	-	-	-	-	-	-	(1AFA-148-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1030 (REF. DWG. NO. AF-1-2B 01)																	
522450	1AFA-174	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500020
	ANCHOR	F1.30-A		2	-	C	-	-	-	-	-	-	-	-	-	-	(1AFA-174-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1063 (REF. DWG. NO. AF-1-2B 01)																	
522460	1AFA-204	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 500345
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	-	(1AFA-204-IA).
				3	-	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

SALEM NUCLEAR GENERATING STATION UNIT 1
INSERVICE INSPECTION PROGRAM LONG TERM PLAN
CLASS 3 ALL STATUS COMPONENTS

COMPONENT COOLING SYSTEM

[illegible]

CLASS 3 ALL STATUS COMPONENTS

PLAN STATUS

[illegible]

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				INSTRUCTIONS **CALIBRATION BLOCK**	
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
523035	1-AFG-103-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523030 (1-AFG-103).
AF1000 (REF. DWG. NO. AF-1-2A-01)																	
523040	1-AFS-104 H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
AF1133 (REF. DWG. NO. AF-1-2A-01)																	
523050	1-AFS-105 H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
AF1000 (REF. DWG. NO. AF-1-2A-01)																	
523060	1-AFA-106 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523065 (1-AFA-106-IA).
AF1133 (REF. DWG. NO. AF-1-2A-01)																	
523065	1-AFA-106-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523060 (1-AFA-106).
AF1133 (REF. DWG. NO. AF-1-2A-01)																	
523070	1-AFA-107 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523075 (1-AFA-107-IA).
AF1133 (REF. DWG. NO. AF-1-2A-01)																	
523075	1-AFA-107-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523070 (1-AFA-107).

AUXILIARY FEEDWATER SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
	AF1000 (REF. DWG. NO. AF-1-2A-01)															
523080	1-AFG-108	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1133 (REF. DWG. NO. AF-1-2A-01)															
523090	1-AFG-109	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1000 (REF. DWG. NO. AF-1-2A-01)															
523100	1-AFG-110	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1133 (REF. DWG. NO. AF-1-2A-01)															
523110	1-AFG-111	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1000 (REF. DWG. NO. AF-1-2A-01)															
523120	1-AFH-112	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	ROD HANGER	F1.30-L		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1000 (REF. DWG. NO. AF-1-2A-01)															
523130	1-AFH-114	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	ROD HANGER	F1.30-L		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
	AF1000 (REF. DWG. NO. AF-1-2A-01)															
523140	1-AFG-116	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

REVISION: 0

PAGE: 170

INSPECTION INTERVAL

PLAN STATUS

[illegible]

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
523220	1-AFS-136 H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
523230	1-AFS-138 H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
523240	1-AFS-140 H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
523250	1-AFH-142 ROD HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
523260	1-AFH-144 ROD HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
	AF1133 (REF. DWG. NO. AF-1-2A-01)																
523270	1-AFS-101A H. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523275 (1-AFS-101A-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
523275	1-AFS-101A-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523270 (1-AFS-101A).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

CLASS 3 ALL STATUS COMPONENTS

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**
				1	2	3	4	1	2	3	4	1	2	3	4	
AF1000 (REF. DWG. NO. AF-1-2A-01)																
523280	1-AFA-146 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523285 (1-AFA-146-IA).
.....																
523285	1-AFA-146-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523280 (1-AFA-146).
.....																
AF1004 (REF. DWG. NO. AF-1-2A-01)																
523290	1-AFH-150 ROD HANGER	F-A F1.30-L	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
.....																
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																
.....																
AF1148 (REF. DWG. NO. AF-1-2A-01)																
523300	1-AFA-152 ANCHOR	F-A F1.30-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523305 (1-AFA-152-IA).
.....																
523305	1-AFA-152-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523300 (1-AFA-152).
.....																
AF1004 (REF. DWG. NO. AF-1-2A-01)																
523310	1-AFG-153 H. GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
.....																
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																
.....																
523320	1-AFS-154 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523325 (1-AFS-154-IA).

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				**CALIBRATION BLOCK**	
				1	2	3	4	1	2	3	4	1	2	3	4		
523325	1-AFS-154-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523320 (1-AFS-154).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1148 (REF. DWG. NO. AF-1-2A-01)																	
523330	1-AFS-155 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523335 (1-AFS-155-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1012 (REF. DWG. NO. AF-1-2A-01)																	
523335	1-AFS-155-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523330 (1-AFS-155).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1012 (REF. DWG. NO. AF-1-2A-01)																	
523340	1-AFS-156 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523345 (1-AFS-156-IA).
				2	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
523345	1-AFS-156-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523340 (1-AFS-156).
				2	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
AF1159 (REF. DWG. NO. AF-1-2A-01)																	
523350	1-AFS-157 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523355 (1-AFS-157-IA).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
AF1159 (REF. DWG. NO. AF-1-2A-01)																	
523355	1-AFS-157-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523350 (1-AFS-157).
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				O U T A G E													
				1	2	3	4	1	2	3	4	1	2	3	4		
AF1009 (REF. DWG. NO. AF-1-2A-01)																	
523360	1-AFS-158 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523365 (1-AFS-158-IA).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1157 (REF. DWG. NO. AF-1-2A-01)																	
523365	1-AFS-158-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523360 (1-AFS-158).
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1159 (REF. DWG. NO. AF-1-2A-01)																	
523370	1-AFS-159 V. SUPPORT	F-A F1.30-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523375 (1-AFS-159-IA).
				2	-	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
523375	1-AFS-159-IA WELDED ATTACHMENT	D-A D1.20	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523370 (1-AFS-159).
				2	-	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
AF1000 (REF. DWG. NO. AF-1-2A-01)																	
523380	1-AFG-227 V. GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
AF1142 (REF. DWG. NO. AF-1-1A-01)																	
523390	1-AFSG-1 H. GUIDE	F-A F1.30-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	-	X	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
	AF1145 (REF. DWG. NO. AF-1-1A-01)																
523400	1-AFSG-2	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	-	X	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
	AF1146 (REF. DWG. NO. AF-1-1A-01)																
523410	1-AFSG-3	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523420	1-AFSG-4	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523430	1-AFSG-5	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523440	1-AFSG-6	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523450	1-AFSG-7	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523460	1-AFSG-8	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
523470	1-AFSG-9	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		

REVISION: 0

PAGE: 176

AUXILIARY FEEDWATER SYSTEM

[illegible]

AUXILIARY FEEDWATER SYSTEM

[illegible]

AUXILIARY FEEDWATER SYSTEM

INSPECTION INTERVAL				PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
		1		2	3	4	1	2	3	4	1	2	3	4			
	AF1155 (REF. DWG. NO. AF-1-1A-01)																
523620	1-AFSG-26	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-		
	H. GUIDE	F1.30-N		2	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-		
	AF1142 (REF. DWG. NO. AF-1-1A-01)																
523630	1A-AFSA-SLV-A	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523635	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1A-AFSA-SLV-A-IA) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
523635	1A-AFSA-SLV-A-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523630	
	WELDED ATTACHMENT	D1.20		2	-	-	-	-	-	-	-	-	-	-	-	(1A-AFSA-SLV-A) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
	AF1145 (REF. DWG. NO. AF-1-1A-01)																
523640	1A-AFSA-SLV-B	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523645	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	-	-	-	(1A-AFSA-SLV-B-IA) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
523645	1A-AFSA-SLV-B-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523640	
	WELDED ATTACHMENT	D1.20		2	-	-	-	-	-	-	-	-	-	-	-	(1A-AFSA-SLV-B) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
	AF1155 (REF. DWG. NO. AF-1-1A-01)																
523650	1A-AFSA-SLV-C	F-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523655	
	ANCHOR	F1.30-A		2	-	-	-	-	-	-	-	-	C	-	-	(1A-AFSA-SLV-C-IA) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	
523655	1A-AFSA-SLV-C-IA	D-A	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	REF. SUM # 523650	
	WELDED ATTACHMENT	D1.20		2	-	-	-	-	-	-	-	-	C	-	-	(1A-AFSA-SLV-C) .	
				3	-	-	-	-	-	-	-	-	-	-	-		
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																	