



ISO SHT. NO. 3406					
QSL	ITEM	QTY.	SIZE	MATERIAL DESCRIPTION	HEAT NO.
01	1	2	1 1/2"	150# RF SW FLG SCH. 80	A-181
	2	2	1 1/2"	1" THK 150# RF GASK COMP. ASSY	A-181
	3	8	1/2"	1/2" L4-HEX. HD. MACH. BOLTS	A-307 GR. B
	4	8	1/2"	HEAVY HEX. NUTS. CL. 2 TOL.	A-307 GR. B
	5	1	3"	125# C.I. FLGD GATE VA.	12 GF09RZ
	6	2	3"	1" THK 150# F.E. GASK. COMP. ASSY	A-181
	7	8	1/2"	1/2" L4-HEX. HD. MACH. BOLTS	A-307 GR. B
	8	8	1/2"	HEAVY HEX. NUTS. CL. 2 TOL.	A-307 GR. B
	9	1	1"	200# THD BRONZE GLOBE VA.	Y-100T23
	10	1	1"	3000# CS. THD CAP.	A-181 GR. B
	11	2	1 1/2"	3000# CS. S.W. 90° ELL.	A-181 GR. B
	12	1	1"	PIPE (SCH. 80) SMLS C.S.	A-106 GR. B
	13	1	1 1/2"	PIPE (SCH. 80) SMLS C.S.	A-106 GR. B

REVISION RECORD			
NO.	DATE	DESCRIPTION	REMARKS
1	REV. PER. RDM-MC-0177	ADDED NOTE #2	
2	REV. PER. RDM-MC-0177	ADDED NOTE #2	

HANGER MARK NO'S

- 2-GNSW-R-547
- 2-GNSW-R-548
- 2-ANSW-R-548A
- 2-GNSW-R-549
- 2-GNSW-R-550
- 2-GNSW-R-565
- 2-ANSW-R-601

NOTE:

1-USE CRANE #25-A OR GRINNELL 1698 COMPOUND ON ALL THREADED CONNS.

DESIGN SPEC. DCCPM102GCS

HANGER SEISMIC CLASS II

TEST REQUIREMENTS N/A

MATERIAL CLASS A-21 SP-104

DESIGNER J.C.

CHECKED J.C.

DATE 10/1/73

FLOW DIAGRAM 2-114A

REQUIRED COMPLETION DATE 10/1/73

FABRICATOR NOTE: FABRICATION MUST CONFORM TO LATEST A.E.P. ARRGT. DWGS.

WELD PROCEDURE

LIVSEY & COMPANY, INC.

INDIANA & MICHIGAN ELECTRIC CO.

DONALD C. COOK NUCLEAR PLANT

CONTAINMENT BLDG.

2-NSW-133

SH# 2 OF 2

SIZE	QTY.	FW
1 1/2"	2	
1"	1	

INDICATES LOCATION OF PIPE SUPPORT AND SUPPORT DETAIL NUMBER

SUPPORT MARK NUMBERS SHOWN ARE FOR GENERAL AND CENTRAL LOCATION OF SUPPORTS ONLY FOR EXACT LOCATIONS SEE PIPE SUPPORT DETAIL

PIPE									
A-23	A-106	A-376	A-312	A-103	A-234	A-182	N.D.T.	N/A	
STD.	XY	XY	10	20	30	40	60	80	100
SMLS	WLD								

FITTINGS			
A-103	A-234	A-182	N.D.T.
A-403	A-181		