

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.1.1 Perform required visual examinations and leakage rate testing except for primary containment air lock testing, in accordance with the Primary Containment Leakage Rate Testing Program.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program.</p>
<p>SR 3.6.1.1.2 Verify that the drywell-to-suppression chamber bypass leakage is less than 0.00535 ft² at an initial differential pressure of ≥ 4.3 psi.</p>	<p>When performing 10 CFR 50 Appendix J, Type A testing, in accordance with the Primary Containment Leakage Rate Testing Program.</p> <p><u>AND</u></p> <p>-----Note-----</p> <p>Only required after two consecutive tests fail and continues until two consecutive tests pass</p> <p>-----</p> <p>24 months</p>