

October 23, 2001

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 - CLARIFICATION OF RELIEF
REQUESTS REGARDING RISK-INFORMED INSERVICE INSPECTION
PROGRAM (TAC NOS. MB1566 AND MB1567)

Dear Mr. Scalice:

In a letter dated October 19, 2001, the U.S. Nuclear Regulatory Commission (NRC) approved a risk-informed inservice inspection (RI-ISI) program for Class 1 and Class 2 piping welds as an alternative to the current ISI program at the Sequoyah Nuclear Plant, Units 1 and 2. The letter also approved Relief Requests 1-RI-ISI-2 and 2-RI-ISI-2 as requested in the Tennessee Valley Authority's submittal dated March 23, 2001. The purpose this letter is to provide clarification of our October 19 letter and the associated Safety Evaluation (SE).

The first sentence of the second paragraph of our approval letter contains the words "Class 1 socket welds." The correct words are "Class 1 and 2 branch connection welds equal to or less than 2 inches nominal pipe size and socket welds." The same word change also applies in the NRC staff's SE wherever the words "Class 1 socket welds" appear.

The staff's SE also erroneously stated that "for Sequoyah Units 1 and 2, the applicable editions of the Code for the second 10-year ISI interval are the 1989 Edition and the 1995 Edition through 1996 Addenda of ASME [American Society of Mechanical Engineers] Section XI, respectively." The staff hereby acknowledges that the code of record for Sequoyah's ISI Program is the 1989 Edition (no addenda) of the ASME Boiler and Pressure Vessel Code, Section XI.

These clarifications were discussed with your Sequoyah staff by telephone on October 22, 2001.

Sincerely,

/RA/

Richard P. Correia, Chief, Section 2
Project Directorate 11
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure: Safety Evaluation

cc w/enclosures: See next page

October 23, 2001

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 - CLARIFICATION OF RELIEF
REQUESTS REGARDING RISK-INFORMED INSERVICE INSPECTION
PROGRAM (TAC NOS. MB1566 AND MB1567)

Dear Mr. Scalice:

In a letter dated October 19, 2001, the U.S. Nuclear Regulatory Commission (NRC) approved a risk-informed inservice inspection (RI-ISI) program for Class 1 and Class 2 piping welds as an alternative to the current ISI program at the Sequoyah Nuclear Plant, Units 1 and 2. The letter also approved Relief Requests 1-RI-ISI-2 and 2-RI-ISI-2 as requested in the Tennessee Valley Authority's submittal dated March 23, 2001. The purpose this letter is to provide clarification of our October 19 letter and the associated Safety Evaluation (SE).

The first sentence of the second paragraph of our approval letter contains the words "Class 1 socket welds." The correct words are "Class 1 and 2 branch connection welds equal to or less than 2 inches nominal pipe size and socket welds." The same word change also applies in the NRC staff's SE wherever the words "Class 1 socket welds" appear.

The staff's SE also erroneously stated that "for Sequoyah Units 1 and 2, the applicable editions of the Code for the second 10-year ISI interval are the 1989 Edition and the 1995 Edition through 1996 Addenda of ASME [American Society of Mechanical Engineers] Section XI, respectively." The staff hereby acknowledges that the code of record for Sequoyah's ISI Program is the 1989 Edition (no addenda) of the ASME Boiler and Pressure Vessel Code, Section XI.

These clarifications were discussed with your Sequoyah staff by telephone on October 22, 2001.

Sincerely,

/RA/

Richard P. Correia, Chief, Section 2
Project Directorate 11
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure: Safety Evaluation

cc w/enclosures: See next page

DISTRIBUTION:

PUBLIC (PUBLIC)	ACRS (RidsAcrsAcnwMailCenter)	GHill (Hardcopy)
PDII-2 Reading(Hardcopy)	HBerkow (RidsNrrDlpmLpdii)	MRubin
SRosenberg, EDO (e-mail)	OGC (RidsOgcRp)	PPatniak
BClayton (Hardcopy)	TChan (RidsNrrDeEmcb)	SDinsmore
RHernan (Hardcopy)	PFredrickson (RidsRgn2MailCenter)	RCorreia (RidsNrrDlpmLpdii2)

ACCESSION NUMBER ML012960623

OFFICE	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	RHernan	BClayton	Rcorreia
DATE	10/23/01	10/ 23 /01	10/ 22 /01

OFFICIAL RECORD COPY

Mr. J. A. Scalice
Tennessee Valley Authority

SEQUOYAH NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Jon R. Rupert, Vice President
(Acting) Engineering & Technical
Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Richard T. Purcell
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager Licensing and
Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Russell A. Gibbs
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Ms. Ann P. Harris
341 Swing Loop Road
Rockwood, Tennessee 37854