

## REACTIVITY CONTROL SYSTEMS

### ACTION: (Continued)

- g. With more than one CEA trippable but misaligned from any other CEA in its group by more than 19 inches (indicated position), be in at least HOT STANDBY within 6 hours.

### SURVEILLANCE REQUIREMENTS

---

4.1.3.1.1 The position of each CEA shall be determined to be within 7 inches (indicated position) of all other CEAs in its group at least once per 12 hours.

4.1.3.1.2 Each CEA not fully inserted in the core shall be determined to be OPERABLE by movement of at least 5 inches in any one direction at least once per 92 days. (Note 1)

Note 1 - Movement of CEA #43 is not required for the remainder of cycle 15. If an outage of sufficient duration occurs prior to the end of Cycle 15, maintenance activities will be performed to restore the CEA.