

TABLE OF CONTENTS (Cont'd)

		<u>Page</u>
3.13 and 4.13	Alternate Shutdown System	223
	A. Alternate Shutdown System	223
	3.13 Bases	225
	4.13 Bases	226
3.14 and 4.14	Accident Monitoring Instrumentation	229a
	3.14 and 4.14 Bases	229e
3.15 and 4.15	(Deleted)	
3.16 and 4.16	(Deleted)	
3.17 and 4.17	Control Room Habitability	229u
	A. Control Room Ventilation System	229u
	B. Control Room Emergency Filtration System	229v
	3.17 Bases	229y
	4.17 Bases	229z
5.0	DESIGN FEATURES	230
	5.1 Site	230
	5.2 Reactor	230
	5.3 Reactor Vessel	230
	5.4 Containment	230
	5.5 Fuel Storage	231
	5.6 Seismic Designs	231
6.0	ADMINISTRATIVE CONTROLS	232
	6.1 Organization	232
	6.2 (Deleted)	
	6.3 (Deleted)	
	6.4 Action to be taken if a Safety Limit is Exceeded	243
	6.5 Procedures	244
	6.6 (Deleted)	
	6.7 Reporting Requirements	248
	6.8 Programs and Manuals	253
	6.9 High Radiation Area	259

C. Plant Staff

1. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.1.1.
 2. At least one licensed operator shall be in the control room when fuel is in the reactor.
 3. At least two licensed operators shall be present in the control room during cold startup, scheduled reactor shutdown, and during recovery from reactor trips.
 4. An individual qualified in radiation protection procedures shall be onsite when fuel is in the reactor.
 5. All alterations of the reactor core shall be directly supervised by a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
 6. The operations manager shall be formerly licensed as a Senior Reactor Operator or hold a current Senior Reactor Operator License.
 7. At least one member of plant management holding a current Senior Reactor Operator License shall be assigned to the plant operations group on a long term basis (approximately two years). This individual will not be assigned to a rotating shift.
 8. Licensed reactor operators and senior reactor operators shall complete qualification training in accordance with a Commission-approved training program that is based on a systems approach to training and uses a simulation facility that is acceptable to the Commission. This program has been accredited by the National Nuclear Accrediting Board.
- D. Each member of the site staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for (1) the radiation protection manager or designated health physicist who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975, (2) the Shift Technical Advisor who shall have a bachelor's degree or equivalent in a scientific or engineering discipline with specific training in plant design, and response and analysis of the plant for transients and accidents, (3) the operations manager who shall meet the requirement of ANSI N18.1-1971 except that NRC license requirements are as specified in Specification 6.1.C.7, and (4) licensed reactor operators and senior reactor operators shall meet the requirements of Specification 6.1.C.8. The training program shall be under the direction of a designated member of Nuclear Management Company, LLC management.

6.5 Procedures

A. Written procedures shall be established, implemented, and maintained covering the following activities:

1. The applicable procedures recommended in Regulatory Guide 1.33, Revision 2, Appendix A, February 1978;
2. The emergency operating procedures required to implement the requirements of NUREG-0737 and NUREG-0737, Supplement 1, as stated in Generic Letter 82-33;
3. Quality assurance for effluent and environmental monitoring;
4. Fire Protection Program implementation; and
5. All programs specified in Specification 6.8.

6.6 (Deleted)

B. (Deleted)

C. Environmental Reports

1. Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

The Annual Radiological Environmental Operating Report shall include the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.