

From: Hubert J. Miller
To: David Lew
Date: Tue, Jul 18, 2000 12:24 PM
Subject: Fwd: Expectations

i neglected to copy you on this

10

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5
FOIA- 2001-0256

ITEM # 172 6/25

31

From: Hubert J. Miller
To: Brian Sheron, Jack Strosnider
Date: Tue, Jul 18, 2000 12:05 PM
Subject: Expectations

Brian/Jack,

[REDACTED]

EXE

CC:
Schmidt

BEH, Bill Bateman, John Zwolinski, JTW1, Pete Eselgroth, W Lanning, Wayne

The licensee failed to effectively implement a program of steam generator inspections which:

- was founded upon and accounted for the known and likely potential degradation mechanisms that could be occurring
- was sensitive to and accounted for conditions that increased the susceptibility of tubes to these degradation mechanisms
- accounted and compensated for conditions that challenged or limited detection capabilities
- adjusted or modified inspection methods and analysis during the inspection process to account for anomalies and other new conditions encountered

All of the above to provide reasonable assurance of steam generator tube integrity.