

From:  
To:  
Date:  
Subject:

EX. 6  
EX. 6  
EX. 6  
<Doddcv@>  
<WLS@nrc.gov>  
Fri, Jul 21, 2000 3:02 PM  
Rebuttal of talking points:

Wayne:

I have received the transmission from Westinghouse and have some ideas on how we should reply. The amplitude of the noise and the defects that were missed should be stated for all eight of the tubes. I believe that the noise at 300 kHz was greater than they have indicated. Also, I may be able to find some data about the amplitude of SCC as were applied to the alternate plugging criteria.

My phone number is [REDACTED] and I will be here the rest of the evening if you want to call.

Caius

EX 6

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 6  
FOIA-2001-0236

6/37