



444 South 16th Street Mall  
Omaha NE 68102-2247

October 10, 2001  
LIC-01-0096

U. S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, D.C. 20555

Reference: Docket No. 50-285

**SUBJECT: September 2001 Monthly Operating Report (MOR)**

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for September 2001.

If you have any questions, please contact me.

Sincerely,

S. K. Gambhir  
Division Manager  
Nuclear Operations

SKG/EPM/epm

**Attachments**

- c: E. W. Merschoff, NRC Regional Administrator, Region IV  
A. B. Wang, NRC Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
INPO Records Center  
Winston & Strawn

IE24

**ATTACHMENT 1  
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>October 1, 2001</u>
COMPLETED BY	<u>E. P. Matzke</u>
TELEPHONE	<u>(402) 533-6855</u>

**REPORT PERIOD: September 2001**

1. Design Electrical Rating	<u>(MWe-Net):</u>	<u>478</u>
2. Maximum Dependable Capacity	<u>(MWe-Net):</u>	<u>478</u>

**OPERATING STATUS**

	<b>MONTH</b>	<b>YEAR TO DATE</b>	<b>CUMULATIVE</b>
3. Number of Hours Reactor was Critical:	720	5,526	197,671
4. Number of Hours Generator was On-line:	720	5,493	195,659
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy Generated (MWh):	345,616	2,446,027	84,129,434

**ATTACHMENT 2  
UNIT SHUTDOWNS**

**REPORT MONTH September 2001**

DOCKET NO. 50-285  
UNIT NAME Fort Calhoun Station  
DATE October 1, 2001  
COMPLETED BY E. P. Matzke  
TELEPHONE (402) 533-6855

No.	Date (YY/MM/DD)	Type F: Forced S: Scheduled	Duration (Hours)	Reason <sup>1</sup>	Method of Shutting Down Reactor <sup>2</sup>	Cause & Corrective Action to Prevent Recurrence
none						

**(1) Reason:**

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

**(2) Method:**

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

**OPERATIONS SUMMARY**

The Fort Calhoun Station (FCS) was operated at a nominal 100% power throughout the month of September. There has been no change in the status of the lower seal on Reactor Coolant Pump (RCP) RC-3D. Fuel reliability problems continue to be a challenge.

**SAFETY VALVE OR PORV CHALLENGES/FAILURES**

No failures or challenges to safety valves or PORVs occurred during the month.