

## REACTOR COOLANT SYSTEM

### OPERATIONAL LEAKAGE

#### SURVEILLANCE REQUIREMENTS (Continued)

---

4.4.6.2.1 Reactor Coolant System leakages shall be demonstrated to be within each of the above limits by:

- a. Monitoring the containment atmosphere gaseous radioactivity and particulate radioactivity channels at least once per 12 hours;
- b. Monitoring the containment normal sump inventory and discharge at least once per 12 hours;
- c. Performance of a Reactor Coolant System water inventory balance at least once per 72 hours; and
- d. Monitoring the Reactor Head Flange Leakoff System at least once per 24 hours.

4.4.6.2.2 Each Reactor Coolant System Pressure Isolation Valve specified in Table 3.4-1 shall be demonstrated OPERABLE by verifying leakage to be within its limit:

- a. At least once per 18 months,
- b. Prior to entering MODE 2 whenever the plant has been in COLD SHUTDOWN for 72 hours or more and if leakage testing has not been performed in the previous 9 months,
- c. Prior to returning the valve to service following maintenance, repair or replacement work on the valve, and
- d. Prior to entering MODE 2 following valve actuation due to automatic or manual action or flow through the valve except for valves XRH0060 A, B, C, and XRH0061 A, B, C.

The provisions of Specification 4.0.4 are not applicable for entry into MODE 3 or 4.