



LEGEND

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- HVAC DUCT

- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

NOTES:

- DELETED
- FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
- FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
- UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

REV	DATE	DESCRIPTION	BY	CHKD	APP'D	FILE
1	05/10/90	INC. DCM'S ISID2-033A-6 PER DCR 94-0010, ISID2-033A-9 PER DCR 94-0425 AND ISID2-033A-10 PER MOD 95-0008 SUP. 0	JJK	RJC	TWB	ON FILE
2	05/10/90	INC. DCM ISID2-033A-8 PER RFA 94-0112	JJK	RJC	TWB	ON FILE
3	05/10/90	INC. DCM ISID2-033A-14 PER DCR 94-0028 (REF. RFA 94-0028)	JJK	RJC	TWB	ON FILE
4	05/10/90	INC. DCM ISID2-033A-13 PER DCR 94-0028 (REF. RFA 94-0028)	JJK	RJC	TWB	ON FILE
5	05/10/90	INC. DCM ISID2-033A-11 PER MOD 97-0074 SUP. 00 AND ISID2-033A-12 PER MOD 97-0074 SUP. 01	JJK	RJC	TWB	ON FILE
6	05/10/90	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	JJK	RJC	TWB	ON FILE

SCALE: N.T.S. DESIGNED: DRAWN: CB DATE: _____

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1

THE TOLSON ENGINEERING COMPANY

INSERVICE INSPECTION DIAGRAM
HIGH PRESSURE INJECTION

ISID2-033A 8