

[illegible]

- RC-CEL: 155, 100 IFORMATS, CEL AC-E7749

UPPER CONTAINMENT SPRAY RING HEADER (90 NOZZLES TOTAL)

LOWER CONTAINMENT SPRAY RING HEADER (90 NOZZLES TOTAL)

CONTAINMENT SPRAY SYSTEM

CORE FLOODING SYSTEM

LEGEND:

 - ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
 - RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
 - REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
 - ASME SECTION XI CLASS CHANGE
 - ISI PROGRAM BOUNDARY

NOTES:

 - DELETED
 - FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID-001.
 - FOR PIPING SYMBOLS AND P 8 (D) INDEX, SEE DRAWING M-001.
 - UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 1/2" AND DRAIN CONNECTIONS ARE 1/2". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
 - WHERE NOTED THE TANK CAPACITY IS NOMINAL. WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF: PCAOR 96-0976).

REVISION TABLE:

NO.	DATE	REVISIONS	BY	CHK'D	ENGR.	ENGR. SUPV.	GEN. SUPV.
1	11-13-01	INC DCM ISID-034-6 PER MOD 97-0009 SUP. 01 8 DCM ISID-034-7 PER DCM 97-0081					
2	01/16/01	INC DCM ISID-034-5 PER DCM 97-0187					
3	01/16/01	INC DCM ISID-034-10 PER DCM 01-1685					
4	08/24/00	INC DCM ISID-034-9 PER DCM 00-1766					
5	08/24/00	INC DCM ISID-034-8 PER DCM 99-0001					
6	03-17-98	ISSUED FOR SECOND 10 YEAR ISI PROGRAM					

TITLE BLOCK:

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1
INSERVICE INSPECTION DIAGRAM
EMERG. CORE COOLING SYSTEM
CTMT. SPRAY & CORE FLOODING SYSTEMS
DRAWING NO. ISID-034
REV. 7

RC-CEL: 155, 100 IFORMATS, CEL AC-E7749

LEGEND:

- ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

NOTES:

- DELETED
- FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID-001.
- FOR PIPING SYMBOLS AND P 8 (D) INDEX, SEE DRAWING M-001.
- UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 1/2" AND DRAIN CONNECTIONS ARE 1/2". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
- WHERE NOTED THE TANK CAPACITY IS NOMINAL. WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF: PCAOR 96-0976).

REVISION TABLE:

NO.	DATE	REVISIONS	BY	CHK'D	ENGR.	ENGR. SUPV.	GEN. SUPV.
1	11/13/01	INC DCM ISID-034-6 PER MOD 97-009 SUP. 01 8 DCM ISID-034-7 PER DCM 97-008					
2	01/16/01	INC DCM ISID-034-5 PER DCM 97-017					
3	01/16/01	INC DCM ISID-034-10 PER DCM 01-1685					
4	08/24/00	INC DCM ISID-034-9 PER DCM 00-1766					
5	09/17/99	INC DCM ISID-034-8 PER DCM 99-0001					
6	03/17/98	ISSUED FOR SECOND 10 YEAR ISI PROGRAM					

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1

INSERVICE INSPECTION DIAGRAM EMERG. CORE COOLING SYSTEM CTMT. SPRAY & CORE FLOODING SYSTEMS

ISID-034

7