

1P-2

4/3/97

Cycle 12

1993 - 1995 Cycle 12 598 EFP Days

↓ ~~1~~ Cold shutdown

16 DAYS in cold shutdown 1993

Cycle 13 May 95

603 EFP DAY

May 2 97

end-to-end

100% tubes - first support plate in all four SGs 1995 bobbin/Cecco
Cold leg

Sampling -

SG 21 2010

SG 22 1475

SG 23 2103

SG 24 2991

Using bobbin for full length

Sampling 200 Cecco in ~~SG~~ SG 21

first use of Cecco in

~~Handwritten signature or initials~~

SG 21	end of 1995 end	279	tube Plug
22		344	Plugs
23		256	Plugs
24		273	plugs

Denting at TSP

Scatter everywhere

Cecco
Westinghouse qualified Cecco ^{in dent} use EDM Notches

Denting	270
Cold log pitting	"
A/B wear	Play 3 tubes
re-roll	579 (541 in SG23)

Plugs

48

Plug 1150 tubes