



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D-D HVAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SNUBBER
- MS MECHANICAL SNUBBER
- N NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SWAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WOL WELD-OLET
- ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

NOTES:

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
2. THE SUPPORTS ON THE AUXILIARY FEED PUMP DISCHARGE LINE 6" EBD-14 ARE WITHIN THE ISI EXAMINATION BOUNDARY. THE PIPING WELDS IN THIS LINE ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.
3. DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

- IS102-000D AUXILIARY FEEDWATER SYSTEM
- IS102-007B STEAM GENERATOR SECONDARY SYSTEM

D-046

INCORPORATING 204F-1 FOR 204F-1001 IS GENERAL UPDATE (ADD SUPPORT TYP TO HSC-HSC & HSC-1001 & 1002 SUPPORT TWO VERIFICATION & END COMMENT	
0 9-17-80 ISSUED FOR SECOND 10 YEAR ISI PROGRAM	INITIALS ON FILE BY: CH-ENR DATE: 9-17-80
SCALE: N.T.S. DRAWING NO.: DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 THE TRUENOV COMPANY	SHEET NO.: 1
INSERVICE INSPECTION ISOMETRIC AUXILIARY FEEDWATER SYSTEM AUX. FEED PUMP DISCH. TO STEAM GENERATORS	
ISIM2-206F SHEET 3	