



- LEGEND**
- ASME SECTION XI CLASS 2 PIPING
 - ASME SECTION XI CLASS 3 PIPING
 - NON-ISI NUCLEAR CLASS AND HSC CLASS
 - PRESSURE BOUNDARY EXTENSION
 - REFERENCE & CONTINUITY
 - D-D-HVAC DUCT
 - AANCHOR
 - CSCONSTANT SPRING HANGER
 - VSVARIABLE SPRING HANGER
 - HSHYDRAULIC SNUBBER
 - MSMECHANICAL SNUBBER
 - NNON-WELDED SUPPORT ATTACHMENT
 - WWELED INTEGRAL SUPPORT ATTACHMENT
 - R RIGID SUPPORT
 - T SWAY STRUT
 - SW SHOP WELD
 - FW FIELD WELD
 - LW LONGITUDINAL WELD
 - WOL WELDOLLET
 - ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

NOTES:

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)

GENERAL NOTE

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

151D2-007A STEAM GENERATOR SECONDARY SYSTEM
 151D2-007B STEAM GENERATOR SECONDARY SYSTEM
 BARCOCK & WILCOX DRAWING 1134882
 AUXILIARY FEEDWATER INLET HEADER ASSEMBLY
 BARCOCK & WILCOX DRAWING 1134883
 AUXILIARY FEEDWATER HEADER GENERAL ARRANGEMENT

DATE N.T.S.		DESIGNED	BY	DATE
DAVIS-BESSE NUCLEAR POWER STATION		UNIT NO. 1		
INSERVICE INSPECTION ISOMETRIC		AUXILIARY FEEDWATER SYSTEM		
CONTAINMENT		DRAWING NO.		
ISIM2-206N		1		

D-050