



T04 011109 842

Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

10 CFR 50.4

NOV 09 2001

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of ) Docket Nos. 50-390  
Tennessee Valley Authority )

WATTS BAR NUCLEAR PLANT (WBN) - OCTOBER 2001 MONTHLY OPERATING  
REPORT

Enclosed is the October 2001 Monthly Operating Report as  
required by WBN Technical Specification Section 5.9.4. If you  
have any questions concerning this matter, please call me at  
(423) 365-1824.

Sincerely,

P. L. Pace  
Manager, Licensing and Industry Affairs

Enclosure  
cc: See page 2

TE24  
Rec'd FedEx  
12/17/01

U.S. Nuclear Regulatory Commission

Page 2

NOV 09 2001

cc (Enclosure):

NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Mr. L. Mark Padovan, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
MS 08G9  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303

ENCLOSURE

TENNESSEE VALLEY AUTHORITY  
WATTS BAR NUCLEAR PLANT (WBN)

MONTHLY OPERATING REPORT

OCTOBER 2001

UNIT 1

DOCKET NUMBER 50-390

LICENSE NUMBER NPF-90

## OPERATING DATA REPORT

Docket No. 50-390  
 Unit Name: WBN Unit 1  
 Date: November 5, 2001  
 Completed By: D. K. Flourney  
 Telephone: (423) 365-3803  
 Reporting Period: October 2001

1. Design Electrical Rating (MWe-Net): 1168  
 2. Maximum Dependable Capacity (MWe-Net): 1128

	<u>Month</u>	<u>Year-to-Date</u>	<u>Cumulative</u>
3. Number of Hours Reactor was Critical	<u>745</u>	<u>7014.4</u>	<u>43663.0</u>
4. Hours Generator On-Line	<u>745</u>	<u>6990.9</u>	<u>43470.2</u>
5. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
6. Net Electrical Energy Generated (MWh)	<u>861068</u>	<u>7978157</u>	<u>47738298</u>

# UNIT SHUTDOWNS

**DOCKET NO:** 50-390  
**UNIT NAME:** WBN-1  
**DATE:** November 5, 2001  
**COMPLETED BY:** D. K. Flournoy  
**TELEPHONE:** (423) 365-3803

**REPORT PERIOD: JULY 2001**

No.	Date	Type	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report No.	System Code <sup>4</sup>	Component Code <sup>4</sup>	Cause and Corrective Action to Prevent Recurrence
									The unit operated at or near full power for the entire month of October 2001. No significant power reductions or shutdowns occurred during this reporting period.

<sup>1</sup> F: Forced  
S: Scheduled

<sup>2</sup> Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training / License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H- Other (Explain)

<sup>3</sup> Method  
 1-Manual  
 2-Manual Trip/Scram  
 3-Automatic Trip/Scram  
 4-Continuation Outage  
 5-Other (Explain)

<sup>4</sup> Instructions for Preparation of  
 Data Entry sheets for Licensee  
 Event Report (LER)  
 (NUREG - 1022)

**Summary:** Watts Bar Nuclear Plant Unit 1 operated at or near 100% power for the entire month of October 2001. No significant power reductions or shutdowns occurred during this reporting period. There were no challenges to the pressurizer power operated relief valves or pressurizer safety valves during the month of October 2001.