

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Two separate and independent diesel generator sets each with:
 1. Engine-mounted fuel tanks containing a minimum of 152 gallons of fuel,
 2. A separate fuel storage system containing a minimum of 16,450 gallons of fuel, and
 3. A separate fuel transfer pump.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With one offsite circuit of 3.8.1.1.a inoperable, except as provided in Action f. below, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. Restore the offsite circuit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.
- b. With one diesel generator of 3.8.1.1.b inoperable, demonstrate the OPERABILITY of the A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and if the EDG became inoperable due to any cause other than an inoperable support system, an independently testable component, or preplanned preventative maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE EDG by performing Surveillance Requirement 4.8.1.1.2.a.4 within 8 hours, unless it can be confirmed that the cause of the inoperable EDG does not exist on the remaining EDG*; restore the diesel generator to OPERABLE status within 14 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Additionally, within 4 hours from the discovery of concurrent inoperability of required redundant feature(s) (including the steam driven auxiliary feed pump in MODE 1, 2, and 3), declare required feature(s) supported by the inoperable EDG inoperable if its redundant required feature(s) is inoperable.

* If the absence of any common-cause failure cannot be confirmed, this test shall be completed regardless of when the inoperable EDG is restored to OPERABILITY.

ELECTRICAL POWER SYSTEMS

ACTION (continued)

- c. With one offsite A.C. circuit and one diesel generator inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within one hour and at least once per 8 hours thereafter; and if the EDG became inoperable due to any cause other than an inoperable support system, an independently testable component, or preplanned preventative maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE EDG by performing Surveillance Requirement 4.8.1.1.2.a.4 within 8 hours unless it can be confirmed that the cause of the inoperable EDG does not exist on the remaining EDG*. Restore at least one of the inoperable sources to OPERABLE status within 12 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore the other A.C. power source (offsite circuit or diesel generator) to OPERABLE status in accordance with the provisions of Section 3.8.1.1 ACTION Statement a or b, as appropriate, with the time requirement of that ACTION Statement based on the time of the initial loss of the remaining inoperable A.C. power source. Additionally, within 4 hours from the discovery of concurrent inoperability of required redundant feature(s) (including the steam driven auxiliary feed pump in MODE 1, 2, and 3), declare required feature(s) supported by the inoperable EDG inoperable if its redundant required feature(s) is inoperable.
- d. With two of the required offsite A.C. circuits inoperable, restore one of the inoperable offsite sources to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours. Following restoration of one offsite source, follow ACTION Statement a. with the time requirement of that ACTION Statement based on the time of the initial loss of the remaining inoperable offsite A.C. circuit.

* If the absence of any common-cause failure cannot be confirmed, this test shall be completed regardless of when the inoperable EDG is restored to OPERABILITY.