



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-151 NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- HVAC DUCT
- ANCHOR
- CONSTANT SPRING HANGER
- VARIABLE SPRING HANGER
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- NON-WELDED SUPPORT ATTACHMENT
- WELDED INTEGRAL SUPPORT ATTACHMENT
- RIGID SUPPORT
- SWAY STRUT
- SHOP WELD
- FIELD WELD
- LONGITUDINAL WELD
- WELDLET
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

NOTES:

- MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2NWS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
- ALL LINES ON THIS DRAWING ARE PART OF THE HIGH PRESSURE SAFETY INJECTION SYSTEM.

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:
15102-030A REACTOR COOLANT SYSTEM
15102-033A HIGH PRESSURE INJECTION

D-088

INC DON 15102-233E-2 FOR DCR 91-0011		JON
15102-233E-2 FOR SECOND 10 YEAR ISI PROGRAM		INITIALS: JON FILE
NO.	DATE	REVISIONS
SCALE: N.T.S.	DESIGNED	DRAWN: CB
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1		
INSERVICE INSPECTION ISOMETRIC H. P. INJECTION SYSTEM CTMT. BLDG.		
DRAWING NO. 15102-233E		SHEET 2