



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
 - ASME SECTION XI CLASS 2 PIPING
 - ASME SECTION XI CLASS 3 PIPING
 - NON-ISI NUCLEAR CLASS AND HSC CLASS
 - PRESSURE BOUNDARY EXTENSION
 - REFERENCE B CONTINUITY
 - D-O-HVAC DUCT
 - A-ANCHOR
 - CS-CONSTANT SPRING HANGER
 - VS-VARIABLE SPRING HANGER
 - HS-HYDRAULIC SHOCKER
 - MS-MECHANICAL SHOCKER
 - N-NON-WELDED SUPPORT ATTACHMENT
 - W-WELDED INTEGRAL SUPPORT ATTACHMENT
 - R-RIGID SUPPORT
 - T-SWAY STRUT
 - SW-SHOP WELD
 - FW-FIELD WELD
 - LW-LONGITUDINAL WELD
 - WOL-WELD OLET
 - ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SHOCKERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SHOCKERS THAT ARE NOT WELDED INTERNAL TO THE PIPE).
 2. THE SPENT FUEL POOL COOLING SYSTEM LINE 3" 8" HCC-9 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10.1.2.20. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
 3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE ISI BOUNDARY ARE SHOWN FOR REFERENCE AND "CONTINUITY" PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

REFERENCE DRAWINGS:

15102-033A HIGH PRESSURE INJECTION
15102-033B DECAY HEAT TRAIN 1

D-099

ISSUED FOR SECOND 10 YEAR ISI PROGRAM	BY	DATE	REV
1	CB	10/1/80	1
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1			
INSERVICE INSPECTION ISOMETRIC CONTAINMENT SPRAY SYSTEM AND SPENT FUEL POOL COOLING SYSTEM AUXILIARY BUILDING PUMP 1-2 DISCHARGE			
ISIM2-234D (SHEET 1 OF 2)			