



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- - - ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-151 NUCLEAR CLASS A1 HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D - D HVAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SHOCKER
- MS MECHANICAL SHOCKER
- N NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SHAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WOL WELDLET
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

NOTES:

1. MULTIPLE SHAY STRUTS, SPRING SUPPORTS OR SHOCKERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SHOCKERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
2. THE SUPPORTS ON THE COMPONENT COOLING LINE 18-HBC-2, 20-HBC-2 & 14-HBC-20 ARE WITHIN THE 151 EXAMINATION BOUNDARY. THE PIPING WELDS IN THESE LINES ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.
3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

REFERENCE DRAWINGS:

15102-035A COMPONENT COOLING WATER SYSTEM

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

D-115

1	INC DCH 151M2-236D-9 PER	JOR	
2	INC DCH 151M2-236D-8 PER	INITIALS ON FILE	
3	INC DCH 151M2-236D-5 PER	INITIALS ON FILE	
4	ISSUED FOR SECOND 10 YEAR 151	CB GFB LLC MFP ECC	
5	PROGRAM		
DATE	REVISIONS	BY	CHKD
DATE	DESIGNED	DRWN	DATE
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1			
INSERVICE INSPECTION ISOMETRIC COMPONENT COOLING SYSTEM C.C. HEAT EXCHANGERS OUTLET PIPING EL. 585'-0"			
DRAWING NO.		REV.	
151M2-236D		3	
SHEET 2			

7-11-90 Lisa Bourne 30X