



# LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-151 NUCLEAR CLASS AND JC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D-D NVAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SHUBBER
- MS MECHANICAL SHUBBER
- N NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SWAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WLD WELDLET
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

# NOTES:

- MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SHUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLES: 2MS, TWO HYDRAULIC TYPE SHUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
- THE COMPONENT COOLING WATER LINE 4"-HBB-3, 3"-HBB-3, 4"-HBB-4, 3"-HBB-4 & 3"-HBB-5 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 2.2 AND 2.2.2. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
- PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
- AN 1/4" THICK BLANK PLATE HAS BEEN INSERTED BETWEEN THESE FLANGES PER MOD 98-0050-00.

# GENERAL NOTE

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

# REFERENCE DRAWINGS:

- IS102-036C COMPONENT COOLING WATER SYSTEM
- IS102-0400 REACTOR COOLANT PUMP & MOTOR

1	INC. DCM IS102-236F-14	JOR	10/1/80
2	INC. DCM IS102-236F-12	INITIALS ON FILE	10/1/80
3	INC. DCM IS102-236F-11	INITIALS ON FILE	10/1/80
4	INC. DCM IS102-236F-10	INITIALS ON FILE	10/1/80
5	ISSUED FOR SECOND TO YEAR ISI	JUN 78	10/1/80
6	PROGRAM	JUN 78	10/1/80
7	REV. 10/1/80	JUN 78	10/1/80
8	REV. 10/1/80	JUN 78	10/1/80
9	REV. 10/1/80	JUN 78	10/1/80
10	REV. 10/1/80	JUN 78	10/1/80
11	REV. 10/1/80	JUN 78	10/1/80
12	REV. 10/1/80	JUN 78	10/1/80
13	REV. 10/1/80	JUN 78	10/1/80
14	REV. 10/1/80	JUN 78	10/1/80

DAVIS-BESSE NUCLEAR POWER STATION  
UNIT NO. 1  
INSERVICE INSPECTION ISOMETRIC  
COMPONENT COOLING WATER SYSTEM  
CONTAINMENT BUILDING (P36-2)  
IS102-236F  
SHEET 31

7-11-80 Lisa Bowering 30X