



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE B CONTINUITY
- D-D-HVAC DUCT
- A-ANCHOR
- CS-CONSTANT SPRING HANGER
- VS-VARIABLE SPRING HANGER
- HS-HYDRAULIC SNUBBER
- MS-MECHANICAL SNUBBER
- N-NON-WELDED SUPPORT ATTACHMENT
- W-WELDED INTEGRAL SUPPORT ATTACHMENT
- R-RIGID SUPPORT
- T-SWAY STRUT
- SW-SHOP WELD
- FW-FIELD WELD
- LW-LONGITUDINAL WELD
- WOL-WELDLET
- ISI-ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

NOTES:

- MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT LINE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
- THE SUPPORTS ON THE COMPONENT COOLING LINE 6-HBC-26, AND 6-HBC-27 ARE WITHIN THE ISI EXAMINATION BOUNDARY. THE PIPING WELDS IN THESE LINES ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

15102-0563 COMPONENT COOLING WATER SYSTEM

INC DCM 15102-236H-3		FOR DCR 81-0011	
ISSUED FOR SECOND TO YEAR ISI		CB EFB LLC MCP ECC	
NO.	DATE	REVISIONS	BY
SCALE: N.T.S.			
DESIGNED: CB			
CHECKED: CB			
DATE: 10/1/01			
DAVIS-BESSE NUCLEAR POWER STATION			
UNIT NO. 1			
INSERVICE INSPECTION ISOMETRIC			
COMPONENT COOLING SYSTEM SUPPLY			
AND RETURN EMERG. DIESEL GENS.			
DRAWING NO.			
15102-236H			
SHEET 3			

D-125