



- NOTES:**
1. MULTIPLE WELD STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2NHS = TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
 2. THE SUPPORTS ON THE COMPONENT COOLING LINE, 6" HBC-26, AND 6" HBC-27 ARE WITHIN THE 151 EXAMINATION BOUNDARY. PIPING WELDS IN THESE LINES ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONC. JN.

REFERENCE DRAWINGS:

REFERENCE DRAWINGS:

D-126

INC DEN 151M2-236H 4 PER
DCH 191-001
ISSUED FOR SECOND 10 YEAR 151
PROGRAM

CB GFL LLC MGR ECU
GFL LLC MGR ECU

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1

INSERVICE INSPECTION ISOWTRIC
COMPONENT COOLING SYSTEM SUPPLY
AND RETURN EMERG. DIESEL GEN.

151M2-236H
SHEET 4