



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D-D-HYAC DUCT
- ANCHOR
- CONSTANT SPRING HANGER
- VARIABLE SPRING HANGER
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- NON-WELDED SUPPORT ATTACHMENT
- WELDED INTEGRAL SUPPORT ATTACHMENT
- RIGID SUPPORT
- SWAY STRUT
- SHOP WELD
- FIELD WELD
- LONGITUDINAL WELD
- WELDLET
- ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

NOTES:

- ALL PIPING ON THIS DRAWING IS 10" LISTED EXCEPT 3" HBC-56.
- THIS DRAWING TO BE WORKED WITH DRAWING 151M2-236C.
- EMBEDDED PIPING HYDROSTATIC TESTED IN ACCORDANCE WITH ASME CODE SECTION XI PRIOR TO EMBEDMENT.
- THE COMPONENT COOLING LINE 4" HBC-28 & 3" HBC-56 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 100.1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

15102-036A COMPONENT COOLING WATER SYSTEM

NO.	DATE	REVISIONS	BY	CHK'D	DATE
1	05-14-91				
<p>SCALE AS NOTED</p> <p>DESIGNER: [Signature]</p> <p>DATE: 05-14-91</p> <p>DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1</p> <p>INSERVICE INSPECTION ISOMETRIC COMPONENT COOLING SYSTEM EMBEDDED PIPING-CONTROL ROOM FLOOR EL. 623'-0"</p> <p>PROJECT NO. [Blank]</p> <p>151M2-236J</p>					

D-127