



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
  - ASME SECTION XI CLASS 2 PIPING
  - ASME SECTION XI CLASS 3 PIPING
  - NON-ISI NUCLEAR CLASS AND HSC CLASS
  - PRESSURE BOUNDARY EXTENSION
  - REFERENCE & CONTINUITY
  - D-D-HVAC DUCT
  - AANCHOR
  - CSCONSTANT SPRING HANGER
  - VSVARIABLE SPRING HANGER
  - HSHYDRAULIC SNUBBER
  - MSMECHANICAL SNUBBER
  - NNON-WELDED SUPPORT ATTACHMENT
  - WWELED INTEGRAL SUPPORT ATTACHMENT
  - R RIGID SUPPORT
  - T SWAY STRUT
  - SW SHOP WELD
  - FW FIELD WELD
  - LW LONGITUDINAL WELD
  - WOL WELDLET
  - ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLES: 2MS - TWO MECHANICAL TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
  2. THE SERVICE WATER LINE 20-HBC-43 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 100.1200. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

**GENERAL NOTE**  
DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**  
IS102-041B PRIMARY SERVICE WATER SYSTEM

D-135

INC. DCN IS102-241C-2 FOR DCN 91-0011	JFS	YK
ISSUED FOR SECOND 10 YEAR ISI PROGRAM	CB	EFB TMB MCP ECC
REV	DESCRIPTION	DATE
1	REVISED	10/1/00
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1		
INSERVICE INSPECTION ISOMETRIC SERVICE WATER SYSTEM AUXILIARY BUILDING-SUPPLY PIPING		
DRAWING NO.		REV.
ISIM2-241C		1
SHEET 1		1