



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-151 NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D-D-HVAC DUCT
- AANCHOR
- CSCONSTANT SPRING HANGER
- VSVARIABLE SPRING HANGER
- HSHYDRAULIC SNUBBER
- MSMECHANICAL SNUBBER
- NNON-WELDED SUPPORT ATTACHMENT
- WWELDED INTEGRAL SUPPORT ATTACHMENT
- RRIGID SUPPORT
- TSWAY STRUT
- SWSHOP WELD
- FWFIELD WELD
- LWLONGITUDINAL WELD
- WDLWELDLET
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

NOTES:

- MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2NHS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
- DELETED.
- THE SUPPORTS ON THE SERVICE WATER LINE 8" HBC-37.8 10" HBC-37 ARE WITHIN THE 151 EXAMINATION BOUNDARY. THE PIPING WELDS IN THESE LINES ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.

GENERAL NOTE

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

- 15102-041B PRIMARY SERVICE WATER SYSTEM
- 15102-041C SERVICE WATER SYSTEM FOR CONTAINMENT AIR COOLERS

D-137

1	INC DEN 15102-241D-11 FOR	JP5	SP	MS	-
2	INC DEN 15102-241D-10 FOR	JP5	SP	MS	-
3	INC DEN 15102-241D-9 PER	JP5	SP	MS	-
4	INC DEN 15102-241D-8 PER	JP5	SP	MS	-
5	ISSUED FOR SECOND 10 YEAR 151	CB	CD	LLC	ECC
6	PROPOSAL	CB	CD	LLC	ECC
NO.	DATE	REVISIONS	BY	CHKD	APPD
SCALE	N.T.S.	DESIGNED	DRWING	CB	DATE
DAVIS-BESSE NUCLEAR POWER STATION					
UNIT NO. 1					
INSERVICE INSPECTION ISOMETRIC					
SERVICE WATER SYSTEM					
AUXILIARY BUILDING - RETURN PIPING					
DRAWING NO.					
SHEET 1					
14 3644 1/2 SIZE					