

LEGEND

- ASME SECTION XI CLASS 1 PIPING
ASME SECTION XI CLASS 2 PIPING
ASME SECTION XI CLASS 3 PIPING
NON-151 NUCLEAR CLASS AND HSC CLASS
PRESSURE BOUNDARY EXTENSION
REFERENCE & CONTINUITY
HVAC DUCT
ANCHOR
CONSTANT SPRING HANGER
VARIABLE SPRING HANGER
HYDRAULIC SNUBBER
MECHANICAL SNUBBER
NON-WELDED SUPPORT ATTACHMENT
WELDED INTEGRAL SUPPORT ATTACHMENT
RIGID SUPPORT
SWAY STRUT
SHOP WELD
FIELD WELD
LONGITUDINAL WELD
WELDLET

NOTES:

1. THERE ARE NO SPOOL NUMBERS ON THIS DRAWING.
2. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2NHS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
3. THE SUPPORTS ON THE SERVICE WATER LINE 6" HBC-43 ARE WITHIN THE 151 EXAMINATION BOUNDARY. THE PIPING WELDS IN THIS LINE ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.
4. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

REFERENCE DRAWINGS:

15102-0418 PRIMARY SERVICE WATER SYSTEM

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

D-147

NO.	REV.	DATE	BY	CHKD.	APP.
1	1	10/1/00	JON	CB	ECC
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 INSERVICE INSPECTION ISOMETRIC SERVICE WATER SYSTEM AUXILIARY BLDG-SUPPLY TO MOTOR DRIVEN FEED PUMP					
ISIM2-241M					1