

January 9, 2002

LICENSEE: Duke Energy Corporation

FACILITY: McGuire Nuclear Station, Units 1 and 2

SUBJECT: SUMMARY - MEETING WITH DUKE ENERGY ON SPENT FUEL POOL
BORAFLEX UPDATE (TAC NOS. MB3570 AND MB3571)

Representatives of Duke Energy Corporation (DEC), met with members of the U.S. Nuclear Regulatory Commission (NRC) staff at NRC Headquarters on December 11, 2001, in Rockville, Maryland. DEC requested this meeting to provide an update on the McGuire spent fuel pool (SFP) boraflex issue and to outline their plans for the future submittal of a license amendment application dealing with the issue. A list of attendees is provided in Attachment 1.

An amendment to the McGuire Technical Specifications (TS) was issued on November 27, 2000, to allow credit for soluble boron in the SFP criticality analyses. The analyses account for a credit for the degraded spent fuel rack Boraflex neutron absorber panels. The McGuire SFP consists of two fuel pools with a two-region design. Region one is designed for storage of new and recently discharged fuel. Region 2 is designed for long-term storage of burned fuel assemblies. Based on allowance for partial Boraflex credit, the regions are further divided into Alpha and Bravo sub-regions. Alpha areas of Region 1 take credit for 25% of the Boraflex and Alpha areas of Region 2 take credit for 50% of the Boraflex. Bravo areas of Regions 1 and 2 take no credit for Boraflex and result in severe storage restrictions for affected and surrounding cells. Further details of Duke's presentation are provided in Attachment 2.

Duke described its overall plan for management of SFP storage capacity and indicated that part of its near-term plan is to request a TS amendment to change the threshold for Alpha to Bravo from 50% to 40% Boraflex credit. This would extend the critical need date to the end of 2005. It would result in more restrictive storage requirement for Alpha cells but would reduce the number of Bravo cells. Duke indicated that this TS amendment request would be identical in all other aspects to the application that was approved by NRC on November 27, 2000. Duke indicated that it planned to submit this TS amendment in March 2002 and requested the NRC staff's views regarding whether it could be acted on by December 2002.

The NRC staff identified a need for information on Duke's use of the RACKLIFE and BADGER programs. This informational need is similar to that identified for other licensees but is specific to Duke's use for the McGuire plant. See, for example, the request for additional information from the NRC staff to Entergy Nuclear Operations, for the Indian Point Unit 2 plant dated November 30, 2001. The staff suggested that one beneficial approach to this issue could be for Duke to prepare a presentation on this issue and meet with the staff again early in 2002.

Subject to the resolution of these additional information needs for RACKLIFE and BADGER, the staff indicated that it is likely that the staff could reach a finding on an application submitted in March 2002 by December 2002, which is Duke's indicated date of need for a finding.

/RA/

Robert E. Martin, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Attachments: 1. Attendance List
2. Duke Presentation

cc w/atts: See next page

January 9, 2002

Subject to the resolution of these additional information needs for RACKLIFE and BADGER, the staff indicated that it is likely that the staff could reach a finding on an application submitted in March 2002 by December 2002, which is Duke's indicated date of need for a finding.

/RA/

Robert E. Martin, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Attachments: 1. Attendance List
2. Duke Presentation

cc w/atts: See next page

DISTRIBUTION:

PUBLIC	RLaufer	ACRS	CHaruck	SColpo	Rll
PDII-1 R/F	RMartin	OGC	SJones	RTaylor	
JZwolinski/TMarsh	CPatel	FAkstulewicz	AAttard	GShukla	
HBerkow	CHawes	BThomas	YOrechwa	JDonahew	

Accession Number: ML013600458

*See previous concurrence

OFC	PDII-1/PM	PDII-1/LA	PDII-1/ASC	SRXB
NAME	RMartin	CHawes	RLaufer	FAktulewicz*
DATE	1/9/02	1/7/02	1/9/02	1/4/02

OFFICIAL RECORD COPY

ATTENDEES LIST

DECEMBER 11, 2001

MEETING WITH DUKE ENERGY

<u>NAME</u>	<u>ORGANIZATION</u>
Bob Matin	NRC/NRR/DLPM
Francis Akstulewicz	NRC/SRXB
Brian Thomas	NRC/SPLB
Steven Jones	NRC/SPLB
Jimmy Glenn	Duke/McG Engineering
David Jones	Duke/SFP Management
Keith Waldrop	Duke/SFP Management
Marcus Nichol	Duke/SFP Management
Norman Simms	Duke/McG Reg Compliance
Craig Harbuck	NRC/RTSB
Tony Attard	NRC/SRXB
Yuri Orechwa	NRC/SRXB
Sarah Colpo	NRC/SRXB
Robert Taylor	NRC/SRXB
Girija Shukla	NRC/DLPM
Jack Donahew	NRC/PD IV-2

McGuire Nuclear Station

cc:

Ms. Lisa F. Vaughn
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

County Manager of
Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Michael T. Cash
Regulatory Compliance Manager
Duke Energy Corporation
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Anne Cottingham, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Peter R. Harden, IV
VP-Customer Relations and Sales
Westinshouse Electric Company
6000 Fairview Road
12th Floor
Charlotte, North Carolina 28210

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health and Natural
Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745