

INDIAN POINT 2 - 10 CFR 2.206 DECISION BASES

- The petition includes a request for enforcement action, in that the petitioners request that the NRC order IP2 to remain shutdown until the petition issues are resolved.
- The petition is plant specific, in that it applies specifically to IP2. The petition identifies that IP2 is the only plant still operating with Model 44 steam generators, and they state that these steam generators have numerous tubes with crack indications.
- An actual event occurred at IP2 which resulted in the petition.
- The petition clearly and directly states that it is being submitted in accordance with 10 CFR 2.206.
- The petition provides specific basis for the request, which includes the Model steam generators installed at IP2, the tube inspection results, the tube rupture that occurred, and how the petitioners feel these bases affect the safe operation of the facility.
- Additional statement was made in phone call that petitioners have information which they believe indicates that calculations done for auxiliary feedwater heat transfer removal, following transients, improperly account for the number of S/G tubes plugged.

J/184