

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

- 1) Identification of a sampling schedule for the critical variables and control points for these variables,
- 2) Identification of the procedures used to measure the values of the critical variables,
- 3) Identification of process sampling points, including monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
- 4) Procedures for the recording and management of data,
- 5) Procedures defining corrective actions for all off-control point chemistry conditions,
- 6) A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Not Used

e. Radioactive Effluent Controls Program

A program shall be provided conforming with 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program (1) shall be contained in the ODCM, (2) shall be implemented by operating procedures, and (3) shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- 1) Limitations on the operability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determinations in accordance with the methodology in the ODCM;
- 2) Limitations on the concentration of radioactive material released in liquid effluents to unrestricted areas conforming to 10 times the concentration values in 10 CFR Part 20, Appendix B, Table 2, Column 2;