

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

November 26, 2001

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 01-714
NLOS/ETS
Docket No. 50-338
License No. NPF-4

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 1
ASME SECTION XI INSERVICE INSPECTION PROGRAM RELIEF REQUEST
NDE PARTIAL-2 REQUEST FOR ADDITIONAL INFORMATION

In a letter dated January 29, 2001 (Serial No. 01-023), Virginia Electric and Power Company (Dominion) requested relief from certain requirements of ASME Section XI Code associated with examinations where only partial coverage could be obtained due to interferences and weld geometry. In a telephone conference call on November 15, 2001, the NRC staff requested additional information concerning the construction code inspection requirements performed during the pre-service examination of Weld 11 at check valve 1-CH-279 on line 3"-CH-81-1502. The construction code inspection requirements of ANSI B31.7, 1969 Edition, 1970 Addenda were met, which included radiography of the weld.

If you have any additional questions concerning this request, please contact us.

Very truly yours,



Leslie N. Hartz
Vice President - Nuclear Engineering and Services

Commitments made in this letter:

None

A047

cc: U. S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Mr. M. J. Morgan
NRC Senior Resident Inspector
North Anna Power Station

Mr. M. M. Grace
Authorized Nuclear Inspector
North Anna Power Station

Mr. J. A. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, Virginia 23060